


VENTILATION AUDIT REPORT

SCHOOL:	Karningul School (5581)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Bankstown
LOCAL GOVERNMENT AREA:	Canterbury-Bankstown

5581 - Karningul School
Site Plan (11969)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Clerical Office/Workroom - (7.76 SQM)	Office (1)	
B00A - R0002 - Staff Kitchen - (12.89 SQM)	Office (3)	
B00A - R0004 - Movement - (12.64 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Interview - (13.25 SQM)	Office (3)	
B00A - R0007 - Movement - (5.34 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Staff Room - (22.36 SQM)	Office (5)	
B00A - R0009 - Clerical Office - (15.61 SQM)	Office (3)	
B00A - R0010 - Movement - (5.83 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Staff Room - (12.4 SQM)	Office (3)	
B00A - R0012 - Principal - (16.15 SQM)	Office (4)	
B00B - R0002 - Practical Activities - 1hb - (20.04 SQM)	Student Space (9)	
B00B - R0004 - Home Base - (60.34 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0005 - Withdrawal Space - 2hb - (11.3 SQM)	Student Space (5)	
B00B - R0006 - Home Base - (60.49 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0008 - Practical Activities - 1hb - (19.92 SQM)	Student Space (9)	
B00B - R1002 - Practical Activities - 1hb - (19.98 SQM)	Student Space (9)	
B00B - R1004 - Home Base - (60.25 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R1005 - Withdrawal Space - 2hb - (11.31 SQM)	Student Space (5)	
B00B - R1006 - Home Base - (60.47 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R1008 - Practical Activities - 1hb - (18.85 SQM)	Student Space (8)	