

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Karuah Public School (2263)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Port Stephens</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Port Stephens</b>

2263 - Karuah Public School  
Site Plan (12564)





















1:541

Printed: 29-May-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0007 - Practical Activities - 1hb - (9.76 SQM)	 Student Space (4)	
B00A - R0008 - Communal Space - (83.69 SQM)	 Student Space (38)	
B00A - R0009 - Movement - (74.24 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Communal Space - (59.13 SQM)	 Student Space (27)	
B00A - R0011 - Practical Activities - 1hb - (10.96 SQM)	 Student Space (5)	
B00A - R0013 - Staff Room - (25.09 SQM)	 Office (6)	
B00A - R0019 - Home Base - (57.52 SQM) - Teaching Space: 1	 Student Space (26)	
B00A - R0022 - Clerical Office/Workroom - (11.08 SQM)	 Office (2)	
B00A - R0023 - Principal - (15.1 SQM)	 Office (3)	
B00B - R0004 - Reading Area - (89.82 SQM)	 Student Space (41)	
B00C - R0002 - Canteen - (37.02 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Home Base - (41.09 SQM) - Teaching Space: 1	 Student Space (19)	
B00D - R0006 - Special Programs Room - (40.7 SQM)	 Student Space (18)	
B00E - R0001 - Home Base - (91.05 SQM) - Teaching Space: 1	 Student Space (42)	
B00F - R0002 - Practical Activities - 1hb - (19.84 SQM)	 Student Space (9)	
B00F - R0004 - Home Base - (58.11 SQM) - Teaching Space: 1	 Student Space (26)	
B00F - R0005 - Withdrawal Space - 2hb - (10.67 SQM)	 Student Space (4)	
B00F - R0006 - Home Base - (58.11 SQM) - Teaching Space: 1	 Student Space (26)	
B00F - R0008 - Practical Activities - 1hb - (19.84 SQM)	 Student Space (9)	
OS 602 14608 - OS 602 14608 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	