

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Katoomba Public School (4546)</b>
<b>AMU REGION:</b>	<b>Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Blue Mountains</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Blue Mountains</b>

4546 - Katoomba Public School  
Site Plan (13199)



1:968


Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (58.96 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0003 - Withdrawal Space - 1hb - (11.15 SQM)	● Student Space (5)	
B00A - R0005 - Home Base - (59.43 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0007 - Practical Activities - 1hb - (54.74 SQM)	● Student Space (25)	
B00A - R0008 - Practical Activities - 1hb - (48.84 SQM)	● Student Space (22)	
B00A - R0009 - Practical Activities - 1hb - (37.17 SQM)	● Student Space (17)	
B00A - R0011 - Home Base - (59.12 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0013 - Withdrawal Space - 1hb - (11.25 SQM)	● Student Space (5)	
B00A - R0015 - Home Base - (60.45 SQM) - Teaching Space: 1	● Student Space (28)	
B00A - R0016 - Movement - (54.44 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Movement - (10.04 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Withdrawal Space - 1hb - (15.88 SQM)	● Student Space (7)	
B00A - R0024 - Practical Activities - M - 1hb - (13.99 SQM)	● Student Space (6)	
B00A - R0025 - Home Base - M - (45.87 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0026 - Movement - (19.66 SQM)	Not Applicable	Circulation or storage space.
B00A - R0027 - Movement - (7.94 SQM)	Not Applicable	Circulation or storage space.
B00A - R0029 - Practical Activities - 1hb - (14.47 SQM)	● Student Space (6)	
B00A - R0030 - Home Base - (46.14 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0036 - Movement - (14.28 SQM)	Not Applicable	Circulation or storage space.
B00A - R0037 - Duplicating Workroom - (29.59 SQM)	● Office (7)	
B00A - R0038 - Clerical Office - (16.73 SQM)	● Office (4)	
B00A - R0039 - Sick Bay - (6.46 SQM)	● Student Space (2)	
B00A - R0041 - Entry Vestibule - (14.62 SQM)	Not Applicable	Circulation or storage space.
B00A - R0042 - Movement - (6.19 SQM)	Not Applicable	Circulation or storage space.
B00A - R0043 - Principal - (26.36 SQM)	● Office (6)	
B00A - R0044 - Interview - (14.82 SQM)	● Office (3)	
B00A - R0045 - Deputy Principal - (13.76 SQM)	● Office (3)	
B00A - R0046 - Interview - (16.02 SQM)	● Office (4)	
B00A - R0053 - Movement - (13.39 SQM)	Not Applicable	Circulation or storage space.
B00A - R0054 - Movement - (53.81 SQM)	Not Applicable	Circulation or storage space.
B00A - R0055 - Movement - (74.33 SQM)	Not Applicable	Circulation or storage space.
B00A - R0056 - Movement - (66.38 SQM)	Not Applicable	Circulation or storage space.
B00A - R0057 - Movement - (11.27 SQM)	Not Applicable	Circulation or storage space.
B00A - R0058 - Movement - (10.73 SQM)	Not Applicable	Circulation or storage space.
B00A - R0063 - Movement - (68.02 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Home Base - (65.48 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R1003 - Withdrawal Space - 1hb - (12.44 SQM)	● Student Space (5)	
B00A - R1006 - Practical Activities - 1hb - (38.66 SQM)	● Student Space (17)	
B00A - R1008 - Home Base - (62.54 SQM) - Teaching Space: 1	● Student Space (29)	
B00A - R1010 - Special Programs Room - (26.1 SQM)	● Student Space (12)	
B00A - R1014 - Movement - (25.77 SQM)	Not Applicable	Circulation or storage space.
B00A - R1019 - Special Programs Room - (44.5 SQM)	● Student Space (20)	
B00A - R1020 - Practical Activities - 1hb - (22.6 SQM)	● Student Space (10)	
B00A - R1021 - Home Base - (64.06 SQM) - Teaching Space: 1	● Student Space (29)	
B00A - R1022 - Withdrawal Space - 1hb - (12.01 SQM)	● Student Space (5)	
B00A - R1023 - Interview - (13.4 SQM)	● Office (3)	
B00A - R1025 - Practical Activities - 1hb - (30.16 SQM)	● Student Space (13)	
B00A - R1026 - Home Base - (64.25 SQM) - Teaching Space: 1	● Student Space (29)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R1028 - Staff Room - (68.92 SQM)	Office (17)	
B00A - R1034 - Movement - (12.27 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Movement - (42.7 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Communal Space - (196.29 SQM)	Student Space (91)	
B00B - R0007 - Movement - (19 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Raised Platform - (76.05 SQM)	Not Applicable	Circulation or storage space.
B00B - R0010 - Movement - (30.17 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Canteen - (27.16 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Movement - (16.74 SQM)	Not Applicable	Circulation or storage space.
B00B - R0021 - Movement - (5.81 SQM)	Not Applicable	Circulation or storage space.
B00B - R0024 - Movement - (6.67 SQM)	Not Applicable	Circulation or storage space.
B00B - R0025 - Movement - (14.24 SQM)	Not Applicable	Circulation or storage space.
B00B - R0026 - Movement - (35.5 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Special Programs Room - (47.42 SQM)	Student Space (22)	
B00C - R0005 - Reading Area - (195.51 SQM)	Student Space (90)	
B00C - R0013 - Seminar/Study - (8.7 SQM)	Office (2)	
B00C - R0014 - Seminar/Study - (8.64 SQM)	Office (2)	
B00C - R0018 - Movement - (70.56 SQM)	Not Applicable	Circulation or storage space.
B00C - R0019 - Movement - (21.86 SQM)	Not Applicable	Circulation or storage space.
B00C - R0020 - Movement - (6.3 SQM)	Not Applicable	Circulation or storage space.
B00C - R0021 - Movement - (85.18 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Movement - (30.57 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Practical Activities - 1hb - (25.77 SQM)	Student Space (11)	
B00D - R0004 - Home Base - (56.96 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0005 - Withdrawal Space - 1hb - (12.35 SQM)	Student Space (5)	
B00D - R0006 - Home Base - (56.57 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0009 - Movement - (21.63 SQM)	Not Applicable	Circulation or storage space.
B00D - R0010 - Practical Activities - 1hb - (26.02 SQM)	Student Space (12)	
B00D - R0011 - Home Base - (57.92 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0012 - Withdrawal Space - 1hb - (12.42 SQM)	Student Space (5)	
B00D - R0014 - Home Base - (58 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0021 - Movement - (13.88 SQM)	Not Applicable	Circulation or storage space.
B00D - R0022 - Practical Activities - 1hb - (38.47 SQM)	Student Space (17)	
B00D - R0023 - Movement - (23.99 SQM)	Not Applicable	Circulation or storage space.
B00D - R0024 - Staff Room Annexe - (14.47 SQM)	Office (3)	
B00D - R0025 - Movement - (16.43 SQM)	Not Applicable	Circulation or storage space.
B00D - R0026 - Movement - (5.76 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Movement - (30.52 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Practical Activities - 1hb - (25.74 SQM)	Student Space (11)	
B00E - R0004 - Home Base - (56.84 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0005 - Withdrawal Space - 1hb - (12.28 SQM)	Student Space (5)	
B00E - R0006 - Home Base - (56.56 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0009 - Movement - (21.69 SQM)	Not Applicable	Circulation or storage space.
B00E - R0010 - Practical Activities - 1hb - (25.95 SQM)	Student Space (12)	
B00E - R0011 - Home Base - (57.94 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0012 - Withdrawal Space - 1hb - (12.35 SQM)	Student Space (5)	
B00E - R0014 - Home Base - (58.08 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0020 - Movement - (13.72 SQM)	Not Applicable	Circulation or storage space.
B00E - R0021 - Practical Activities - 1hb - (43.35 SQM)	Student Space (20)	
B00E - R0022 - Movement - (18.29 SQM)	Not Applicable	Circulation or storage space.
B00E - R0023 - Staff Room Annexe - (14.5 SQM)	Office (3)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0024 - Movement - (16.71 SQM)	Not Applicable	Circulation or storage space.
B00E - R0025 - Movement - (5.87 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Communal Space - (276.5 SQM)	 Student Space (128)	