

VENTILATION AUDIT REPORT

SCHOOL:	Keira High School (8541)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Keira
LOCAL GOVERNMENT AREA:	Wollongong

8541 - Keira High School
Site Plan (13205)



1:3,248

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Gymnasium - (287.9 SQM)	● Student Space (133)	
B00B - R0001 - Duplicating Workroom - (26.88 SQM)	● Office (6)	
B00B - R0002 - Administration - Clerical - (38.62 SQM)	● Office (9)	
B00B - R0003 - Movement - (11.93 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Clinic - Boys - (13.57 SQM)	● Office (3)	
B00B - R0006 - Clinic - Girls - (13.49 SQM)	● Office (3)	
B00B - R0009 - Administration - Clerical - (10.83 SQM)	● Office (2)	
B00B - R0010 - Principal Office - (22.36 SQM)	● Office (5)	
B00B - R0011 - Leading Teacher - (12.12 SQM)	● Office (3)	
B00B - R0013 - Staff Study - (14.3 SQM)	● Office (3)	
B00B - R0018 - Deputy Principal Office - (29.4 SQM)	● Office (7)	
B00B - R0022 - Commonroom - (52.97 SQM)	● Office (13)	
B00B - R0024 - Deputy Principal Office - (21.41 SQM)	● Office (5)	
B00B - R0025 - Movement - (16.9 SQM)	Not Applicable	Circulation or storage space.
B00B - R0026 - General Learning Space - (53.23 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0027 - General Learning Space - (53.07 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0028 - General Learning Space - (53.07 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0029 - General Learning Space - (53.07 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0030 - Staff Study - (7.84 SQM)	● Office (1)	
B00B - R0032 - General Learning Space - (52.33 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0033 - Laboratory L.S. - (89.93 SQM) - Teaching Space: 1	● Student Space (41)	
B00B - R0034 - Preparation - Science - (15.87 SQM)	Not Applicable	Circulation or storage space.
B00B - R0038 - Special Learning Space - (53.07 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0040 - General Learning Space - (53.07 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0042 - Movement - (29.42 SQM)	Not Applicable	Circulation or storage space.
B00B - R0045 - Public Entry - (48.36 SQM)	Not Applicable	Circulation or storage space.
B00B - R0046 - Movement - (52.6 SQM)	Not Applicable	Circulation or storage space.
B00B - R0051 - Withdrawal - S - (9.7 SQM)	● Student Space (4)	
B00B - R0053 - Staff Study - (24.15 SQM)	● Office (6)	
B00B - R0054 - Movement - (14.19 SQM)	Not Applicable	Circulation or storage space.
B00B - R0055 - Movement - (267.32 SQM)	Not Applicable	Circulation or storage space.
B00B - R1003 - Staff Study - (38.64 SQM)	● Office (9)	
B00B - R1007 - General Learning Space - (53.07 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1008 - General Learning Space - (53.07 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1009 - General Learning Space - (53.07 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1010 - General Learning Space - (53.07 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1011 - General Learning Space - (53.07 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1012 - Computer Learning Space - (53.07 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1018 - Commonroom - (146.29 SQM)	● Office (36)	
B00B - R1019 - General Learning Space - (52.91 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1020 - Preparation - (15.51 SQM)	Not Applicable	Circulation or storage space.
B00B - R1021 - Laboratory L.S. - (89.6 SQM) - Teaching Space: 1	● Student Space (41)	
B00B - R1025 - Movement - (8.71 SQM)	Not Applicable	Circulation or storage space.
B00B - R1028 - Movement - (251.72 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Movement - (80.04 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Laboratory L.S. - (85.75 SQM) - Teaching Space: 1	● Student Space (39)	
B00C - R0004 - Preparation - (20.1 SQM)	Not Applicable	Circulation or storage space.
B00C - R1004 - General Learning Space - (52.56 SQM) - Teaching Space: 1	● Student Space (24)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R1005 - General Learning Space - (52.24 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1011 - Movement - (62.41 SQM)	Not Applicable	Circulation or storage space.
B00C - R2001 - Staff Study - (25.55 SQM)	● Office (6)	
B00C - R2002 - Special Learning Space - (52.49 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R2003 - General Learning Space - (52.17 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R2006 - Movement - (51.1 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - General Assistants - (18.18 SQM)	● Office (4)	
B00E - R0001 - Materials Technology L.S. - (134.19 SQM) - Teaching Space: 1	● Student Space (62)	
B00E - R0002 - Materials Technology L.S. - (111.38 SQM) - Teaching Space: 1	● Student Space (51)	
B00E - R0003 - Seminar/Technology Space - (21.86 SQM)	● Office (5)	
B00E - R0006 - Materials Technology L.S. - (103.52 SQM) - Teaching Space: 1	● Student Space (48)	
B00E - R0011 - Design L.S. - (74.72 SQM) - Teaching Space: 1	● Student Space (34)	
B00E - R0014 - Staff Study - (35.52 SQM)	● Office (8)	
B00E - R0017 - Design L.S. - (80 SQM) - Teaching Space: 1	● Student Space (37)	
B00E - R0018 - Materials Technology L.S. - (103.52 SQM) - Teaching Space: 1	● Student Space (48)	
B00E - R0021 - Movement - (143.23 SQM)	Not Applicable	Circulation or storage space.
B00E - R0023 - Art Learning Space - (60.06 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R0026 - Darkroom Space - (54.52 SQM)	● Office (13)	
B00E - R0027 - Art Learning Space - (81.62 SQM) - Teaching Space: 1	● Student Space (37)	
B00E - R0028 - Staff Study - (16.16 SQM)	● Office (4)	
B00E - R0033 - Computer Learning Space - (50.64 SQM) - Teaching Space: 1	● Student Space (23)	
B00E - R0034 - Movement - (5.54 SQM)	Not Applicable	Circulation or storage space.
B00E - R0035 - Movement - (41.27 SQM)	Not Applicable	Circulation or storage space.
B00E - R0036 - Movement - (8.24 SQM)	Not Applicable	Circulation or storage space.
B00E - R0037 - Art Learning Space - (76.85 SQM) - Teaching Space: 1	● Student Space (35)	
B00G - R0004 - Movement - (22.1 SQM)	Not Applicable	Circulation or storage space.
B00G - R0005 - General Learning Space - (53.57 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0006 - General Learning Space - (53.87 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0007 - General Learning Space - (52.99 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0008 - General Learning Space - (53.72 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0009 - Stage - (26.2 SQM)	Not Applicable	Circulation or storage space.
B00G - R0017 - Movement - (319.9 SQM)	Not Applicable	Circulation or storage space.
B00G - R0018 - Student Canteen - (43.64 SQM)	Not Applicable	Circulation or storage space.
B00G - R0025 - Laboratory L.S. - (87.14 SQM) - Teaching Space: 1	● Student Space (40)	
B00G - R0026 - Preparation - (29.34 SQM)	Not Applicable	Circulation or storage space.
B00G - R0027 - Growing/Breeding - (9.57 SQM)	Not Applicable	Circulation or storage space.
B00G - R0028 - Laboratory L.S. - (87.41 SQM) - Teaching Space: 1	● Student Space (40)	
B00G - R0032 - Interview - (7.07 SQM)	● Office (1)	
B00G - R0033 - Movement - (27.88 SQM)	Not Applicable	Circulation or storage space.
B00G - R0041 - Movement - (119.29 SQM)	Not Applicable	Circulation or storage space.
B00G - R1001 - Movement - (16.8 SQM)	Not Applicable	Circulation or storage space.
B00G - R1005 - Study Space - (12.99 SQM)	Not Applicable	Circulation or storage space.
B00G - R1006 - Study Space - (12.99 SQM)	Not Applicable	Circulation or storage space.
B00G - R1007 - General Learning Space - (66.88 SQM) - Teaching Space: 1	● Student Space (31)	
B00G - R1008 - Study Space - (12.96 SQM)	Not Applicable	Circulation or storage space.
B00G - R1009 - Study Space - (12.99 SQM)	Not Applicable	Circulation or storage space.
B00G - R1010 - Staff Study - (56.96 SQM)	● Office (14)	
B00G - R1013 - Staff Study - (27.67 SQM)	● Office (6)	
B00G - R1014 - General Learning Space - (54.31 SQM) - Teaching Space: 1	● Student Space (25)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R1016 - General Learning Space - (55.87 SQM) - Teaching Space: 1	Student Space (25)	
B00G - R1017 - Computer Learning Space - (81.1 SQM) - Teaching Space: 1	Student Space (37)	
B00G - R1018 - Computer Learning Space - (53.94 SQM) - Teaching Space: 1	Student Space (25)	
B00G - R1019 - Staff Study - (29.08 SQM)	Office (7)	
B00G - R1023 - Laboratory L.S. - (87.21 SQM) - Teaching Space: 1	Student Space (40)	
B00G - R1026 - Laboratory L.S. - (87.73 SQM) - Teaching Space: 1	Student Space (40)	
B00G - R1029 - General Learning Space - (53.43 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R1032 - Movement - (7.18 SQM)	Not Applicable	Circulation or storage space.
B00G - R1036 - Staff Study - (38.95 SQM)	Office (9)	
B00G - R1039 - Movement - (213.72 SQM)	Not Applicable	Circulation or storage space.
B00G - R2001 - Movement - (16.87 SQM)	Not Applicable	Circulation or storage space.
B00G - R2004 - Senior Study - (17.6 SQM)	Office (4)	
B00G - R2005 - General Learning Space - (53.36 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R2006 - General Learning Space - (53.58 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R2007 - General Learning Space - (53.58 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R2011 - General Learning Space - (57.85 SQM) - Teaching Space: 1	Student Space (26)	
B00G - R2014 - Practice/Seminar - (53.95 SQM)	Not Applicable	Circulation or storage space.
B00G - R2017 - Practice/Seminar - (26.57 SQM)	Not Applicable	Circulation or storage space.
B00G - R2018 - General Learning Space - (64.97 SQM) - Teaching Space: 1	Student Space (30)	
B00G - R2019 - Practice/Seminar - (28.64 SQM)	Not Applicable	Circulation or storage space.
B00G - R2020 - Computer Learning Space - (53.5 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R2021 - Staff Study - (26.79 SQM)	Office (6)	
B00G - R2023 - Movement - (76.52 SQM)	Not Applicable	Circulation or storage space.
B00G - R2026 - General Learning Space - (51.43 SQM) - Teaching Space: 1	Student Space (23)	
B00G - R2029 - General Learning Space - (53.87 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R2030 - General Learning Space - (53.87 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R2032 - General Learning Space - (53.87 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R2036 - Movement - (7.19 SQM)	Not Applicable	Circulation or storage space.
B00G - R2037 - Staff Study - (27.46 SQM)	Office (6)	
B00G - R2042 - Movement - (135.38 SQM)	Not Applicable	Circulation or storage space.
B00H - R0005 - Food Technology L.S. - (102.93 SQM) - Teaching Space: 1	Student Space (47)	
B00H - R0006 - Preparation - Materials - (18.43 SQM)	Not Applicable	Circulation or storage space.
B00H - R0008 - Food Technology L.S. - (103.08 SQM) - Teaching Space: 1	Student Space (47)	
B00H - R0009 - Design L.S. - (65.85 SQM) - Teaching Space: 1	Student Space (30)	
B00H - R0011 - General Learning Space - (67.35 SQM) - Teaching Space: 1	Student Space (31)	
B00H - R0014 - Staff Kitchen - (5.46 SQM)	Office (1)	
B00H - R0015 - Staff Study - (17.52 SQM)	Office (4)	
B00H - R0017 - Movement - (81.3 SQM)	Not Applicable	Circulation or storage space.
B00H - R0018 - Food Technology L.S. - (41.2 SQM) - Teaching Space: 1	Student Space (19)	
B00H - R1002 - Movement - (13.74 SQM)	Not Applicable	Circulation or storage space.
B00H - R1005 - Main Area - (444.79 SQM)	Not Applicable	Circulation or storage space.
B00H - R1006 - Workroom - (42.44 SQM)	Office (10)	
B00H - R1007 - Audio Visual Workroom - (43.5 SQM)	Student Space (20)	
B00H - R1009 - Seminar - (14.4 SQM)	Office (3)	
B00H - R1010 - Seminar - (14.7 SQM)	Office (3)	
B00H - R1011 - Seminar - (14.44 SQM)	Office (3)	