

VENTILATION AUDIT REPORT

SCHOOL:	Kellyville High School (8477)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Castle Hill
LOCAL GOVERNMENT AREA:	The Hills

8477 - Kellyville High School
Site Plan (13589)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0004 - Student Canteen - (54.2 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Gymnasium - (477.14 SQM)	● Student Space (221)	
B00A - R0008 - Gymnasium - (118.82 SQM)	● Student Space (55)	
B00A - R0009 - Movement - (635.88 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Movement Studio - (158.85 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Movement - (34.89 SQM)	Not Applicable	Circulation or storage space.
B00A - R0027 - Movement - (20.96 SQM)	Not Applicable	Circulation or storage space.
B00A - R0028 - Stage - (56.72 SQM)	Not Applicable	Circulation or storage space.
B00A - R0029 - Movement - (29.77 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - General Learning Space - Type 3 - (58.79 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0002 - General Learning Space - Type 3 - (58.71 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0008 - General Learning Space - Type 3 - (57.49 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0009 - General Learning Space - Type 3 - (58.47 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0010 - General Learning Space - Type 3 - (58.47 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0011 - General Learning Space - Type 3 - (57.76 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0012 - Science Laboratory - (97.94 SQM)	● Student Space (45)	
B00B - R0013 - Science Laboratory - (97.52 SQM)	● Student Space (45)	
B00B - R0014 - Preparation - Science - (49.28 SQM)	Not Applicable	Circulation or storage space.
B00B - R0015 - Science Laboratory - (97.94 SQM)	● Student Space (45)	
B00B - R0016 - Seminar - Type 2 - (20.12 SQM)	● Office (5)	
B00B - R0017 - Seminar - (16.28 SQM)	● Office (4)	
B00B - R0018 - Movement - (176.15 SQM)	Not Applicable	Circulation or storage space.
B00B - R0021 - Movement - (68.9 SQM)	Not Applicable	Circulation or storage space.
B00B - R1019 - General Learning Space - Type 1 - (58.65 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R1020 - Movement - (160.5 SQM)	Not Applicable	Circulation or storage space.
B00B - R1023 - General Learning Space - Type 6 - (58.88 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R1024 - General Learning Space - Type 7 - (58.79 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R1025 - Seminar - Type 2 - (20.35 SQM)	● Office (5)	
B00B - R1027 - General Learning Space - Type 1 - (58.47 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R1028 - General Learning Space - Type 1 - (59.2 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R1031 - Practice/Seminar - (22.17 SQM)	Not Applicable	Circulation or storage space.
B00B - R1032 - Performance Workshop - (115.04 SQM)	● Student Space (53)	
B00B - R1035 - Preparation - Materials - (19.1 SQM)	Not Applicable	Circulation or storage space.
B00B - R1043 - Food Technology L.S. - (93.81 SQM) - Teaching Space: 1	● Student Space (43)	
B00B - R1044 - Food Technology L.S. - (93.34 SQM) - Teaching Space: 1	● Student Space (43)	
B00B - R1045 - Food/Research Space - (13.5 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Interview/Office - Type 1 - (14.75 SQM)	● Office (3)	
B00C - R0002 - Deputy Principal Office - (16.08 SQM)	● Office (4)	
B00C - R0003 - Administration - Executive - (23.37 SQM)	● Office (5)	
B00C - R0004 - Principal Office - (20.39 SQM)	● Office (5)	
B00C - R0008 - Visitors Office - (13.35 SQM)	● Office (3)	
B00C - R0009 - Movement - (16.57 SQM)	Not Applicable	Circulation or storage space.
B00C - R0010 - Interview/Meeting - (12.97 SQM)	● Office (3)	
B00C - R0012 - Public Reception - (34.11 SQM)	Not Applicable	Circulation or storage space.
B00C - R0014 - Administration - Clerical - (64.93 SQM)	● Office (16)	
B00C - R0015 - Interview/Office - Type 2 - (13.36 SQM)	● Office (3)	
B00C - R0016 - Clinic - Boys - (13.28 SQM)	● Office (3)	
B00C - R0018 - Student Reception - (54.26 SQM)	Not Applicable	Circulation or storage space.
B00C - R0019 - Clinic - Girls - (12.28 SQM)	● Office (3)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0021 - Interview/Office - Type 1 - (13.1 SQM)	Office (3)	
B00C - R0022 - Movement - (7.56 SQM)	Not Applicable	Circulation or storage space.
B00C - R0023 - Interview/Meeting - (12.97 SQM)	Office (3)	
B00C - R0024 - Movement - (360.61 SQM)	Not Applicable	Circulation or storage space.
B00C - R1025 - General Learning Space - Type 1 - (55.65 SQM) - Teaching Space: 1	Student Space (25)	
B00C - R1026 - General Learning Space - Type 1 - (56.53 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R1027 - Seminar - Type 1 - (24.57 SQM)	Office (6)	
B00C - R1028 - General Learning Space - Type 1 - (56.6 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R1029 - General Learning Space - Type 1 - (56.43 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R1030 - General Learning Space - Type 2 - (68.05 SQM) - Teaching Space: 1	Student Space (31)	
B00C - R1032 - General Learning Space - Type 1 - (57.76 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R1035 - Movement - (124.32 SQM)	Not Applicable	Circulation or storage space.
B00C - R1039 - Movement - (38.4 SQM)	Not Applicable	Circulation or storage space.
B00C - R1042 - Movement - (88.55 SQM)	Not Applicable	Circulation or storage space.
B00C - R1043 - Movement - (19.34 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - General Learning Space - Type 1 - (58.98 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0002 - Practical Activity Area - (12.81 SQM)	Student Space (5)	
B00D - R0003 - General Learning Space - Type 2 - (64.13 SQM) - Teaching Space: 1	Student Space (29)	
B00D - R0005 - General Learning Space - Type 1 - (59.3 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0006 - General Learning Space - Type 1 - (59.46 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0007 - Seminar - Type 1 - (24.46 SQM)	Office (6)	
B00D - R0008 - General Learning Space - Type 1 - (59.16 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0009 - General Learning Space - Type 1 - (60.12 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0014 - Shared Learning Space - (140.43 SQM)	Student Space (65)	
B00D - R0015 - Movement - (10.33 SQM)	Not Applicable	Circulation or storage space.
B00D - R1009 - Practical Activity Area - (12.51 SQM)	Student Space (5)	
B00D - R1010 - Movement - (10.33 SQM)	Not Applicable	Circulation or storage space.
B00D - R1012 - Shared Learning Space - (139.13 SQM)	Student Space (64)	
B00D - R1013 - General Learning Space - Type 1 - (58.79 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R1015 - General Learning Space - Type 2 - (64.21 SQM) - Teaching Space: 1	Student Space (29)	
B00D - R1016 - General Learning Space - Type 1 - (59.22 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R1017 - General Learning Space - Type 1 - (59.47 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R1018 - Seminar - Type 1 - (24.42 SQM)	Office (6)	
B00D - R1019 - General Learning Space - Type 1 - (59.16 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R1020 - General Learning Space - Type 1 - (60.29 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0001 - General Learning Space - Type 2 - (64.2 SQM) - Teaching Space: 1	Student Space (29)	
B00E - R0002 - Shared Learning Space - (202.13 SQM)	Student Space (93)	
B00E - R0003 - Special Learning Space - (59.6 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0004 - Staff Study - (21.17 SQM)	Office (5)	
B00E - R0012 - Special Learning Space - (60.03 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0013 - Special Learning Space - (60.03 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0014 - Seminar - Type 1 - (25.22 SQM)	Office (6)	
B00E - R0015 - General Learning Space - Type 1 - (60.11 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0016 - General Learning Space - Type 1 - (60.19 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0020 - Movement - (55.8 SQM)	Not Applicable	Circulation or storage space.
B00E - R0022 - Movement - (13.47 SQM)	Not Applicable	Circulation or storage space.
B00E - R0023 - Movement - (209.05 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R1019 - Movement - (21.8 SQM)	Not Applicable	Circulation or storage space.
B00E - R1021 - Seminar - Type 3 - (12.91 SQM)	Office (3)	
B00E - R1022 - Seminar - Type 3 - (12.91 SQM)	Office (3)	
B00E - R1023 - Seminar - Type 3 - (12.91 SQM)	Office (3)	
B00E - R1025 - Main Area - (425.52 SQM)	Not Applicable	Circulation or storage space.
B00E - R1026 - Computer Learning Space - (63.09 SQM) - Teaching Space: 1	Student Space (29)	
B00E - R1027 - Movement - (46.97 SQM)	Not Applicable	Circulation or storage space.
B00E - R1031 - General Learning Space - (57.01 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R1032 - Movement - (108.32 SQM)	Not Applicable	Circulation or storage space.
B00E - R1033 - General Learning Space - (57.92 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R1034 - General Learning Space - (63.98 SQM) - Teaching Space: 1	Student Space (29)	
B00F - R0001 - General Learning Space - Type 1 - (58.78 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0002 - Shared Learning Space - (157.12 SQM)	Student Space (72)	
B00F - R0003 - General Learning Space - Type 2 - (64.05 SQM) - Teaching Space: 1	Student Space (29)	
B00F - R0004 - Movement - (296.78 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - General Learning Space - Type 1 - (59.36 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0006 - General Learning Space - Type 1 - (59.45 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0007 - Seminar - Type 1 - (38.71 SQM)	Office (9)	
B00F - R0008 - General Learning Space - Type 1 - (58.36 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0009 - General Learning Space - Type 1 - (59.45 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0014 - Practical Activity Area - (14.28 SQM)	Student Space (6)	
B00F - R1010 - Movement - (106.22 SQM)	Not Applicable	Circulation or storage space.
B00F - R1011 - Movement - (88.58 SQM)	Not Applicable	Circulation or storage space.
B00F - R1012 - Movement - (13.76 SQM)	Not Applicable	Circulation or storage space.
B00F - R1014 - Interview/Meeting - (12.38 SQM)	Office (3)	
B00F - R1015 - Interview/Meeting - (12.38 SQM)	Office (3)	
B00F - R1024 - Interview/Meeting - (12.68 SQM)	Office (3)	
B00F - R1025 - Interview/Meeting - (12.76 SQM)	Office (3)	
B00F - R1026 - Staff Study - (200.4 SQM)	Office (50)	
B00F - R1027 - Staff Lounge - (106.98 SQM)	Office (26)	
B00F - R1028 - Staff Study - (200.02 SQM)	Office (50)	
B00G - R0004 - Materials Workshop - Type 3 - (121.82 SQM)	Student Space (56)	
B00G - R0005 - Seminar - Type 1 - (19.98 SQM)	Office (4)	
B00G - R0007 - Fitness Laboratory - (100.99 SQM)	Student Space (46)	
B00G - R0010 - General Learning Space - Type 1 - (59.71 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0011 - General Learning Space - Type 1 - (60.04 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0013 - General Learning Space - Type 9 - (59.55 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0014 - General Learning Space - Type 5 - (59.69 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0016 - Movement - (273.37 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - Materials Workshop - Type 2 - (108.24 SQM)	Student Space (50)	
B00H - R0006 - Visual Arts Workshop - (100.16 SQM)	Student Space (46)	
B00H - R0009 - Dark Room - (28.78 SQM)	Office (7)	
B00H - R0010 - General Learning Space - Type 5 - (60.3 SQM) - Teaching Space: 1	Student Space (27)	
B00H - R0011 - General Learning Space - Type 4 - (60.44 SQM) - Teaching Space: 1	Student Space (28)	
B00H - R0014 - General Learning Space - Type 9 - (60.78 SQM) - Teaching Space: 1	Student Space (28)	
B00H - R0015 - General Learning Space - Type 8 - (60.64 SQM) - Teaching Space: 1	Student Space (28)	
B00H - R0016 - Outdoor Workshop - (87.73 SQM)	Not Applicable	Circulation or storage space.
B00H - R0018 - Welding/Hot Metals Area - (12.23 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0021 - Welding/Hot Metals Area - (11.39 SQM)	Not Applicable	Circulation or storage space.
B00H - R0022 - Movement - (192.99 SQM)	Not Applicable	Circulation or storage space.
B00I - R0004 - Movement - (19.76 SQM)	Not Applicable	Circulation or storage space.
B00I - R1003 - Movement - (19.15 SQM)	Not Applicable	Circulation or storage space.
NS 110 13825 - NS 110 13825 - Learning Unit - Single Secondary/Secure - (57 SQM)	● Student Space (26)	
NS 110 14379 - NS 110 14379 - Learning Unit - Single Secondary/Secure - (57 SQM)	● Student Space (26)	
NS 200 11651 - NS 200 11651 - Art Learning Space/Workshop/Bulk Store - (95 SQM)	Not Applicable	Circulation or storage space.