


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Kellyville Public School (2274)</b>
<b>AMU REGION:</b>	<b>Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Castle Hill</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>The Hills</b>

2274 - Kellyville Public School  
Site Plan (12569)



1:949

Printed: 07-Oct-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Staff Room - (98.15 SQM)	Office (24)	
B00B - R0002 - Special Programs Room - (44.36 SQM)	Student Space (20)	
B00C - R0003 - Clerical Office - (19.08 SQM)	Office (4)	
B00C - R0019 - Principal - (20.71 SQM)	Office (5)	
B00C - R0020 - Entry Vestibule - (29.59 SQM)	Not Applicable	Circulation or storage space.
B00C - R0021 - Movement - (18.45 SQM)	Not Applicable	Circulation or storage space.
B00C - R0023 - Sick Bay - (6.36 SQM)	Student Space (2)	
B00C - R0024 - Duplicating Workroom - (28.94 SQM)	Office (7)	
B00C - R1002 - Home Base - (56.87 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R1009 - Home Base - (56.95 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R1011 - Movement - (55.5 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Home Base - (59.11 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0005 - Movement - (8.53 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Movement - (6.53 SQM)	Not Applicable	Circulation or storage space.
B00D - R0011 - Home Base - (58.63 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0015 - Interview - (15.52 SQM)	Office (3)	
B00D - R0016 - Interview - (11.93 SQM)	Office (2)	
B00D - R0017 - Movement - (7.47 SQM)	Not Applicable	Circulation or storage space.
B00D - R0018 - Interview - (17.68 SQM)	Office (4)	
B00D - R1001 - Movement - (70.87 SQM)	Not Applicable	Circulation or storage space.
B00D - R1002 - Home Base - (58.54 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R1005 - Movement - (6.53 SQM)	Not Applicable	Circulation or storage space.
B00D - R1010 - Home Base - (58.87 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R1011 - Home Base - (58.87 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0002 - Home Base - (53.88 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0003 - Home Base - (53.8 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0007 - Practical Activities - 2hb - (34.52 SQM)	Student Space (16)	
B00H - R0004 - Home Base - (56.8 SQM) - Teaching Space: 1	Student Space (26)	
B00H - R0005 - Home Base - (85.27 SQM) - Teaching Space: 1	Student Space (39)	
B00I - R0004 - Home Base - (56.77 SQM) - Teaching Space: 1	Student Space (26)	
B00I - R0005 - Home Base - (78.33 SQM) - Teaching Space: 1	Student Space (36)	
B00J - R0004 - Home Base - (57.83 SQM) - Teaching Space: 1	Student Space (26)	
B00J - R0005 - Home Base - (57.6 SQM) - Teaching Space: 1	Student Space (26)	
B00J - R0008 - Withdrawal Space - 2hb - (14.59 SQM)	Student Space (6)	
B00J - R0017 - Practical Activities - 1hb - (16.52 SQM)	Student Space (7)	
B00J - R0018 - Home Base - (57.33 SQM) - Teaching Space: 1	Student Space (26)	
B00K - R0001 - Withdrawal - Pre - (18.12 SQM)	Student Space (8)	
B00K - R0006 - Withdrawal - Pre - (6.79 SQM)	Student Space (3)	
B00K - R0007 - Practical Activities - Pre - (6.69 SQM)	Student Space (3)	
B00L - R0001 - Canteen - (45.73 SQM)	Not Applicable	Circulation or storage space.
B00L - R0018 - Raised Platform - (47.18 SQM)	Not Applicable	Circulation or storage space.
B00L - R0019 - Communal Space - (214.65 SQM)	Student Space (99)	
B00M - R0001 - Reading Area - (224.04 SQM)	Student Space (103)	
B00N - R0006 - Practical Activities - 1hb - (19.48 SQM)	Student Space (9)	
B00N - R0008 - Home Base - (60.6 SQM) - Teaching Space: 1	Student Space (28)	
B00N - R0009 - Withdrawal Space - 2hb - (11.35 SQM)	Student Space (5)	
B00N - R0010 - Home Base - (60.74 SQM) - Teaching Space: 1	Student Space (28)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00N - R0012 - Practical Activities - 1hb - (19.51 SQM)	● Student Space (9)	
B00O - R0002 - Practical Activities - 1hb - (19.57 SQM)	● Student Space (9)	
B00O - R0004 - Home Base - (60.82 SQM) - Teaching Space: 1	● Student Space (28)	
B00O - R0005 - Withdrawal Space - 2hb - (11.51 SQM)	● Student Space (5)	
B00O - R0006 - Home Base - (60.78 SQM) - Teaching Space: 1	● Student Space (28)	
B00O - R0008 - Practical Activities - 1hb - (19.53 SQM)	● Student Space (9)	
B00P - R0002 - Practical Activities - 1hb - (19.58 SQM)	● Student Space (9)	
B00P - R0004 - Home Base - (60.6 SQM) - Teaching Space: 1	● Student Space (28)	
B00P - R0005 - Withdrawal Space - 2hb - (11.54 SQM)	● Student Space (5)	
B00P - R0006 - Home Base - (60.8 SQM) - Teaching Space: 1	● Student Space (28)	
B00P - R0008 - Practical Activities - 1hb - (19.51 SQM)	● Student Space (9)	
B00Q - R0002 - Special Programs Room - (70.23 SQM)	● Student Space (32)	
B00Q - R0004 - Withdrawal Space - 1hb - (8.46 SQM)	● Student Space (3)	
OS 602 10268 - OS 602 10268 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 12616 - OS 602 12616 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 12770 - OS 602 12770 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 13710 - OS 602 13710 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 14457 - OS 602 14457 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 15012 - OS 602 15012 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 15285 - OS 602 15285 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 606 13143 - OS 606 13143 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 13418 - OS 606 13418 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19066 - OS 606 19066 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	