

VENTILATION AUDIT REPORT

SCHOOL:	Kemblawarra Public School (4083)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Wollongong
LOCAL GOVERNMENT AREA:	Wollongong

4083 - Kemblawarra Public School
Site Plan (12571)



1:1,025

Printed: 27-Mar-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0038 - Staff Room Annexe - (12.53 SQM)	Office (3)	
B00A - R0042 - Movement - (24.37 SQM)	Not Applicable	Circulation or storage space.
B00A - R0043 - Principal - (12.51 SQM)	Office (3)	
B00A - R0044 - Deputy Principal - (12.44 SQM)	Office (3)	
B00A - R0045 - Sick Bay - (8.13 SQM)	Student Space (3)	
B00A - R0047 - Entry Vestibule - (20.72 SQM)	Not Applicable	Circulation or storage space.
B00A - R0048 - Special Programs Room - (17.94 SQM)	Student Space (8)	
B00A - R0051 - Reading Area - (91.12 SQM)	Student Space (42)	
B00A - R0054 - Practical Activities - 1hb - (19.57 SQM)	Student Space (9)	
B00A - R0055 - Withdrawal Space - 2hb - (12.64 SQM)	Student Space (5)	
B00A - R0056 - Practical Activities - 1hb - (18.57 SQM)	Student Space (8)	
B00A - R0058 - Practical Activities - 1hb - (18.72 SQM)	Student Space (8)	
B00A - R0059 - Withdrawal Space - 2hb - (12.68 SQM)	Student Space (5)	
B00A - R0060 - Practical Activities - 1hb - (19.4 SQM)	Student Space (9)	
B00A - R0062 - Home Base - (60.63 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R0063 - Home Base - (60.67 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R0066 - Home Base - (60.76 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R0067 - Home Base - (60.65 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R0070 - Special Programs Room - (17.84 SQM)	Student Space (8)	
B00A - R0072 - Clerical Office/Workroom - (26.73 SQM)	Office (6)	
B00A - R0074 - Interview - (11.96 SQM)	Office (2)	
B00A - R0076 - Staff Room - (41.61 SQM)	Office (10)	
B00A - R9021 - Movement - (33.03 SQM)	Not Applicable	Circulation or storage space.
B00A - R9022 - Canteen - (34.06 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Home Base - (46.84 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0009 - Withdrawal Space - 1hb - (42.65 SQM)	Student Space (19)	
B00C - R0001 - Clerical Office - (8.81 SQM)	Office (2)	
B00C - R0007 - Movement - (24.61 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Staff Kitchen - (21.64 SQM)	Office (5)	
B00C - R0010 - Withdrawal - Pre - (11.77 SQM)	Student Space (5)	
B00C - R0011 - Home Base - Pre - (72.93 SQM) - Teaching Space: 1	Student Space (33)	
B00C - R0015 - Home Base - Pre - (73.94 SQM) - Teaching Space: 1	Student Space (34)	
B00C - R0017 - Withdrawal - Pre - (10.61 SQM)	Student Space (4)	
B00C - R0021 - Movement - (9.49 SQM)	Not Applicable	Circulation or storage space.
B00C - R0026 - Practical Activities - Pre - (22.29 SQM)	Student Space (10)	
B00C - R0031 - Movement - (20.22 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Communal Space - (113.67 SQM)	Student Space (52)	
OS 602 14154 - OS 602 14154 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 14369 - OS 602 14369 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 15372 - OS 602 15372 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 16353 - OS 602 16353 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 19825 - OS 602 19825 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	