


VENTILATION AUDIT REPORT

SCHOOL:	Kemps Creek Public School (3615)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Mulgoa
LOCAL GOVERNMENT AREA:	Liverpool

3615 - Kemps Creek Public School
Site Plan (10451)



1:1,105

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room - (37.42 SQM)	Office (9)	
B00A - R0002 - Movement - (27.98 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Principal - (18.64 SQM)	Office (4)	
B00A - R0007 - Entry Vestibule - (23.39 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Clerical Office - (12.14 SQM)	Office (3)	
B00A - R0009 - Duplicating Workroom - (18.42 SQM)	Office (4)	
B00A - R0013 - Movement - (8 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Movement - (24.31 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Deputy Principal - (11.69 SQM)	Office (2)	
B00A - R0021 - Reading Area - (59.73 SQM)	Student Space (27)	
B00A - R0022 - Movement - (59.38 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Canteen - (11.59 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Movement - (18.2 SQM)	Not Applicable	Circulation or storage space.
B00B - R0018 - Entry Vestibule - (12.84 SQM)	Not Applicable	Circulation or storage space.
B00B - R0023 - Raised Platform - (52.33 SQM)	Not Applicable	Circulation or storage space.
B00B - R0025 - Communal Space - (206.31 SQM)	Student Space (95)	
B00C - R0001 - Home Base - (70.2 SQM) - Teaching Space: 1	Student Space (32)	
B00C - R0003 - Withdrawal Space - 1hb - (7.74 SQM)	Student Space (3)	
B00C - R0006 - Movement - (7.54 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - Home Base - (70.48 SQM) - Teaching Space: 1	Student Space (32)	
B00C - R0008 - Movement - (7.55 SQM)	Not Applicable	Circulation or storage space.
B00C - R0009 - Practical Activities - 1hb - (15.58 SQM)	Student Space (7)	
B00C - R0010 - Movement - (44.98 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Home Base - (55.65 SQM) - Teaching Space: 1	Student Space (25)	
B00D - R0004 - Withdrawal Space - 1hb - (7.2 SQM)	Student Space (3)	
B00D - R0006 - Movement - (10.87 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Home Base - (55.77 SQM) - Teaching Space: 1	Student Space (25)	
B00D - R0008 - Movement - (7.58 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - Practical Activities - 1hb - (15.8 SQM)	Student Space (7)	
B00E - R0001 - Movement - (19.08 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Movement - (18.83 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Home Base - (55.76 SQM) - Teaching Space: 1	Student Space (25)	
B00E - R0006 - Withdrawal Space - 1hb - (7.34 SQM)	Student Space (3)	
B00E - R0008 - Movement - (10.8 SQM)	Not Applicable	Circulation or storage space.
B00E - R0009 - Home Base - (55.88 SQM) - Teaching Space: 1	Student Space (25)	
B00E - R0010 - Movement - (7.57 SQM)	Not Applicable	Circulation or storage space.
B00E - R0011 - Practical Activities - 1hb - (14.66 SQM)	Student Space (6)	
B00F - R0001 - Reading Area - (169.93 SQM)	Student Space (78)	
B00G - R0002 - Canteen - (20.53 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Practical Activities - (17.95 SQM)	Student Space (8)	
B00G - R0005 - Withdrawal Space - 1hb - (7.62 SQM)	Student Space (3)	
B00G - R0007 - Home Base - (60.11 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0009 - Movement - (5.09 SQM)	Not Applicable	Circulation or storage space.
B00G - R0010 - Special Programs Room - (33.22 SQM)	Student Space (15)	