

VENTILATION AUDIT REPORT

SCHOOL:	Kempsey East Public School (2278)
AMU REGION:	North Coast
STATE ELECTORATE:	Oxley
LOCAL GOVERNMENT AREA:	Kempsey

2278 - Kempsey East Public School
Site Plan (12572)



1:928

Printed: 20-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (51.01 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R0002 - Practical Activities - 1hb - (18.78 SQM)	● Student Space (8)	
B00B - R0001 - Practical Activities - 1hb - (22.15 SQM)	● Student Space (10)	
B00B - R0002 - Home Base - (48.82 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R0003 - Home Base - (48.66 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R0004 - Practical Activities - 1hb - (22.63 SQM)	● Student Space (10)	
B00B - R1001 - Movement - (42.88 SQM)	Not Applicable	Circulation or storage space.
B00B - R1002 - Practical Activities - 1hb - (22.35 SQM)	● Student Space (10)	
B00B - R1003 - Home Base - (48 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R1004 - Home Base - (48.15 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R1005 - Practical Activities - 1hb - (22.36 SQM)	● Student Space (10)	
B00D - R0001 - Movement - (97.47 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Canteen - (18.6 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Staff Room - (45.47 SQM)	● Office (11)	
B00E - R0004 - Sick Bay - (8 SQM)	● Student Space (3)	
B00E - R0005 - Entry Vestibule - (15.39 SQM)	Not Applicable	Circulation or storage space.
B00E - R0006 - Withdrawal Space - 1hb - (15.54 SQM)	● Student Space (7)	
B00E - R0009 - Principal - (17.86 SQM)	● Office (4)	
B00E - R0012 - Home Base - (56.89 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0013 - Home Base - (56.89 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0019 - Entry Vestibule - (8.07 SQM)	Not Applicable	Circulation or storage space.
B00E - R0020 - Clerical Office - (29.24 SQM)	● Office (7)	
B00E - R0021 - Practical Activities/Movement - 2hb - (38.35 SQM)	● Student Space (17)	
B00E - R0022 - Clerical/Printing - (20.38 SQM)	Not Applicable	Circulation or storage space.
B00E - R0023 - Movement - (7.43 SQM)	Not Applicable	Circulation or storage space.
B00F - R0006 - Home Base - (86.39 SQM) - Teaching Space: 1	● Student Space (40)	
B00F - R0011 - Interview - (16.48 SQM)	● Office (4)	
B00G - R0001 - Home Base - (103.56 SQM) - Teaching Space: 1	● Student Space (48)	
B00H - R0003 - Reading Area - (163.68 SQM)	● Student Space (75)	
B00I - R0001 - Communal Space - (145.5 SQM)	● Student Space (67)	
B00I - R0002 - Raised Platform - (60.15 SQM)	Not Applicable	Circulation or storage space.
B00I - R0016 - Movement - (6.18 SQM)	Not Applicable	Circulation or storage space.
B00I - R0018 - Movement - (13.01 SQM)	Not Applicable	Circulation or storage space.