

VENTILATION AUDIT REPORT

SCHOOL:	Kendall Public School (2280)
AMU REGION:	North Coast
STATE ELECTORATE:	Port Macquarie
LOCAL GOVERNMENT AREA:	Port Macquarie-Hastings

2280 - Kendall Public School
Site Plan (12574)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Sick Bay - (13.54 SQM)	● Student Space (6)	
B00A - R0005 - Movement - (26.47 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Movement - (20.54 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Principal - (19.93 SQM)	● Office (4)	
B00A - R0012 - Deputy Principal - (11.57 SQM)	● Office (2)	
B00A - R0015 - Movement - (22.78 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Sick Bay - (10.73 SQM)	● Student Space (4)	
B00A - R0020 - Staff Kitchen - (9.54 SQM)	● Office (2)	
B00A - R0021 - Staff Room - (57.18 SQM)	● Office (14)	
B00A - R0022 - Clerical Office/Workroom - (47.81 SQM)	● Office (11)	
B00B - R0005 - Movement - (85.66 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Practical Activities - 1hb - (19.13 SQM)	● Student Space (8)	
B00B - R0007 - Withdrawal Space - 2hb - (15.97 SQM)	● Student Space (7)	
B00B - R0008 - Practical Activities - 1hb - (20.3 SQM)	● Student Space (9)	
B00B - R0010 - Home Base - (79.36 SQM) - Teaching Space: 1	● Student Space (36)	
B00B - R0011 - Home Base - (75.01 SQM) - Teaching Space: 1	● Student Space (34)	
B00D - R0001 - Movement - (13.3 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - Movement - (97.38 SQM)	Not Applicable	Circulation or storage space.
B00D - R0010 - Movement - (40.64 SQM)	Not Applicable	Circulation or storage space.
B00D - R0016 - Practical Activities - 1hb - (13.87 SQM)	● Student Space (6)	
B00D - R0017 - Home Base - (71.83 SQM) - Teaching Space: 1	● Student Space (33)	
B00D - R0020 - Withdrawal Space - 2hb - (12.13 SQM)	● Student Space (5)	
B00D - R0021 - Home Base - (63.87 SQM) - Teaching Space: 1	● Student Space (29)	
B00D - R0022 - Practical Activities - 1hb - (13.43 SQM)	● Student Space (6)	
B00D - R0024 - Movement - (5.03 SQM)	Not Applicable	Circulation or storage space.
B00D - R1016 - Movement - (78.99 SQM)	Not Applicable	Circulation or storage space.
B00D - R1018 - Withdrawal Space - 1hb - (10.13 SQM)	● Student Space (4)	
B00D - R1019 - Home Base - (60.78 SQM) - Teaching Space: 1	● Student Space (28)	
B00D - R1020 - Practical Activities - 1hb - (18.82 SQM)	● Student Space (8)	
B00D - R1021 - Practical Activities - 1hb - (19.68 SQM)	● Student Space (9)	
B00D - R1022 - Home Base - (60.04 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R1023 - Withdrawal Space - 1hb - (8.28 SQM)	● Student Space (3)	
B00D - R1025 - Special Programs Room - (44 SQM)	● Student Space (20)	
B00D - R9001 - Movement - (20.13 SQM)	Not Applicable	Circulation or storage space.
B00D - R9002 - Special Programs Room - (48.89 SQM)	● Student Space (22)	
B00D - R9004 - Computer Learning Space - (36.21 SQM) - Teaching Space: 1	● Student Space (16)	
B00D - R9005 - Withdrawal Space - 1hb - (16.89 SQM)	● Student Space (7)	
B00D - R9006 - Movement - (13.22 SQM)	Not Applicable	Circulation or storage space.
B00D - R9007 - Movement - (13.5 SQM)	Not Applicable	Circulation or storage space.
B00D - R9008 - Movement - (18.26 SQM)	Not Applicable	Circulation or storage space.
B00D - R9010 - Welding Area - (21.57 SQM)	Not Applicable	Circulation or storage space.
B00D - R9012 - Materials Technology L.S. - (127.83 SQM) - Teaching Space: 1	● Student Space (59)	
B00D - R9016 - Movement - (7.28 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Reading Area - (282.77 SQM)	● Student Space (131)	
B00E - R0015 - Movement - (61.78 SQM)	Not Applicable	Circulation or storage space.
B00E - R9001 - Special Programs Room - (199.35 SQM)	● Student Space (92)	
B00E - R9005 - Movement - (66.74 SQM)	Not Applicable	Circulation or storage space.
B00E - R9008 - Movement - (46.18 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0005 - Movement - (41.48 SQM)	Not Applicable	Circulation or storage space.
B00H - R0017 - Movement - (78.12 SQM)	Not Applicable	Circulation or storage space.
B00H - R0019 - Withdrawal Space - 1hb - (9.52 SQM)	● Student Space (4)	
B00H - R0020 - Home Base - (79.79 SQM) - Teaching Space: 1	● Student Space (37)	
B00H - R0021 - Practical Activities - 1hb - (18.15 SQM)	● Student Space (8)	
B00H - R0022 - Home Base - (71.62 SQM) - Teaching Space: 1	● Student Space (33)	
B00H - R0023 - Withdrawal Space - 1hb - (8.92 SQM)	● Student Space (4)	
B00H - R0026 - Practical Activities - 1hb - (18.75 SQM)	● Student Space (8)	
B00J - R0002 - Home Base - (63.45 SQM) - Teaching Space: 1	● Student Space (29)	
B00J - R0003 - Movement - (18.93 SQM)	Not Applicable	Circulation or storage space.
B00J - R0004 - Withdrawal Space - 1hb - (13.58 SQM)	● Student Space (6)	
B00J - R0006 - Home Base - (63.06 SQM) - Teaching Space: 1	● Student Space (29)	
B00J - R0008 - Practical Activities - 1hb - (54.92 SQM)	● Student Space (25)	
B00J - R0010 - Movement - (18.93 SQM)	Not Applicable	Circulation or storage space.
B00J - R9001 - Movement - (43.8 SQM)	Not Applicable	Circulation or storage space.
B00L - R0002 - Canteen - (27.53 SQM)	Not Applicable	Circulation or storage space.
B00L - R0004 - Movement - (23.43 SQM)	Not Applicable	Circulation or storage space.
B00L - R0012 - Special Programs Room - (146.64 SQM)	● Student Space (68)	
B00L - R0013 - Movement - (22.26 SQM)	Not Applicable	Circulation or storage space.
B00L - R0014 - Raised Platform - (46.74 SQM)	Not Applicable	Circulation or storage space.
B00L - R0015 - Movement - (6.43 SQM)	Not Applicable	Circulation or storage space.
B040 - R0001 - Movement - (16.42 SQM)	Not Applicable	Circulation or storage space.