

VENTILATION AUDIT REPORT

SCHOOL:	Kent Road Public School (4160)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Ryde
LOCAL GOVERNMENT AREA:	Ryde

4160 - Kent Road Public School
Site Plan (12576)



1:1,333

Printed: 15-Jul-2021







Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Movement - (13.74 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Deputy Principal - (17.59 SQM)	Office (4)	
B00A - R0009 - Home Base - (65.01 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R0010 - Home Base - (88.75 SQM) - Teaching Space: 1	Student Space (41)	
B00A - R0015 - Movement - (8.1 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Movement - (8.26 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Home Base - (65.37 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R0005 - Movement - (15.78 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Deputy Principal - (19.13 SQM)	Office (4)	
B00B - R0010 - Home Base - (65.19 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R0002 - Home Base - (57.46 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0006 - Home Base - (57.46 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0007 - Staff Room - (22.88 SQM)	Office (5)	
B00C - R0008 - Movement - (6.18 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Home Base - (85.43 SQM) - Teaching Space: 1	Student Space (39)	
B00D - R0007 - Home Base - (56.9 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0001 - Movement - (23.38 SQM)	Not Applicable	Circulation or storage space.
B00H - R0003 - Special Programs Room - (86.46 SQM)	Student Space (40)	
B00I - R0009 - Special Programs Room - Type 1 - (144 SQM)	Student Space (66)	
B00J - R0023 - Reading Area - (284.08 SQM)	Student Space (131)	
B00N - R0010 - Movement - (9.48 SQM)	Not Applicable	Circulation or storage space.
B00N - R0011 - Raised Platform - (49.28 SQM)	Not Applicable	Circulation or storage space.
B00N - R0013 - Movement - (7.75 SQM)	Not Applicable	Circulation or storage space.
B00N - R0035 - Communal Space - (312.18 SQM)	Student Space (144)	
B00P - R0001 - Movement - (70.96 SQM)	Not Applicable	Circulation or storage space.
B00P - R0002 - Home Base X2 - (119.2 SQM) - Teaching Space: 2	Student Space (55)	
B00P - R0003 - Withdrawal Space - 1hb - (11.38 SQM)	Student Space (5)	
B00P - R0005 - Home Base X2 - (118.87 SQM) - Teaching Space: 2	Student Space (55)	
B00P - R0006 - Withdrawal Space - 2hb - (11.41 SQM)	Student Space (5)	
B00P - R0008 - Staff Room - (20.73 SQM)	Office (5)	
B00P - R0009 - Presentation Area - (46.91 SQM)	Not Applicable	Circulation or storage space.
B00P - R0010 - Practical Activities - 4hb - (54.48 SQM)	Student Space (25)	
B00P - R0011 - Movement - (70.96 SQM)	Not Applicable	Circulation or storage space.
B00P - R0012 - Home Base X2 - (119.2 SQM) - Teaching Space: 2	Student Space (55)	
B00P - R0013 - Withdrawal Space - 2hb - (11.38 SQM)	Student Space (5)	
B00P - R0027 - Movement - (28.11 SQM)	Not Applicable	Circulation or storage space.
B00P - R0028 - Movement - (28.3 SQM)	Not Applicable	Circulation or storage space.
B00P - R1001 - Movement - (70.96 SQM)	Not Applicable	Circulation or storage space.
B00P - R1002 - Home Base X2 - (119.2 SQM) - Teaching Space: 2	Student Space (55)	
B00P - R1003 - Withdrawal Space - 2hb - (11.38 SQM)	Student Space (5)	
B00P - R1005 - Home Base X2 - (118.87 SQM) - Teaching Space: 2	Student Space (55)	
B00P - R1006 - Withdrawal Space - 2hb - (11.41 SQM)	Student Space (5)	
B00P - R1008 - Staff Room - (20.73 SQM)	Office (5)	
B00P - R1009 - Presentation Area - (46.91 SQM)	Not Applicable	Circulation or storage space.
B00P - R1010 - Practical Activities - 4hb - (54.48 SQM)	Student Space (25)	
B00P - R1011 - Movement - (70.96 SQM)	Not Applicable	Circulation or storage space.
B00P - R1012 - Home Base X2 - (119.2 SQM) - Teaching Space: 2	Student Space (55)	
B00P - R1013 - Withdrawal Space - 2hb - (11.38 SQM)	Student Space (5)	
B00P - R1015 - Movement - (10.14 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00P - R1023 - Movement - (10.09 SQM)	Not Applicable	Circulation or storage space.
B00P - R2001 - Movement - (70.96 SQM)	Not Applicable	Circulation or storage space.
B00P - R2002 - Home Base X2 - (119.2 SQM) - Teaching Space: 2	● Student Space (55)	
B00P - R2003 - Withdrawal Space - 2hb - (11.38 SQM)	● Student Space (5)	
B00P - R2005 - Home Base X2 - (118.87 SQM) - Teaching Space: 2	● Student Space (55)	
B00P - R2006 - Withdrawal Space - 2hb - (11.41 SQM)	● Student Space (5)	
B00P - R2008 - Staff Room - (20.73 SQM)	● Office (5)	
B00P - R2009 - Presentation Area - (46.91 SQM)	Not Applicable	Circulation or storage space.
B00P - R2010 - Practical Activities - 4hb - (54.48 SQM)	● Student Space (25)	
B00P - R2011 - Movement - (70.96 SQM)	Not Applicable	Circulation or storage space.
B00P - R2012 - Home Base X2 - (119.2 SQM) - Teaching Space: 2	● Student Space (55)	
B00P - R2013 - Withdrawal Space - 2hb - (11.38 SQM)	● Student Space (5)	
B00P - R2015 - Movement - (10.14 SQM)	Not Applicable	Circulation or storage space.
B00P - R2023 - Movement - (10.09 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0001 - Movement - (70.96 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0002 - Home Base X2 - (119.2 SQM) - Teaching Space: 2	● Student Space (55)	
B00Q - R0003 - Withdrawal Space - 2hb - (11.38 SQM)	● Student Space (5)	
B00Q - R0005 - Home Base X2 - (118.87 SQM) - Teaching Space: 2	● Student Space (55)	
B00Q - R0006 - Withdrawal Space - 2hb - (11.41 SQM)	● Student Space (5)	
B00Q - R0008 - Staff Room - (20.73 SQM)	● Office (5)	
B00Q - R0009 - Presentation Home Base - (44.72 SQM) - Teaching Space: 1	Not Applicable	Circulation or storage space.
B00Q - R0010 - Practical Activities - 4hb - (53.43 SQM)	● Student Space (24)	
B00Q - R0014 - Movement - (39.99 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0016 - Canteen - (58.98 SQM)	Not Applicable	Circulation or storage space.
B00Q - R1001 - Movement - (70.96 SQM)	Not Applicable	Circulation or storage space.
B00Q - R1002 - Home Base X2 - (119.2 SQM) - Teaching Space: 2	● Student Space (55)	
B00Q - R1003 - Withdrawal Space - 2hb - (11.38 SQM)	● Student Space (5)	
B00Q - R1005 - Home Base X2 - (118.87 SQM) - Teaching Space: 2	● Student Space (55)	
B00Q - R1006 - Withdrawal Space - 2hb - (11.41 SQM)	● Student Space (5)	
B00Q - R1008 - Staff Room - (20.73 SQM)	● Office (5)	
B00Q - R1009 - Presentation Home Base - (46.91 SQM) - Teaching Space: 1	Not Applicable	Circulation or storage space.
B00Q - R1010 - Practical Activities - 4hb - (54.48 SQM)	● Student Space (25)	
B00Q - R1011 - Movement - (70.96 SQM)	Not Applicable	Circulation or storage space.
B00Q - R1012 - Home Base X2 - (119.2 SQM) - Teaching Space: 2	● Student Space (55)	
B00Q - R1013 - Withdrawal Space - 2hb - (11.38 SQM)	● Student Space (5)	
B00Q - R1015 - Movement - (10.14 SQM)	Not Applicable	Circulation or storage space.
B00Q - R1022 - Movement - (10.09 SQM)	Not Applicable	Circulation or storage space.
B00Q - R2001 - Movement - (70.96 SQM)	Not Applicable	Circulation or storage space.
B00Q - R2002 - Home Base X2 - (119.2 SQM) - Teaching Space: 2	● Student Space (55)	
B00Q - R2003 - Withdrawal Space - 2hb - (11.38 SQM)	● Student Space (5)	
B00Q - R2005 - Home Base X2 - (118.87 SQM) - Teaching Space: 2	● Student Space (55)	
B00Q - R2006 - Withdrawal Space - 2hb - (11.41 SQM)	● Student Space (5)	
B00Q - R2008 - Staff Room - (20.73 SQM)	● Office (5)	
B00Q - R2009 - Presentation Home Base - (46.91 SQM) - Teaching Space: 1	Not Applicable	Circulation or storage space.
B00Q - R2010 - Practical Activities - 4hb - (54.48 SQM)	● Student Space (25)	
B00Q - R2011 - Movement - (70.96 SQM)	Not Applicable	Circulation or storage space.
B00Q - R2012 - Home Base X2 - (119.2 SQM) - Teaching Space: 2	● Student Space (55)	
B00Q - R2013 - Withdrawal Space - 2hb - (11.38 SQM)	● Student Space (5)	
B00Q - R2015 - Movement - (10.14 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00Q - R2025 - Movement - (14.81 SQM)	Not Applicable	Circulation or storage space.
B00R - R0001 - Entry Vestibule - (26.51 SQM)	Not Applicable	Circulation or storage space.
B00R - R0002 - Interview - (12.21 SQM)	Office (3)	
B00R - R0003 - Interview - (11.99 SQM)	Office (2)	
B00R - R0004 - Principal - (17.44 SQM)	Office (4)	
B00R - R0006 - Movement - (19.22 SQM)	Not Applicable	Circulation or storage space.
B00R - R0007 - Clerical Office - (60.5 SQM)	Office (15)	
B00R - R0010 - Entry Vestibule - (7.88 SQM)	Not Applicable	Circulation or storage space.
B00R - R0014 - Sick Bay - (8.06 SQM)	Student Space (3)	
B00R - R0015 - Movement - (24.32 SQM)	Not Applicable	Circulation or storage space.
B00R - R0016 - Entry Vestibule - (6.43 SQM)	Not Applicable	Circulation or storage space.
B00R - R0017 - Deputy Principal - Type 1 - (12.15 SQM)	Office (3)	
B00R - R0018 - Deputy Principal - Type 1 - (11.95 SQM)	Office (2)	
B00R - R0019 - Deputy Principal - (13.92 SQM)	Office (3)	
B00R - R0020 - Interview - (14.58 SQM)	Office (3)	
B00R - R0023 - Deputy Principal - (12.42 SQM)	Office (3)	
B00R - R1003 - Movement - (12.34 SQM)	Not Applicable	Circulation or storage space.
B00R - R1008 - Clerical/Printing - (15.07 SQM)	Not Applicable	Circulation or storage space.
B00R - R1009 - Staff Room Annexe - (42.98 SQM)	Office (10)	
B00R - R1010 - Staff Kitchen - (22.72 SQM)	Office (5)	
B00R - R1011 - Staff Room - (63.87 SQM)	Office (15)	
B00R - R1012 - Movement - (8.13 SQM)	Not Applicable	Circulation or storage space.
B00R - R1014 - Special Programs Room - (30.62 SQM)	Student Space (14)	
B00R - R1015 - Special Programs Room - (29.76 SQM)	Student Space (13)	
B00R - R1020 - Movement - (14.11 SQM)	Not Applicable	Circulation or storage space.
B00R - R1021 - Movement - (8.33 SQM)	Not Applicable	Circulation or storage space.
B00R - R2001 - Movement - (7.49 SQM)	Not Applicable	Circulation or storage space.
OS 502 10996 - OS 502 10996 - Admin Staff/Principal/Clerk/Dup/Clinic - (152 SQM)	Office (38)	
OS 520 70142 - OS 520 70142 - Staff Study - (57 SQM)	Office (14)	
OS 534 16146 - OS 534 16146 - Library/Group Study/Office/A V Store - (152 SQM)	Student Space (70)	
OS 601 12927 - OS 601 12927 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 17120 - OS 601 17120 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 602 10917 - OS 602 10917 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 11962 - OS 602 11962 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 12632 - OS 602 12632 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 12850 - OS 602 12850 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 12876 - OS 602 12876 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 13269 - OS 602 13269 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 13479 - OS 602 13479 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 13491 - OS 602 13491 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 15013 - OS 602 15013 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 15260 - OS 602 15260 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 18285 - OS 602 18285 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 18286 - OS 602 18286 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 18356 - OS 602 18356 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 606 19013 - OS 606 19013 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	
OS 606 19565 - OS 606 19565 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	
OS 606 19566 - OS 606 19566 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	

Entity Location	Audit Condition Classification (Capacity)	Comment
OS 606 19567 - OS 606 19567 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 19568 - OS 606 19568 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 19569 - OS 606 19569 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 19570 - OS 606 19570 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 19571 - OS 606 19571 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 19572 - OS 606 19572 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 801 10549 - OS 801 10549 - FSU - (57 SQM)	Not Applicable	Circulation or storage space.