


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Khancoban Public School (4270)</b>
<b>AMU REGION:</b>	<b>Southern NSW</b>
<b>STATE ELECTORATE:</b>	<b>Albury</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Snowy Valleys</b>

4270 - Khancoban Public School  
Site Plan (10452)



1:1,278

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0008 - Movement - (85.19 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Entry Vestibule - (22.93 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Staff Room - (21.14 SQM)	Office (5)	
B00A - R0015 - Principal - (9.25 SQM)	Office (2)	
B00A - R0016 - Duplicating Workroom - (10.98 SQM)	Office (2)	
B00A - R0018 - Home Base - (56.14 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0020 - Movement - (24.8 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Home Base - (53.4 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0022 - Home Base - (53.77 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0027 - Movement - (58.26 SQM)	Not Applicable	Circulation or storage space.
B00A - R0029 - Clerical Office - (19.41 SQM)	Office (4)	
B00A - R0036 - Home Base - (57.01 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0037 - Home Base - (85.16 SQM) - Teaching Space: 1	Student Space (39)	
B00A - R0040 - Movement - (76.44 SQM)	Not Applicable	Circulation or storage space.
B00A - R0045 - Canteen - (61.02 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Communal Space - (108.49 SQM)	Student Space (50)	
B00B - R0003 - Movement - (14.86 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Canteen - (9.6 SQM)	Not Applicable	Circulation or storage space.