

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Killara High School (8457)</b>
<b>AMU REGION:</b>	<b>Northern Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Davidson</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Ku-Ring-Gai</b>

8457 - Killara High School  
Site Plan (12581)



1:1,316

Printed: 23-Apr-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0008 - Administration - Clerical - (23.25 SQM)	Office (5)	
B00A - R0010 - Principal Office - (20.11 SQM)	Office (5)	
B00A - R0014 - Administration - Clerical - (34.14 SQM)	Office (8)	
B00A - R0015 - General Learning Space - (57.76 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0021 - Movement - (168.68 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Staff Study - (25.58 SQM)	Office (6)	
B00A - R0024 - Laboratory L.S. - (91.49 SQM) - Teaching Space: 1	Student Space (42)	
B00A - R0025 - Preparation - (29.24 SQM)	Not Applicable	Circulation or storage space.
B00A - R0027 - Laboratory L.S. - (83.23 SQM) - Teaching Space: 1	Student Space (38)	
B00A - R0031 - Duplicating Workroom - (37.81 SQM)	Office (9)	
B00A - R0032 - Administration - Clerical - (9.31 SQM)	Office (2)	
B00A - R0033 - Staff Study - (14.11 SQM)	Office (3)	
B00A - R0034 - Clinic-Waiting - (15.73 SQM)	Office (3)	
B00A - R0035 - Staff Study - (14.84 SQM)	Office (3)	
B00A - R0036 - Staff Study - (15.36 SQM)	Office (3)	
B00A - R0037 - Entry - (48.06 SQM)	Not Applicable	Circulation or storage space.
B00A - R0038 - Administration - Clerical - (7.06 SQM)	Office (1)	
B00A - R0039 - Staff Study - (15.98 SQM)	Office (3)	
B00A - R0042 - Staff Study - (36.47 SQM)	Office (9)	
B00A - R0043 - Deputy Principal - (13.65 SQM)	Office (3)	
B00A - R1002 - General Learning Space - (51.97 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1010 - General Learning Space - (50.93 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1011 - Staff Study - (12.6 SQM)	Office (3)	
B00A - R1014 - General Learning Space - (57.72 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R1017 - General Learning Space - (52.07 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1018 - General Learning Space - (65.25 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1022 - Staff Lounge - (66.8 SQM)	Office (16)	
B00A - R1025 - General Learning Space - (50.87 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1028 - Movement - (167.32 SQM)	Not Applicable	Circulation or storage space.
B00A - R1031 - General Learning Space - (51.86 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1032 - Staff Study - (13.21 SQM)	Office (3)	
B00A - R1033 - Commonroom - (123.02 SQM)	Office (30)	
B00B - R0003 - Movement - (164.19 SQM)	Not Applicable	Circulation or storage space.
B00B - R0036 - Textiles Technology L.S. - (65.1 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R0037 - Art Learning Space - (57.49 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0044 - Art Learning Space - (49.76 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R0050 - Food Technology L.S. - (93.36 SQM) - Teaching Space: 1	Student Space (43)	
B00B - R0057 - Textiles Technology L.S. - (51.2 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R0065 - Preparation - Materials - (25.35 SQM)	Not Applicable	Circulation or storage space.
B00B - R0066 - Food Technology L.S. - (95.28 SQM) - Teaching Space: 1	Student Space (44)	
B00B - R0070 - Food Technology L.S. - (120.66 SQM) - Teaching Space: 1	Student Space (55)	
B00B - R0074 - Seminar - Type 1 - (27.42 SQM)	Office (6)	
B00B - R1001 - Movement - (166.97 SQM)	Not Applicable	Circulation or storage space.
B00B - R1068 - Materials Technology L.S. - (50.29 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R1080 - Music Learning Space - (50.87 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R1088 - General Learning Space - (70.2 SQM) - Teaching Space: 1	Student Space (32)	
B00B - R1089 - General Learning Space - (64.92 SQM) - Teaching Space: 1	Student Space (30)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R1090 - General Learning Space - (64.81 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R1091 - General Learning Space - (70.13 SQM) - Teaching Space: 1	● Student Space (32)	
B00B - R1092 - General Learning Space - (70.49 SQM) - Teaching Space: 1	● Student Space (32)	
B00B - R1093 - General Learning Space - (65.19 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R1094 - General Assistants - (65.19 SQM)	○ Office (16)	
B00B - R1095 - Staff Lounge - (66.01 SQM)	○ Office (16)	
B00B - R9001 - Movement - (9.28 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - Student Canteen - (57.02 SQM)	Not Applicable	Circulation or storage space.
B00C - R0016 - Movement - (316.94 SQM)	Not Applicable	Circulation or storage space.
B00C - R0017 - Movement - (10.77 SQM)	Not Applicable	Circulation or storage space.
B00C - R0018 - Movement - (5.37 SQM)	Not Applicable	Circulation or storage space.
B00C - R0019 - Movement - (6.23 SQM)	Not Applicable	Circulation or storage space.
B00C - R0020 - Movement - (13.41 SQM)	Not Applicable	Circulation or storage space.
B00C - R0025 - Movement - (233.28 SQM)	Not Applicable	Circulation or storage space.
B00C - R0026 - Movement - (10.68 SQM)	Not Applicable	Circulation or storage space.
B00C - R0028 - General Assistants - (16.43 SQM)	○ Office (4)	
B00C - R1010 - Staff Study - (6.81 SQM)	○ Office (1)	
B00C - R1017 - Movement - (37.4 SQM)	Not Applicable	Circulation or storage space.
B00C - R1018 - Staff Kitchen - (6.83 SQM)	○ Office (1)	
B00C - R1019 - Staff Study - (32.06 SQM)	○ Office (8)	
B00C - R1020 - Shared Learning Space - (76.42 SQM)	● Student Space (35)	
B00C - R1021 - Practice/Seminar - (77.06 SQM)	Not Applicable	Circulation or storage space.
B00C - R1022 - Performance Workshop - (77.9 SQM)	● Student Space (36)	
B00C - R1023 - Movement - (13.6 SQM)	Not Applicable	Circulation or storage space.
B00C - R1024 - Movement - (13.12 SQM)	Not Applicable	Circulation or storage space.
B00D - R0097 - Staff Study - (65.4 SQM)	○ Office (16)	
B00D - R0100 - Movement - (192.43 SQM)	Not Applicable	Circulation or storage space.
B00D - R0101 - Laboratory L.S. - (84.01 SQM) - Teaching Space: 1	● Student Space (38)	
B00D - R0103 - Preparation - (28.9 SQM)	Not Applicable	Circulation or storage space.
B00D - R0104 - Laboratory L.S. - (91.16 SQM) - Teaching Space: 1	● Student Space (42)	
B00D - R0105 - General Learning Space - (57.64 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0108 - General Learning Space - (50.17 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R0115 - Preparation - (19.35 SQM)	Not Applicable	Circulation or storage space.
B00D - R0116 - Preparation - (5.6 SQM)	Not Applicable	Circulation or storage space.
B00D - R0117 - Laboratory L.S. - (91.64 SQM) - Teaching Space: 1	● Student Space (42)	
B00D - R0120 - Computer Learning Space - (50.04 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R1201 - General Learning Space - (57.18 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R1207 - General Learning Space - (51.5 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R1208 - General Learning Space - (52.17 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1209 - Computer Learning Space - (57.27 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R1212 - General Learning Space - (51.06 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R1215 - General Learning Space - (57.76 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R1216 - Staff Study - (25.47 SQM)	○ Office (6)	
B00D - R1217 - General Learning Space - (52.05 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1218 - General Learning Space - (52.05 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1220 - Staff Study - (38.86 SQM)	○ Office (9)	
B00D - R1221 - General Learning Space - (51.07 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R1222 - General Learning Space - (44.45 SQM) - Teaching Space: 1	● Student Space (20)	
B00D - R1224 - Movement - (186.25 SQM)	Not Applicable	Circulation or storage space.
B00D - R1227 - Staff Study - (37.89 SQM)	○ Office (9)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R1228 - Staff Study - (9.14 SQM)	Office (2)	
B00E - R0001 - Computer Learning Space - (49.57 SQM) - Teaching Space: 1	Student Space (22)	
B00E - R0002 - Computer Learning Space - (48.42 SQM) - Teaching Space: 1	Student Space (22)	
B00E - R0004 - Staff Study - (56.38 SQM)	Office (14)	
B00E - R0005 - Computer Learning Space - (52.52 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0009 - Duplicating Workroom - (17.68 SQM)	Office (4)	
B00E - R0010 - Seminar - (12.79 SQM)	Office (3)	
B00E - R0011 - Workroom - (12.79 SQM)	Office (3)	
B00E - R0015 - Administration - Clerical - (44.91 SQM)	Office (11)	
B00E - R0016 - Audio Visual Workroom - (46.87 SQM)	Student Space (21)	
B00E - R0019 - General Learning Space - (54.38 SQM) - Teaching Space: 1	Student Space (25)	
B00E - R0020 - Movement - (148.32 SQM)	Not Applicable	Circulation or storage space.
B00E - R0026 - Main Area - (429 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - Laboratory L.S. - (92.1 SQM) - Teaching Space: 1	Student Space (42)	
B00E - R1002 - Preparation - (24.33 SQM)	Not Applicable	Circulation or storage space.
B00E - R1004 - Laboratory L.S. - (86.29 SQM) - Teaching Space: 1	Student Space (40)	
B00E - R1006 - General Learning Space - (51.34 SQM) - Teaching Space: 1	Student Space (23)	
B00E - R1007 - Staff Study - (13.05 SQM)	Office (3)	
B00E - R1009 - Computer Learning Space - (59.32 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R1010 - General Learning Space - (52.66 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1011 - General Learning Space - (54.08 SQM) - Teaching Space: 1	Student Space (25)	
B00E - R1012 - Staff Study - (26.65 SQM)	Office (6)	
B00E - R1013 - General Learning Space - (61.16 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R1015 - General Learning Space - (52.24 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1017 - Staff Study - (5.18 SQM)	Office (1)	
B00E - R1018 - Staff Study - (15.49 SQM)	Office (3)	
B00E - R1022 - Movement - (152.13 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Dark Room - (22.26 SQM)	Office (5)	
B00G - R0005 - General Learning Space - (58.88 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0006 - General Learning Space - Type 9 - (58.32 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0010 - Materials Workshop - Type 2 - (113.12 SQM)	Student Space (52)	
B00G - R0011 - Materials Workshop - Type 2 - (113.37 SQM)	Student Space (52)	
B00G - R0013 - General Learning Space - Type 8 - (58.83 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0014 - General Learning Space - Type 8 - (58.91 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0016 - Welding Area - (13.03 SQM)	Not Applicable	Circulation or storage space.
B00G - R1003 - Staff Study - (51.47 SQM)	Office (12)	
B00G - R1006 - Visual Arts Workshop - (117.1 SQM)	Student Space (54)	
B00G - R1007 - General Learning Space - (56.68 SQM) - Teaching Space: 1	Student Space (26)	
B00G - R1008 - General Learning Space - Type 5 - (56.88 SQM) - Teaching Space: 1	Student Space (26)	
B00G - R1012 - Visual Arts Workshop - (97.41 SQM)	Student Space (45)	
B00G - R1013 - General Learning Space - Type 4 - (58.88 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R1014 - General Learning Space - Type 4 - (58.88 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R9001 - Outdoor Workshop - (162.25 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Multi-Purpose Space - (654.18 SQM)	Student Space (303)	
B00K - R0002 - Movement - (22.19 SQM)	Not Applicable	Circulation or storage space.
B00K - R0003 - Staff Study - (16.12 SQM)	Office (4)	
B00K - R0004 - Tiered Learning Area - (277.28 SQM)	Student Space (128)	
B00K - R0008 - Public Entry - (61.11 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00K - R0009 - Administration - Clerical - (5.88 SQM)	Office (1)	
B00K - R0010 - Staff Kitchen - (9.24 SQM)	Office (2)	
B00K - R9008 - Movement - (11.19 SQM)	Not Applicable	Circulation or storage space.
B00K - R9013 - Movement - (37.07 SQM)	Not Applicable	Circulation or storage space.
B00M - R0004 - General Learning Space - (59.42 SQM) - Teaching Space: 1	Student Space (27)	
B00M - R0005 - General Learning Space - (59.03 SQM) - Teaching Space: 1	Student Space (27)	
B00M - R0007 - Staff Study - (44.78 SQM)	Office (11)	
B00M - R0008 - Movement - (18.88 SQM)	Not Applicable	Circulation or storage space.
B00M - R0018 - Movement - (5.37 SQM)	Not Applicable	Circulation or storage space.
B00M - R0020 - Preparation - (29.34 SQM)	Not Applicable	Circulation or storage space.
B00M - R0021 - Science Laboratory - (99.71 SQM)	Student Space (46)	
B00M - R0022 - General Learning Space - Type 10 - (59.17 SQM) - Teaching Space: 0.5	Student Space (27)	
B00M - R0023 - General Learning Space - Type 10 - (58.56 SQM) - Teaching Space: 0.5	Student Space (27)	
B00M - R0024 - Shared Learning Space - (66.01 SQM)	Student Space (30)	
B00M - R0025 - Seminar Space - (23.35 SQM)	Office (5)	
B00M - R0026 - General Learning Space - Type 10 - (58.54 SQM) - Teaching Space: 0.5	Student Space (27)	
B00M - R0027 - General Learning Space - Type 10 - (58.9 SQM) - Teaching Space: 0.5	Student Space (27)	
B00M - R0028 - Science Laboratory - (96.13 SQM)	Student Space (44)	
B00M - R0029 - Seminar Space - (21.21 SQM)	Office (5)	
B00M - R0032 - Preparation - (28.22 SQM)	Not Applicable	Circulation or storage space.
B00M - R1003 - General Learning Space - (59.01 SQM) - Teaching Space: 1	Student Space (27)	
B00M - R1004 - Shared Learning Space - (95.26 SQM)	Student Space (44)	
B00M - R1005 - Seminar Space - (26.23 SQM)	Office (6)	
B00M - R1006 - Staff Study - (101.24 SQM)	Office (25)	
B00M - R1008 - General Learning Space - (58.41 SQM) - Teaching Space: 1	Student Space (27)	
B00M - R1009 - General Learning Space - (57.78 SQM) - Teaching Space: 1	Student Space (26)	
B00M - R1013 - Movement - (7.05 SQM)	Not Applicable	Circulation or storage space.
B00M - R1020 - Shared Learning Space - (46.52 SQM)	Student Space (21)	
B00M - R1021 - Seminar Space - (21.87 SQM)	Office (5)	
B00M - R1022 - General Learning Space - (58.99 SQM) - Teaching Space: 1	Student Space (27)	
B00M - R1023 - General Learning Space - (59.44 SQM) - Teaching Space: 1	Student Space (27)	
B00M - R1024 - General Learning Space - (57.77 SQM) - Teaching Space: 1	Student Space (26)	
B00M - R1025 - General Learning Space - (58.57 SQM) - Teaching Space: 1	Student Space (27)	
B00M - R1026 - Shared Learning Space - (62.37 SQM)	Student Space (28)	
B00M - R1027 - Seminar Space - (24.11 SQM)	Office (6)	
B00M - R1028 - General Learning Space - (59.83 SQM) - Teaching Space: 1	Student Space (27)	
B00M - R1029 - General Learning Space - (59.82 SQM) - Teaching Space: 1	Student Space (27)	
B00M - R1038 - Practical Activities - (5.4 SQM)	Student Space (2)	
B00M - R1041 - Practical Activities - (11.74 SQM)	Student Space (5)	
B00M - R1042 - Practical Activities - (6.27 SQM)	Student Space (2)	
NS 220 13228 - NS 220 13228 - Science Learning/Preparation Space - (95 SQM)	Not Applicable	Circulation or storage space.
OS 520 19315 - OS 520 19315 - Staff Study - (57 SQM)	Office (14)	
OS 600 10162 - OS 600 10162 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 600 13437 - OS 600 13437 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 600 13455 - OS 600 13455 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 600 13988 - OS 600 13988 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 600 15116 - OS 600 15116 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 600 15310 - OS 600 15310 - Learning Unit - Small - (57 SQM)	Student Space (26)	

Entity Location	Audit Condition Classification (Capacity)	Comment
OS 600 18317 - OS 600 18317 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 18318 - OS 600 18318 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 18322 - OS 600 18322 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 601 10562 - OS 601 10562 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 14533 - OS 601 14533 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 17665 - OS 601 17665 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 17670 - OS 601 17670 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 17889 - OS 601 17889 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 720 11824 - OS 720 11824 - Science Laboratory/Prep Room - (114 SQM)	Not Applicable	Circulation or storage space.
OS 720 14160 - OS 720 14160 - Science Laboratory/Prep Room - (114 SQM)	Not Applicable	Circulation or storage space.
OS 751 19551 - OS 751 19551 - Learning Unit - ESL - (76 SQM)	● Student Space (35)	