

VENTILATION AUDIT REPORT

SCHOOL:	Killara Public School (3918)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Ku-Ring-Gai
LOCAL GOVERNMENT AREA:	Ku-Ring-Gai

3918 - Killara Public School
Site Plan (10453)





















1:833

Printed: 06-Nov-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0004 - Movement - (5.9 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Home Base - (63.62 SQM) - Teaching Space: 1	● Student Space (29)	
B00A - R0014 - Principal - (18.33 SQM)	● Office (4)	
B00A - R0019 - Movement - (33.29 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Home Base - (51.27 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R0022 - Sick Bay - (11.57 SQM)	● Student Space (5)	
B00A - R0024 - Clerical Office - (29.29 SQM)	● Office (7)	
B00A - R0025 - Entry Vestibule - (26.62 SQM)	Not Applicable	Circulation or storage space.
B00A - R0026 - Interview - (16.51 SQM)	● Office (4)	
B00A - R0028 - Clerical Office/Workroom - (14.43 SQM)	● Office (3)	
B00A - R0029 - Movement - (14.16 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Movement - (26.15 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Canteen - (14.33 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Raised Platform - (37.2 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Home Base - (67.09 SQM) - Teaching Space: 1	● Student Space (31)	
B00E - R0004 - Movement - (19.78 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Home Base - (52.07 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0006 - Practical Activities - 1hb - (17.62 SQM)	● Student Space (8)	
B00F - R0002 - Practical Activities - (19.42 SQM)	● Student Space (9)	
B00F - R0003 - Home Base - (58.45 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0004 - Withdrawal Space - 2hb - (10.87 SQM)	● Student Space (5)	
B00F - R0005 - Home Base - (58.49 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0006 - Practical Activities - (19.45 SQM)	● Student Space (9)	
B00F - R0009 - Practical Activities - S - 1hb - (24.64 SQM)	● Student Space (11)	
B00F - R0010 - Special Programs Room - Type 1 - (58.83 SQM)	● Student Space (27)	
B00G - R0002 - Home Base - (58.51 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0003 - Practical Activities - (19.45 SQM)	● Student Space (9)	
B00G - R0004 - Withdrawal Space - 2hb - (10.93 SQM)	● Student Space (5)	
B00G - R0005 - Practical Activities - (19.49 SQM)	● Student Space (9)	
B00G - R0006 - Home Base - (58.53 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0009 - Practical Activities - (19.48 SQM)	● Student Space (9)	
B00G - R0010 - Home Base - (58.49 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0011 - Withdrawal Space - 2hb - (10.96 SQM)	● Student Space (5)	
B00G - R0012 - Practical Activities - (19.33 SQM)	● Student Space (8)	
B00G - R0013 - Home Base - (58.66 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0016 - Practical Activities - (24.23 SQM)	● Student Space (11)	
B00G - R0017 - Home Base - (58.64 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0019 - Canteen - (13.28 SQM)	Not Applicable	Circulation or storage space.
B00H - R0003 - Reading Area - (104.33 SQM)	● Student Space (48)	
B00H - R0004 - Staff Room - (39.55 SQM)	● Office (9)	
B00I - R0002 - Communal Space - (144.23 SQM)	● Student Space (66)	
B00I - R0003 - Raised Platform - (59.92 SQM)	Not Applicable	Circulation or storage space.
B00I - R0016 - Movement - (5.7 SQM)	Not Applicable	Circulation or storage space.
B00I - R0017 - Movement - (13.13 SQM)	Not Applicable	Circulation or storage space.
B00I - R0018 - Movement - (11.38 SQM)	Not Applicable	Circulation or storage space.
B00M - R0002 - Home Base - (62.14 SQM) - Teaching Space: 1	● Student Space (28)	
B00M - R0003 - Home Base - (62.83 SQM) - Teaching Space: 1	● Student Space (29)	
B00M - R0004 - Special Programs Room - (12.68 SQM)	● Student Space (5)	
B00M - R0005 - Home Base - (61.44 SQM) - Teaching Space: 1	● Student Space (28)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00M - R0006 - Isolation Space - (10.58 SQM)	 Office (2)	
B00M - R0008 - Home Base - (56.91 SQM) - Teaching Space: 1	 Student Space (26)	
B00M - R0009 - Home Base - (54.51 SQM) - Teaching Space: 1	 Student Space (25)	
B00M - R0012 - Special Programs Room - (9.85 SQM)	 Student Space (4)	
B00M - R0014 - Practical Activities - 1hb - (23.12 SQM)	 Student Space (10)	
B00M - R0015 - Practical Activities - 1hb - (24.43 SQM)	 Student Space (11)	
B00M - R0016 - Practical Activities - 1hb - (21.29 SQM)	 Student Space (9)	
B00M - R0017 - Practical Activities - 1hb - (22.91 SQM)	 Student Space (10)	
B00M - R0018 - Practical Activities - 1hb - (19.83 SQM)	 Student Space (9)	
B00M - R1001 - Special Programs Room - (9.44 SQM)	 Student Space (4)	
B00M - R1002 - Home Base - (60.86 SQM) - Teaching Space: 1	 Student Space (28)	
B00M - R1003 - Home Base - (61.03 SQM) - Teaching Space: 1	 Student Space (28)	
B00M - R1004 - Special Programs Room - (10.55 SQM)	 Student Space (4)	
B00M - R1006 - Home Base - (57.78 SQM) - Teaching Space: 1	 Student Space (26)	
B00M - R1007 - Outdoor Learning Area - (94.66 SQM)	Not Applicable	Circulation or storage space.
B00M - R1008 - Practical Activities - 1hb - (21.74 SQM)	 Student Space (10)	
B00M - R1009 - Practical Activities - 1hb - (21.29 SQM)	 Student Space (9)	
B00M - R1010 - Practical Activities - 1hb - (21.43 SQM)	 Student Space (9)	
B00M - R1011 - Outdoor Learning Area - (93.92 SQM)	Not Applicable	Circulation or storage space.
OS 602 14186 - OS 602 14186 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	