


VENTILATION AUDIT REPORT

SCHOOL:	Killarney Heights High School (8422)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Wakehurst
LOCAL GOVERNMENT AREA:	Northern Beaches

8422 - Killarney Heights High School
Site Plan (13173)



1:1,279

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0021 - General Learning Space - (58.44 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0025 - General Learning Space - (52.58 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0031 - Preparation - Science - (30.04 SQM)	Not Applicable	Circulation or storage space.
B00A - R0032 - Performance Workshop - (85.03 SQM)	● Student Space (39)	
B00A - R0055 - Laboratory L.S. - (93.13 SQM) - Teaching Space: 1	● Student Space (43)	
B00A - R0061 - Public Entry - (15.43 SQM)	Not Applicable	Circulation or storage space.
B00A - R0062 - Movement - (13.72 SQM)	Not Applicable	Circulation or storage space.
B00A - R0063 - Movement - (20.97 SQM)	Not Applicable	Circulation or storage space.
B00A - R0064 - Student Waiting - (6.38 SQM)	Not Applicable	Circulation or storage space.
B00A - R0065 - Clinic - (7.63 SQM)	● Office (1)	
B00A - R0066 - Staff Study - (15.58 SQM)	● Office (3)	
B00A - R0072 - Tea Room - (8.89 SQM)	Not Applicable	Circulation or storage space.
B00A - R0073 - Deputy Principal Office - (12.57 SQM)	● Office (3)	
B00A - R0074 - Administration - Clerical - (19.66 SQM)	● Office (4)	
B00A - R0076 - Administration - Clerical - (37.55 SQM)	● Office (9)	
B00A - R0077 - Interview/Meeting - (10.4 SQM)	● Office (2)	
B00A - R0078 - Principal Office - (19.02 SQM)	● Office (4)	
B00A - R0082 - Deputy Principal Office - (12.5 SQM)	● Office (3)	
B00A - R0083 - Seminar Space - (58.11 SQM)	● Office (14)	
B00A - R0084 - Movement - (14.49 SQM)	Not Applicable	Circulation or storage space.
B00A - R1003 - General Learning Space - (52.58 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1005 - Interview/Office - Type 1 - (12.7 SQM)	● Office (3)	
B00A - R1006 - General Learning Space - (58.36 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R1008 - Computer Learning Space - (52.65 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1009 - Computer Room - (5.87 SQM)	● Student Space (2)	
B00A - R1010 - General Learning Space - (65.98 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R1013 - Textiles Technology L.S. - (71.74 SQM) - Teaching Space: 1	● Student Space (33)	
B00A - R1017 - General Learning Space - (52.58 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1021 - Art Learning Space - (52.73 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1022 - General Learning Space - (52.44 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1028 - Darkroom Space - (6.59 SQM)	● Office (1)	
B00A - R1029 - Dark Room - (20.23 SQM)	● Office (5)	
B00A - R1030 - Commonroom - (123.1 SQM)	● Office (30)	
B00A - R1031 - Staff Kitchen - (13 SQM)	● Office (3)	
B00B - R0004 - Music Learning Space - (52.51 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0008 - Metal Technology Bay - (39.2 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Materials Technology L.S. - (92.73 SQM) - Teaching Space: 1	● Student Space (43)	
B00B - R0010 - Design/Technology L.S. - (58.36 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0016 - Design L.S. - (51.85 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0020 - Food Technology L.S. - (65.86 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R0021 - Preparation - Materials - (12.68 SQM)	Not Applicable	Circulation or storage space.
B00B - R0033 - Food Technology L.S. - (117.48 SQM) - Teaching Space: 1	● Student Space (54)	
B00B - R0034 - Staff Study - (40.93 SQM)	● Office (10)	
B00B - R0036 - Metal Technology L.S. - (77.21 SQM) - Teaching Space: 1	● Student Space (35)	
B00B - R0037 - Welding Area - (7.78 SQM)	Not Applicable	Circulation or storage space.
B00B - R1003 - Music Learning Space - (51.78 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1006 - Wood Technology L.S. - (85.12 SQM) - Teaching Space: 1	● Student Space (39)	
B00B - R1008 - Wood Technology Bay - (33.98 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R1009 - Wood Technology L.S. - (79.35 SQM) - Teaching Space: 1	Student Space (36)	
B00B - R1010 - Design L.S. - (58.43 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R1013 - Music Learning Space - (52.65 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1022 - Art Learning Space - (71.84 SQM) - Teaching Space: 1	Student Space (33)	
B00B - R1030 - Staff Study - (29.58 SQM)	Office (7)	
B00B - R1033 - Art Learning Space - (106.26 SQM) - Teaching Space: 1	Student Space (49)	
B00C - R0006 - Multi-Purpose Space - (316.85 SQM)	Student Space (147)	
B00C - R0008 - Student Canteen - (56.74 SQM)	Not Applicable	Circulation or storage space.
B00C - R0015 - Movement - (14.12 SQM)	Not Applicable	Circulation or storage space.
B00C - R0021 - Movement - (14.01 SQM)	Not Applicable	Circulation or storage space.
B00C - R0023 - Movement - (10.36 SQM)	Not Applicable	Circulation or storage space.
B00C - R0027 - Movement - (10.98 SQM)	Not Applicable	Circulation or storage space.
B00C - R1006 - Movement - (12.21 SQM)	Not Applicable	Circulation or storage space.
B00C - R1012 - Movement - (12.22 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - General Learning Space - (52.65 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0017 - General Learning Space - (52.51 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0020 - General Learning Space - (58.43 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0021 - Laboratory L.S. - (91.66 SQM) - Teaching Space: 1	Student Space (42)	
B00D - R0024 - Laboratory L.S. - (85.39 SQM) - Teaching Space: 1	Student Space (39)	
B00D - R0029 - Staff Study - (36.01 SQM)	Office (9)	
B00D - R0033 - Preparation - Science - (39.27 SQM)	Not Applicable	Circulation or storage space.
B00D - R0037 - Science Laboratory - (92.67 SQM)	Student Space (42)	
B00D - R0038 - Science Laboratory - (24.96 SQM)	Student Space (11)	
B00D - R1003 - General Learning Space - (52.65 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1005 - General Learning Space - (58.36 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R1006 - General Learning Space - (52.58 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1007 - Multi Media Workshop - (11.53 SQM)	Not Applicable	Circulation or storage space.
B00D - R1008 - Staff Study - (25.89 SQM)	Office (6)	
B00D - R1009 - Staff Study - (12.64 SQM)	Office (3)	
B00D - R1012 - Computer Room - (12.52 SQM)	Student Space (5)	
B00D - R1013 - Computer Learning Space - (58.21 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R1016 - General Learning Space - (52.51 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1019 - General Learning Space - (58.43 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R1020 - General Learning Space - (52.8 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1021 - General Learning Space - (52.65 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1025 - General Learning Space - (58.36 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R1031 - Staff Study - (21.48 SQM)	Office (5)	
B00D - R1032 - Tea Room - (5.82 SQM)	Not Applicable	Circulation or storage space.
B00D - R1033 - Staff Study - (19.84 SQM)	Office (4)	
B00E - R0006 - General Learning Space - (49.7 SQM) - Teaching Space: 1	Student Space (23)	
B00E - R0007 - General Learning Space - (57.95 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0009 - Staff Study - (20.02 SQM)	Office (5)	
B00E - R0015 - General Assistants - (10.73 SQM)	Office (2)	
B00E - R0018 - Main Area - (51.79 SQM)	Not Applicable	Circulation or storage space.
B00E - R0030 - Senior Study - (14.75 SQM)	Office (3)	
B00E - R0031 - Senior Study - (15.95 SQM)	Office (3)	
B00E - R0033 - Tea Room - (7.04 SQM)	Not Applicable	Circulation or storage space.
B00E - R0034 - Staff Study - (18.28 SQM)	Office (4)	
B00E - R0035 - Commonroom - (84.99 SQM)	Office (21)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0036 - Staff Kitchen - (12.52 SQM)	Office (3)	
B00E - R0039 - Main Entry - (5.64 SQM)	Not Applicable	Circulation or storage space.
B00E - R0040 - Main Area - (288.54 SQM)	Not Applicable	Circulation or storage space.
B00E - R1004 - General Learning Space - (50.99 SQM) - Teaching Space: 1	Student Space (23)	
B00E - R1007 - Fitness Laboratory - (92.06 SQM)	Student Space (42)	
B00E - R1009 - Preparation - Science - (22.56 SQM)	Not Applicable	Circulation or storage space.
B00E - R1011 - Laboratory L.S. - (84.28 SQM) - Teaching Space: 1	Student Space (39)	
B00E - R1015 - General Learning Space - (50.99 SQM) - Teaching Space: 1	Student Space (23)	
B00E - R1018 - General Learning Space - (57.5 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R1019 - General Learning Space - (52.01 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1020 - General Learning Space - (52.08 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1022 - Computer Learning Space - (57.95 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R1026 - Tea Room - (5.81 SQM)	Not Applicable	Circulation or storage space.
B00E - R1027 - Staff Study - (25.04 SQM)	Office (6)	
B00E - R1029 - Staff Study - (20.45 SQM)	Office (5)	
B00F - R0001 - Movement - (68.53 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Multi-Purpose Space - (494.56 SQM)	Student Space (229)	
B00F - R0007 - Movement - (10.22 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Stage - (109.79 SQM)	Not Applicable	Circulation or storage space.
B00F - R0010 - Movement - (9.85 SQM)	Not Applicable	Circulation or storage space.
B00F - R0016 - Movement - (25.27 SQM)	Not Applicable	Circulation or storage space.
B00F - R0021 - Staff Kitchen - (7.42 SQM)	Office (1)	
B00F - R0023 - Movement - (10.47 SQM)	Not Applicable	Circulation or storage space.
B00F - R9001 - Practice/Seminar - (114.98 SQM)	Not Applicable	Circulation or storage space.