

VENTILATION AUDIT REPORT

SCHOOL:	Killarney Vale Public School (4426)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	The Entrance
LOCAL GOVERNMENT AREA:	Central Coast

4426 - Killarney Vale Public School
Site Plan (11091)



1:967

Printed: 24-Apr-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (6.4 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Movement - (45.15 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Principal - (17.06 SQM)	Office (4)	
B00A - R0005 - Entry Vestibule - (8.48 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Clerical Office - (12.66 SQM)	Office (3)	
B00A - R0007 - Sick Bay - (9.34 SQM)	Student Space (4)	
B00A - R0008 - Duplicating Workroom - (33.04 SQM)	Office (8)	
B00A - R0009 - Interview - (8.58 SQM)	Office (2)	
B00A - R0014 - Staff Room Annexe - (13.22 SQM)	Office (3)	
B00A - R0015 - Deputy Principal - (14.6 SQM)	Office (3)	
B00A - R0016 - Movement - (24.55 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Practical Activities - 1hb - (14.04 SQM)	Student Space (6)	
B00A - R1002 - Home Base - (61 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R1003 - Home Base - (61 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R1004 - Practical Activities - 1hb - (14.04 SQM)	Student Space (6)	
B00A - R1005 - Movement - (45.65 SQM)	Not Applicable	Circulation or storage space.
B00B - M0001 - Movement - (7.07 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Practical Activities - 1hb - (13.98 SQM)	Student Space (6)	
B00B - R0003 - Home Base - (60.14 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0005 - Home Base - M - (62.41 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0006 - Practical Activities - 1hb - (12.34 SQM)	Student Space (5)	
B00B - R0009 - Movement - (73.66 SQM)	Not Applicable	Circulation or storage space.
B00B - R0010 - Movement - (7.01 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Movement - (72.8 SQM)	Not Applicable	Circulation or storage space.
B00B - R1002 - Practical Activities - 1hb - (13.99 SQM)	Student Space (6)	
B00B - R1003 - Home Base - (60.04 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R1004 - Home Base - (59.97 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R1005 - Practical Activities - 1hb - (13.99 SQM)	Student Space (6)	
B00B - R1008 - Movement - (9.62 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Practical Activities - 1hb - (14.36 SQM)	Student Space (6)	
B00C - R0005 - Practical Activities - 1hb - (13.13 SQM)	Student Space (6)	
B00C - R0006 - Movement - (34.32 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - Movement - (24.48 SQM)	Not Applicable	Circulation or storage space.
B00C - R0009 - Practical Activities - 1hb - (14.02 SQM)	Student Space (6)	
B00C - R0010 - Home Base - (59.69 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0013 - Home Base - (48.53 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R0015 - Home Base - (50.26 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R1001 - Movement - (34.33 SQM)	Not Applicable	Circulation or storage space.
B00C - R1002 - Practical Activities - 1hb - (14.35 SQM)	Student Space (6)	
B00C - R1003 - Home Base - (59.07 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R1004 - Home Base - (60.96 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R1005 - Practical Activities - 1hb - (13.12 SQM)	Student Space (6)	
B00C - R1006 - Practical Activities - 1hb - (14.01 SQM)	Student Space (6)	
B00C - R1007 - Special Programs Room - (59.69 SQM)	Student Space (27)	
B00C - R1008 - Movement - (24.48 SQM)	Not Applicable	Circulation or storage space.
B00C - R1011 - Movement - (17.06 SQM)	Not Applicable	Circulation or storage space.
B00C - R1012 - Movement - (7.24 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Seminar/Study - (14.49 SQM)	Office (3)	
B00E - R0004 - Movement - (10.41 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0008 - Reading Area - (252.84 SQM)	● Student Space (117)	
B00E - R0009 - Movement - (12.44 SQM)	Not Applicable	Circulation or storage space.
B00E - R0013 - Seminar/Study - (14.48 SQM)	● Office (3)	
B00E - R0015 - Movement - (5.12 SQM)	Not Applicable	Circulation or storage space.
B00E - R0016 - Movement - (7.07 SQM)	Not Applicable	Circulation or storage space.
B00E - R9005 - Movement - (10.17 SQM)	Not Applicable	Circulation or storage space.
B00E - R9006 - Communal Space - (227.5 SQM)	● Student Space (105)	
B00E - R9011 - Movement - (5.27 SQM)	Not Applicable	Circulation or storage space.
B00E - R9012 - Raised Platform - (40.26 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Movement - (121.26 SQM)	Not Applicable	Circulation or storage space.
B00F - R0004 - Interview - (22.62 SQM)	● Office (5)	
B00F - R0008 - Canteen - (53.11 SQM)	Not Applicable	Circulation or storage space.
B00F - R9003 - Movement - (33.47 SQM)	Not Applicable	Circulation or storage space.
B00G - R0006 - Movement - (10.78 SQM)	Not Applicable	Circulation or storage space.
B00G - R0007 - Movement - (11.26 SQM)	Not Applicable	Circulation or storage space.
B00G - R0008 - Movement - (71.5 SQM)	Not Applicable	Circulation or storage space.
B00G - R0009 - Movement - (9 SQM)	Not Applicable	Circulation or storage space.
B00G - R0010 - Practical Activities - 1hb - (10.18 SQM)	● Student Space (4)	
B00G - R0011 - Home Base - (47 SQM) - Teaching Space: 1	● Student Space (21)	
B00G - R0012 - Practical Activities - 1hb - (13.67 SQM)	● Student Space (6)	
B00G - R0013 - Home Base - (51.12 SQM) - Teaching Space: 1	● Student Space (23)	
B00H - R0007 - Movement - (10.71 SQM)	Not Applicable	Circulation or storage space.
B00H - R0008 - Movement - (42.09 SQM)	Not Applicable	Circulation or storage space.
B00H - R0009 - Movement - (9.56 SQM)	Not Applicable	Circulation or storage space.
B00H - R0010 - Movement - (6.85 SQM)	Not Applicable	Circulation or storage space.
B00H - R0011 - Home Base - (58.93 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R0012 - Practical Activities - 1hb - (13.81 SQM)	● Student Space (6)	
B00H - R0013 - Home Base - (55.81 SQM) - Teaching Space: 1	● Student Space (25)	
B00H - R0014 - Practical Activities - 1hb - (20.83 SQM)	● Student Space (9)	
B00J - R0009 - Movement - (41.4 SQM)	Not Applicable	Circulation or storage space.
B00J - R0010 - Practical Activities - 1hb - (16.61 SQM)	● Student Space (7)	
B00J - R0011 - Home Base - (71.74 SQM) - Teaching Space: 1	● Student Space (33)	
B00J - R0012 - Practical Activities - 1hb - (16.96 SQM)	● Student Space (7)	
B00J - R0013 - Home Base - (51.16 SQM) - Teaching Space: 1	● Student Space (23)	
B00K - R0007 - Movement - (27.13 SQM)	Not Applicable	Circulation or storage space.
B00L - R0002 - Staff Room Annexe - (12.81 SQM)	● Office (3)	
B00L - R0003 - Movement - (29.74 SQM)	Not Applicable	Circulation or storage space.
B00L - R0004 - Home Base - (66.1 SQM) - Teaching Space: 1	● Student Space (30)	
B00L - R0005 - Withdrawal Space - 1hb - (11.74 SQM)	● Student Space (5)	
B00L - R0006 - Home Base - (61.93 SQM) - Teaching Space: 1	● Student Space (28)	
B00L - R0012 - Movement - (40.86 SQM)	Not Applicable	Circulation or storage space.
B00L - R0019 - Practical Activities - (52.28 SQM)	● Student Space (24)	
B00M - R0001 - Staff Room - (63.66 SQM)	● Office (15)	
B00M - R0006 - Staff Room Annexe - (17.05 SQM)	● Office (4)	
B00M - R0008 - Movement - (35.05 SQM)	Not Applicable	Circulation or storage space.
OS 606 19221 - OS 606 19221 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	