

VENTILATION AUDIT REPORT

SCHOOL:	Kincumber High School (8585)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Terrigal
LOCAL GOVERNMENT AREA:	Central Coast

8585 - Kincumber High School
Site Plan (10455)



1:1,440

Printed: 07-Jul-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Ancillary Staff - (22.12 SQM)	Office (5)	
B00A - R0003 - Deputy Principal Office - (13.19 SQM)	Office (3)	
B00A - R0004 - Principal Office - (19.8 SQM)	Office (4)	
B00A - R0005 - Administration - Executive - (12.71 SQM)	Office (3)	
B00A - R0006 - Leading Teacher - (12.61 SQM)	Office (3)	
B00A - R0007 - Clinic - Girls - (13.89 SQM)	Office (3)	
B00A - R0010 - Clinic - Boys - (14.05 SQM)	Office (3)	
B00A - R0011 - Deputy Principal Office - (16.14 SQM)	Office (4)	
B00A - R0012 - Administration - Clerical - (35.12 SQM)	Office (8)	
B00A - R0019 - Student Canteen - (54.85 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - General Assistants - (13.19 SQM)	Office (3)	
B00A - R0027 - Movement - (87.29 SQM)	Not Applicable	Circulation or storage space.
B00A - R0030 - Interview/Meeting - (22.12 SQM)	Office (5)	
B00A - R0031 - Staff Lounge - (13.19 SQM)	Office (3)	
B00B - R0001 - Metal Technology L.S. - (84.28 SQM) - Teaching Space: 1	Student Space (39)	
B00B - R0002 - Welding Area - (8.35 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Movement - (10.81 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Wood Technology L.S. - (92.82 SQM) - Teaching Space: 1	Student Space (43)	
B00B - R0008 - Wood Technology L.S. - (92.74 SQM) - Teaching Space: 1	Student Space (43)	
B00B - R0009 - Wood Technology Bay - (34.43 SQM)	Not Applicable	Circulation or storage space.
B00B - R0010 - Staff Study - (27.94 SQM)	Office (6)	
B00B - R0011 - Design L.S. - (56.76 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0012 - Design L.S. - (56.68 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0015 - Wood Technology Bay - (87.33 SQM)	Not Applicable	Circulation or storage space.
B00B - R0021 - Metal Technology Bay - (35.73 SQM)	Not Applicable	Circulation or storage space.
B00B - R0029 - Metal Technology L.S. - (91.64 SQM) - Teaching Space: 1	Student Space (42)	
B00B - R0030 - Movement - (117.24 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Art Learning Space - (60.95 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R0004 - Study Space - (18.92 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Staff Study - (23.22 SQM)	Office (5)	
B00C - R0008 - Art Learning Space - (60.87 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R0012 - Art Learning Space - (61.02 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R0013 - Outdoor Learning Area - (25.88 SQM)	Not Applicable	Circulation or storage space.
B00C - R0014 - Movement - (93.12 SQM)	Not Applicable	Circulation or storage space.
B00C - R0017 - Workshop - (30.08 SQM)	Student Space (13)	
B00D - R0001 - Food Technology L.S. - (100.38 SQM) - Teaching Space: 1	Student Space (46)	
B00D - R0002 - Computer Learning Space - (75.36 SQM) - Teaching Space: 1	Student Space (34)	
B00D - R0005 - Design/Technology L.S. - (75.46 SQM) - Teaching Space: 1	Student Space (35)	
B00D - R0006 - Interview/Office - Type 1 - (22.03 SQM)	Office (5)	
B00D - R0009 - Staff Study - (24.23 SQM)	Office (6)	
B00D - R0010 - Food Technology L.S. - (100.41 SQM) - Teaching Space: 1	Student Space (46)	
B00D - R0012 - Preparation - Materials - (20.95 SQM)	Not Applicable	Circulation or storage space.
B00D - R0013 - Movement - (111.78 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Laboratory L.S. - (93.65 SQM) - Teaching Space: 1	Student Space (43)	
B00E - R0003 - Laboratory L.S. - (91.19 SQM) - Teaching Space: 1	Student Space (42)	
B00E - R0004 - Laboratory L.S. - (91.08 SQM) - Teaching Space: 1	Student Space (42)	
B00E - R0005 - Staff Study - (36.89 SQM)	Office (9)	
B00E - R0007 - Laboratory L.S. - (93.43 SQM) - Teaching Space: 1	Student Space (43)	
B00E - R0008 - Laboratory L.S. - (93.31 SQM) - Teaching Space: 1	Student Space (43)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0009 - Movement - (25.21 SQM)	Not Applicable	Circulation or storage space.
B00E - R0010 - Preparation - Science - (79.11 SQM)	Not Applicable	Circulation or storage space.
B00F - R0004 - Seminar/Study - (13.28 SQM)	Office (3)	
B00F - R0005 - Audio Visual Workroom - (25.96 SQM)	Student Space (12)	
B00F - R0013 - General Learning Space - (47.96 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R0014 - General Learning Space - (47.91 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R0015 - General Learning Space - (47.91 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R0016 - General Learning Space - (48.13 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R0017 - General Learning Space - (47.91 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R0018 - General Learning Space - (47.91 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R0020 - General Learning Space - (46.75 SQM) - Teaching Space: 1	Student Space (21)	
B00F - R0021 - Staff Study - (52.14 SQM)	Office (13)	
B00F - R0024 - Study Space - (25.21 SQM)	Not Applicable	Circulation or storage space.
B00F - R0025 - General Learning Space - (48.11 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R0026 - General Learning Space - (48.13 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R0028 - Leading Teacher - (13.15 SQM)	Office (3)	
B00F - R0031 - Photographic Studio - (13.17 SQM)	Office (3)	
B00F - R0032 - Staff Study - (39.02 SQM)	Office (9)	
B00F - R0033 - Computer Learning Space - (61.22 SQM) - Teaching Space: 1	Student Space (28)	
B00F - R0037 - Senior Seminar - (13.04 SQM)	Office (3)	
B00F - R0038 - Senior Seminar - (12.98 SQM)	Office (3)	
B00F - R0039 - Senior Study - (60.43 SQM)	Office (15)	
B00F - R0045 - Special Learning Space - (49.64 SQM) - Teaching Space: 1	Student Space (23)	
B00F - R0046 - Special Learning Space - (49.55 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R0048 - Special Learning Space - (48.03 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R0049 - Special Learning Space - (47.89 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R0050 - General Learning Space - (48.05 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R0051 - General Learning Space - (48.21 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R0052 - General Learning Space - (48.03 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R0053 - General Learning Space - (47.89 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R0054 - General Learning Space - (52.06 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R0055 - General Learning Space - (52.21 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R0060 - Tiered Learning Area - (67.33 SQM)	Student Space (31)	
B00F - R0062 - Interview/Office - Type 1 - (12.76 SQM)	Office (3)	
B00F - R0063 - Interview/Office - Type 1 - (14.99 SQM)	Office (3)	
B00F - R0079 - Outdoor Learning Area - (22.42 SQM)	Not Applicable	Circulation or storage space.
B00F - R0082 - Main Entry - (12.14 SQM)	Not Applicable	Circulation or storage space.
B00F - R0083 - Main Area - (348.44 SQM)	Not Applicable	Circulation or storage space.
B00F - R0084 - Seminar - (27.64 SQM)	Office (6)	
B00F - R0085 - Commonroom - (80.48 SQM)	Office (20)	
B00F - R0086 - Tea Room - (9.16 SQM)	Not Applicable	Circulation or storage space.
B00F - R0089 - Dark Room - (14.75 SQM)	Office (3)	
B00F - R0099 - General Learning Space - (45.36 SQM) - Teaching Space: 1	Student Space (21)	
B00F - R0101 - General Learning Space - (47.6 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R0102 - Staff Study - (32.64 SQM)	Office (8)	
B00F - R0103 - Staff Study - (32.82 SQM)	Office (8)	
B00F - R0105 - Movement - (935.5 SQM)	Not Applicable	Circulation or storage space.
B00F - R0106 - Staff Study - (63.46 SQM)	Office (15)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0107 - General Learning Space - (47.48 SQM) - Teaching Space: 1	● Student Space (22)	
B00F - R0108 - General Learning Space - (47.21 SQM) - Teaching Space: 1	● Student Space (21)	
B00G - R0002 - Practice/Seminar - (26.33 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Music Learning Space - (61.03 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R0005 - Practice/Seminar - (25.96 SQM)	Not Applicable	Circulation or storage space.
B00G - R0006 - Music Learning Space - (77.98 SQM) - Teaching Space: 1	● Student Space (36)	
B00G - R0008 - Staff Study - (15.91 SQM)	● Office (3)	
B00G - R0012 - Movement - (26.34 SQM)	Not Applicable	Circulation or storage space.
B00H - R0007 - Staff Study - (16.14 SQM)	● Office (4)	
B00H - R0015 - Movement - (55.21 SQM)	Not Applicable	Circulation or storage space.
B00H - R0016 - Movement - (21.47 SQM)	Not Applicable	Circulation or storage space.
B00H - R0018 - Multi-Purpose Space - (491.86 SQM)	● Student Space (228)	
B00H - R0022 - Staff Study - (21.99 SQM)	● Office (5)	
B00H - R0040 - Stage - (115.91 SQM)	Not Applicable	Circulation or storage space.
B00H - R0043 - Staff Study - (33.26 SQM)	● Office (8)	
B00I - R0003 - General Learning Space - (40.23 SQM)	● Student Space (18)	
B00I - R0006 - Movement - (5.71 SQM)	Not Applicable	Circulation or storage space.
B00I - R0014 - General Learning Space - (63.6 SQM) - Teaching Space: 1	● Student Space (29)	
B0II - R0001 - Growing/Breeding - (36.62 SQM)	Not Applicable	Circulation or storage space.
NS 120 15108 - NS 120 15108 - Learning Unit Primary Single - PWD - (76 SQM)	● Student Space (35)	
NS 200 13178 - NS 200 13178 - Art Learning Space/Workshop/Bulk Store - (95 SQM)	Not Applicable	Circulation or storage space.
NS 220 13191 - NS 220 13191 - Science Learning/Preparation Space - (95 SQM)	Not Applicable	Circulation or storage space.
OS 522 18178 - OS 522 18178 - Staff Study - (38 SQM)	● Office (9)	
OS 601 11322 - OS 601 11322 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 14297 - OS 601 14297 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 19455 - OS 601 19455 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 19460 - OS 601 19460 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 19877 - OS 601 19877 - Learning Unit - Standard/Withdrawal - (SQM)	● Student Space ()	