

VENTILATION AUDIT REPORT

SCHOOL:	Kincumber Public School (2304)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Terrigal
LOCAL GOVERNMENT AREA:	Central Coast

2304 - Kincumber Public School
Site Plan (12582)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (57.02 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0005 - Staff Room Annexe - (14.78 SQM)	● Office (3)	
B00A - R0006 - Staff Room Annexe - (13.18 SQM)	● Office (3)	
B00A - R0007 - Movement - (22.81 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Staff Kitchen - (10.31 SQM)	● Office (2)	
B00B - R0003 - Staff Room - (56.2 SQM)	● Office (14)	
B00B - R0006 - Staff Room Annexe - (15.65 SQM)	● Office (3)	
B00B - R0007 - Staff Room Annexe - (24.4 SQM)	● Office (6)	
B00C - R0001 - Practical Activities - 1hb - (18.97 SQM)	● Student Space (8)	
B00C - R0002 - Home Base - (50.35 SQM) - Teaching Space: 1	● Student Space (23)	
B00C - R0003 - Home Base - (50.82 SQM) - Teaching Space: 1	● Student Space (23)	
B00C - R0004 - Practical Activities - 1hb - (19.21 SQM)	● Student Space (8)	
B00C - R0005 - Movement - (35.11 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Practical Activities - 1hb - (13.37 SQM)	● Student Space (6)	
B00D - R0002 - Home Base - (56.03 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R0003 - Home Base - (56.2 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0004 - Practical Activities - 1hb - (13.37 SQM)	● Student Space (6)	
B00D - R0005 - Movement - (31.5 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Movement - (44.35 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - Practical Activities - 1hb - (18.89 SQM)	● Student Space (8)	
B00D - R1002 - Home Base - (50.35 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R1003 - Home Base - (50.43 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R1004 - Practical Activities - 1hb - (18.97 SQM)	● Student Space (8)	
B00D - R1005 - Movement - (45.38 SQM)	Not Applicable	Circulation or storage space.
B00E - R0006 - Home Base - (61.52 SQM) - Teaching Space: 1	● Student Space (28)	
B00E - R0007 - Withdrawal Space - 1hb - (8.45 SQM)	● Student Space (3)	
B00E - R0008 - Movement - (47.11 SQM)	Not Applicable	Circulation or storage space.
B00E - R0009 - Practical Activities - 1hb - (54.46 SQM)	● Student Space (25)	
B00E - R0012 - Movement - (8.18 SQM)	Not Applicable	Circulation or storage space.
B00E - R0013 - Home Base - (60.29 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R0015 - Withdrawal Space - 1hb - (8.37 SQM)	● Student Space (3)	
B00E - R0016 - Home Base - (60.22 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0003 - Special Programs Room - (40.22 SQM)	● Student Space (18)	
B00F - R0007 - Movement - (10.01 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Movement - (43.43 SQM)	Not Applicable	Circulation or storage space.
B00F - R0010 - Special Programs Room - (44.97 SQM)	● Student Space (20)	
B00F - R0012 - Reading Area - (182.98 SQM)	● Student Space (84)	
B00G - R0001 - Deputy Principal - (12.82 SQM)	● Office (3)	
B00G - R0003 - Principal - (18.28 SQM)	● Office (4)	
B00G - R0005 - Sick Bay - (8.7 SQM)	● Student Space (4)	
B00G - R0007 - Duplicating Workroom - (33.38 SQM)	● Office (8)	
B00G - R0008 - Clerical Office - (12.55 SQM)	● Office (3)	
B00G - R0009 - Entry Vestibule - (10.7 SQM)	Not Applicable	Circulation or storage space.
B00G - R0010 - Movement - (8.38 SQM)	Not Applicable	Circulation or storage space.
B00G - R0011 - Clerical Office/Workroom - (12.66 SQM)	● Office (3)	
B00G - R0015 - Deputy Principal - (12.66 SQM)	● Office (3)	
B00G - R0016 - Movement - (35.2 SQM)	Not Applicable	Circulation or storage space.
B00H - R0003 - Movement - (7.59 SQM)	Not Applicable	Circulation or storage space.
B00H - R0007 - Movement - (7.88 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0009 - Movement - (18.63 SQM)	Not Applicable	Circulation or storage space.
B00H - R0010 - Movement - (15.89 SQM)	Not Applicable	Circulation or storage space.
B00H - R0012 - Movement - (26.73 SQM)	Not Applicable	Circulation or storage space.
B00H - R0015 - Movement - (12.35 SQM)	Not Applicable	Circulation or storage space.
B00H - R0017 - Movement - (13.67 SQM)	Not Applicable	Circulation or storage space.
B00H - R0024 - Movement - (17.03 SQM)	Not Applicable	Circulation or storage space.
B00H - R0027 - Communal Space - (200.24 SQM)	● Student Space (92)	
B00H - R0028 - Raised Platform - (48.3 SQM)	Not Applicable	Circulation or storage space.
B00H - R0032 - Canteen - (49.08 SQM)	Not Applicable	Circulation or storage space.
B00H - R0033 - Movement - (195.1 SQM)	Not Applicable	Circulation or storage space.
B00I - R0004 - Movement - (15.57 SQM)	Not Applicable	Circulation or storage space.
B00J - R0005 - Withdrawal Space - 1hb - (5.38 SQM)	● Student Space (2)	
B00J - R0006 - Movement - (5.04 SQM)	Not Applicable	Circulation or storage space.
B00J - R0007 - Home Base - (57.59 SQM) - Teaching Space: 1	● Student Space (26)	
B00J - R0008 - Practical Activities - 1hb - (21.41 SQM)	● Student Space (9)	
B00J - R0009 - Practical Activities - 1hb - (21.42 SQM)	● Student Space (9)	
B00J - R0010 - Home Base - (57.6 SQM) - Teaching Space: 1	● Student Space (26)	
B00J - R0012 - Withdrawal Space - 1hb - (11.13 SQM)	● Student Space (5)	
B00J - R0016 - Practical Activities - 1hb - (21.42 SQM)	● Student Space (9)	
B00J - R0017 - Home Base - (57.6 SQM) - Teaching Space: 1	● Student Space (26)	
B00J - R0018 - Practical Activities - 1hb - (21.42 SQM)	● Student Space (9)	
B00J - R0019 - Home Base - (57.6 SQM) - Teaching Space: 1	● Student Space (26)	
B00J - R0020 - Movement - (6.18 SQM)	Not Applicable	Circulation or storage space.
B00J - R0021 - Withdrawal Space - 1hb - (5.45 SQM)	● Student Space (2)	
B00J - R0025 - Movement - (198.86 SQM)	Not Applicable	Circulation or storage space.
B00K - R0003 - Movement - (15.41 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Movement - (29.21 SQM)	Not Applicable	Circulation or storage space.
B00L - R0005 - Movement - (47.97 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - Practical Activities - 1hb - (14.25 SQM)	● Student Space (6)	
B00M - R0004 - Home Base - (60.41 SQM) - Teaching Space: 1	● Student Space (28)	
B00M - R0005 - Withdrawal Space - 2hb - (11.71 SQM)	● Student Space (5)	
B00M - R0006 - Practical Activities - 1hb - (14.21 SQM)	● Student Space (6)	
B00M - R0009 - Home Base - (60.41 SQM) - Teaching Space: 1	● Student Space (28)	
B00M - R0010 - Practical Activities - 1hb - (15.51 SQM)	● Student Space (7)	
B00M - R0013 - Withdrawal Space - 1hb - (9.28 SQM)	● Student Space (4)	
B00M - R0014 - Home Base - (58.71 SQM) - Teaching Space: 1	● Student Space (27)	
B00M - R0015 - Movement - (6.92 SQM)	Not Applicable	Circulation or storage space.
B00M - R0017 - Special Programs Room - (42.36 SQM)	● Student Space (19)	
B00M - R1001 - Practical Activities - 1hb - (14.17 SQM)	● Student Space (6)	
B00M - R1004 - Home Base - (60.17 SQM) - Teaching Space: 1	● Student Space (27)	
B00M - R1005 - Withdrawal Space - 2hb - (11.54 SQM)	● Student Space (5)	
B00M - R1006 - Practical Activities - 1hb - (14.17 SQM)	● Student Space (6)	
B00M - R1009 - Home Base - (60.17 SQM) - Teaching Space: 1	● Student Space (27)	
B00M - R1010 - Practical Activities - 1hb - (17.33 SQM)	● Student Space (8)	
B00M - R1012 - Withdrawal Space - 1hb - (9.14 SQM)	● Student Space (4)	
B00M - R1014 - Home Base - (58.06 SQM) - Teaching Space: 1	● Student Space (26)	