

VENTILATION AUDIT REPORT

SCHOOL:	Kings Langley Public School (4528)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Seven Hills
LOCAL GOVERNMENT AREA:	Blacktown

4528 - Kings Langley Public School
Site Plan (10458)



1:957

Printed: 25-Nov-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0003 - Special Programs Room - (42.93 SQM)	● Student Space (19)	
B001 - R0006 - Withdrawal Space - 1hb - (8.37 SQM)	● Student Space (3)	
B001 - R0007 - Home Base - (60.92 SQM) - Teaching Space: 1	● Student Space (28)	
B001 - R0012 - Home Base - (60.61 SQM) - Teaching Space: 1	● Student Space (28)	
B001 - R0013 - Withdrawal Space - 1hb - (8.73 SQM)	● Student Space (4)	
B001 - R0014 - Movement - (19.78 SQM)	Not Applicable	Circulation or storage space.
B001 - R0015 - Home Base - (60.66 SQM) - Teaching Space: 1	● Student Space (28)	
B001 - R0018 - Practical Activities - 1hb - (35.16 SQM)	● Student Space (16)	
B001 - R0020 - Practical Activities - 1hb - (22.56 SQM)	● Student Space (10)	
B002 - R0002 - Home Base - (60.77 SQM) - Teaching Space: 1	● Student Space (28)	
B002 - R0005 - Practical Activities - 1hb - (34.54 SQM)	● Student Space (16)	
B002 - R0007 - Practical Activities - 1hb - (35.27 SQM)	● Student Space (16)	
B002 - R0010 - Home Base - (60.84 SQM) - Teaching Space: 1	● Student Space (28)	
B002 - R0012 - Withdrawal Space - 1hb - (11.97 SQM)	● Student Space (5)	
B002 - R0013 - Home Base - (60.75 SQM) - Teaching Space: 1	● Student Space (28)	
B002 - R0019 - Home Base - (60.77 SQM) - Teaching Space: 1	● Student Space (28)	
B002 - R0020 - Withdrawal Space - 1hb - (11.97 SQM)	● Student Space (5)	
B003 - R0002 - Home Base - (60.75 SQM) - Teaching Space: 1	● Student Space (28)	
B003 - R0005 - Practical Activities - 1hb - (35.63 SQM)	● Student Space (16)	
B003 - R0011 - Home Base - (60.91 SQM) - Teaching Space: 1	● Student Space (28)	
B003 - R0013 - Withdrawal Space - 1hb - (11.95 SQM)	● Student Space (5)	
B003 - R0014 - Home Base - (60.68 SQM) - Teaching Space: 1	● Student Space (28)	
B003 - R0019 - Home Base - (60.67 SQM) - Teaching Space: 1	● Student Space (28)	
B003 - R0020 - Withdrawal Space - 1hb - (11.98 SQM)	● Student Space (5)	
B004 - R0003 - Home Base - (60.85 SQM) - Teaching Space: 1	● Student Space (28)	
B004 - R0004 - Movement - (19.9 SQM)	Not Applicable	Circulation or storage space.
B004 - R0005 - Withdrawal Space - 1hb - (8.82 SQM)	● Student Space (4)	
B004 - R0006 - Home Base - (60.63 SQM) - Teaching Space: 1	● Student Space (28)	
B004 - R0009 - Home Base - (60.76 SQM) - Teaching Space: 1	● Student Space (28)	
B004 - R0010 - Withdrawal Space - 1hb - (7.88 SQM)	● Student Space (3)	
B004 - R0017 - Practical Activities - 1hb - (22.55 SQM)	● Student Space (10)	
B004 - R0022 - Practical Activities - 1hb - (35.22 SQM)	● Student Space (16)	
B005 - R0001 - Reading Area - (192.04 SQM)	● Student Space (89)	
B005 - R0007 - Reading Area - (33.4 SQM)	● Student Space (15)	
B006 - R0001 - Staff Room Annexe - (28.07 SQM)	● Office (7)	
B006 - R0002 - Staff Room - (58.58 SQM)	● Office (14)	
B006 - R0004 - Duplicating Workroom - (32.96 SQM)	● Office (8)	
B006 - R0006 - Staff Room Annexe - (12.88 SQM)	● Office (3)	
B006 - R0007 - Entry Vestibule - (20.12 SQM)	Not Applicable	Circulation or storage space.
B006 - R0009 - Staff Room Annexe - (12.91 SQM)	● Office (3)	
B006 - R0010 - Sick Bay - (8.94 SQM)	● Student Space (4)	
B006 - R0012 - Principal - (17.15 SQM)	● Office (4)	
B006 - R0013 - Clerical Office/Workroom - (13.05 SQM)	● Office (3)	
B006 - R0017 - Movement - (43.32 SQM)	Not Applicable	Circulation or storage space.
B006 - R0018 - Clerical Office - (13.69 SQM)	● Office (3)	
B007 - R0004 - Entry Vestibule - (5.11 SQM)	Not Applicable	Circulation or storage space.
B007 - R0006 - Communal Space - (199.5 SQM)	● Student Space (92)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B007 - R0009 - Raised Platform - (54.83 SQM)	Not Applicable	Circulation or storage space.
B007 - R0019 - Canteen - (43.96 SQM)	Not Applicable	Circulation or storage space.
B010 - R0002 - Practical Activities - 1hb - (19.39 SQM)	● Student Space (8)	
B010 - R0004 - Home Base - (59.2 SQM) - Teaching Space: 1	● Student Space (27)	
B010 - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	● Student Space (5)	
B010 - R0006 - Home Base - (59.19 SQM) - Teaching Space: 1	● Student Space (27)	
B010 - R0008 - Practical Activities - 1hb - (19.41 SQM)	● Student Space (9)	
B011 - R0001 - Special Programs Room - (62.05 SQM)	● Student Space (28)	
B012 - R0003 - Home Base - (59.39 SQM) - Teaching Space: 1	● Student Space (27)	
B012 - R0004 - Withdrawal Space - 2hb - (11.26 SQM)	● Student Space (5)	
B012 - R0005 - Home Base - (59.58 SQM) - Teaching Space: 1	● Student Space (27)	
B012 - R0008 - Home Base - (59.42 SQM) - Teaching Space: 1	● Student Space (27)	
B012 - R0009 - Withdrawal Space - 2hb - (11.29 SQM)	● Student Space (5)	
B012 - R0010 - Home Base - (59.45 SQM) - Teaching Space: 1	● Student Space (27)	
B012 - R0012 - Practical Activities - 1hb - (18.65 SQM)	● Student Space (8)	
B012 - R0013 - Practical Activities - 1hb - (18.63 SQM)	● Student Space (8)	
B012 - R0014 - Practical Activities - 1hb - (18.63 SQM)	● Student Space (8)	
B012 - R0015 - Practical Activities - 1hb - (18.43 SQM)	● Student Space (8)	
B013 - R0003 - Home Base - (59.61 SQM) - Teaching Space: 1	● Student Space (27)	
B013 - R0004 - Withdrawal Space - 2hb - (11.36 SQM)	● Student Space (5)	
B013 - R0005 - Home Base - (59.66 SQM) - Teaching Space: 1	● Student Space (27)	
B013 - R0007 - Practical Activities - 1hb - (18.6 SQM)	● Student Space (8)	
B013 - R0008 - Practical Activities - 1hb - (18.65 SQM)	● Student Space (8)	
B014 - R0002 - Movement - (19.58 SQM)	Not Applicable	Circulation or storage space.
B014 - R0005 - Practical Activities - Pre - (105.72 SQM)	● Student Space (49)	
B014 - R0008 - Practical Activities - Pre - (51.07 SQM)	● Student Space (23)	
B014 - R0015 - Practical Activities - Pre - (53.97 SQM)	● Student Space (25)	
B014 - R0018 - Practical Activities - Pre - (53.21 SQM)	● Student Space (24)	
B014 - R0020 - Child Care Centre - (8.44 SQM)	● Student Space (3)	
OS 602 10311 - OS 602 10311 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 10666 - OS 602 10666 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 13547 - OS 602 13547 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 14322 - OS 602 14322 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 14328 - OS 602 14328 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 750 11879 - OS 750 11879 - Learning Unit - ESL - (38 SQM)	● Student Space (17)	