


# VENTILATION AUDIT REPORT

SCHOOL:	Kingsgrove High School (8247)
AMU REGION:	Sydney
STATE ELECTORATE:	Kogarah
LOCAL GOVERNMENT AREA:	Georges River

8247 - Kingsgrove High School  
Site Plan (12585)



1:1,096

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Computer Learning Space - (37.42 SQM) - Teaching Space: 1	Student Space (17)	
B00A - R0002 - Computer Learning Space - (35.82 SQM) - Teaching Space: 1	Student Space (16)	
B00A - R0003 - Laboratory L.S. - (91.33 SQM) - Teaching Space: 1	Student Space (42)	
B00A - R0004 - Preparation - (30.16 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Tiered Learning Area - (51.98 SQM)	Student Space (24)	
B00A - R0011 - Movement - (137.85 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Staff Kitchen - (11.22 SQM)	Office (2)	
B00A - R0016 - General Learning Space - (41.12 SQM) - Teaching Space: 1	Student Space (19)	
B00A - R0018 - Interview/Office - Type 1 - (8.28 SQM)	Office (2)	
B00A - R0019 - Principal Office - (14.43 SQM)	Office (3)	
B00A - R0022 - Movement - (12.73 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Movement - (18.82 SQM)	Not Applicable	Circulation or storage space.
B00A - R0028 - Deputy Principal Office - (14.3 SQM)	Office (3)	
B00A - R0029 - Duplicating Workroom - (7.56 SQM)	Office (1)	
B00A - R0030 - Administration - Clerical - (6.93 SQM)	Office (1)	
B00A - R0031 - Administration - Clerical - (10.01 SQM)	Office (2)	
B00A - R0032 - Administration - Clerical - (65.56 SQM)	Office (16)	
B00A - R0034 - Movement - (20.11 SQM)	Not Applicable	Circulation or storage space.
B00A - R0037 - Duplicating Workroom - (16.42 SQM)	Office (4)	
B00A - R0038 - Pupil Entry - (11.82 SQM)	Not Applicable	Circulation or storage space.
B00A - R0039 - Movement - (77.5 SQM)	Not Applicable	Circulation or storage space.
B00A - R0040 - Clinic - Boys - (13.61 SQM)	Office (3)	
B00A - R0044 - Deputy Principal Office - (13.94 SQM)	Office (3)	
B00A - R0045 - Leading Teacher - (16.46 SQM)	Office (4)	
B00A - R0049 - Staff Study - (20.96 SQM)	Office (5)	
B00A - R0051 - Preparation - (19.72 SQM)	Not Applicable	Circulation or storage space.
B00A - R0053 - Laboratory L.S. - (88.33 SQM) - Teaching Space: 1	Student Space (40)	
B00A - R0060 - Commonroom - (40.18 SQM)	Office (10)	
B00A - R0061 - Staff Kitchen - (11.66 SQM)	Office (2)	
B00A - R0062 - Commonroom - (104.8 SQM)	Office (26)	
B00A - R0063 - Movement - (7.95 SQM)	Not Applicable	Circulation or storage space.
B00A - R0065 - Movement - (12.03 SQM)	Not Applicable	Circulation or storage space.
B00A - R0066 - Movement - (23.44 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - General Learning Space - (51.9 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1002 - General Learning Space - (65.73 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1007 - Art Learning Space - (64.95 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1008 - General Learning Space - (38.85 SQM) - Teaching Space: 1	Student Space (18)	
B00A - R1009 - Staff Study - (38.8 SQM)	Office (9)	
B00A - R1013 - General Learning Space - (64.87 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1014 - General Learning Space - (52.05 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1015 - General Learning Space - (51.77 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1016 - General Learning Space - (51.77 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1017 - General Learning Space - (52.05 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1020 - General Learning Space - (52.28 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1021 - General Learning Space - (51.91 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1022 - General Learning Space - (51.84 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1023 - General Learning Space - (51.98 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1024 - General Learning Space - (65.27 SQM) - Teaching Space: 1	Student Space (30)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R1026 - Staff Study - (16.15 SQM)	Office (4)	
B00A - R1029 - General Learning Space - (49.96 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1030 - General Learning Space - (51.91 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1032 - General Learning Space - (51.26 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1033 - Movement - (201.06 SQM)	Not Applicable	Circulation or storage space.
B00A - R1038 - Movement - (14.31 SQM)	Not Applicable	Circulation or storage space.
B00A - R1042 - Commonroom - (12.4 SQM)	Office (3)	
B00A - R9001 - Student Canteen - (39.98 SQM)	Not Applicable	Circulation or storage space.
B00A - R9005 - General Assistants - (12.1 SQM)	Office (3)	
B00A - R9007 - Movement - (156.06 SQM)	Not Applicable	Circulation or storage space.
B00A - R9012 - Movement - (12.78 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Music Learning Space - (64.46 SQM) - Teaching Space: 1	Student Space (29)	
B00B - R0005 - Computer Learning Space - (51.91 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0007 - General Learning Space - (52.06 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0015 - Food Technology L.S. - (65.05 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R0020 - Movement - (137.67 SQM)	Not Applicable	Circulation or storage space.
B00B - R0029 - Preparation - (24.65 SQM)	Not Applicable	Circulation or storage space.
B00B - R0030 - Food Technology L.S. - (90.65 SQM) - Teaching Space: 1	Student Space (42)	
B00B - R0032 - Commonroom - (45.36 SQM)	Office (11)	
B00B - R1001 - General Learning Space - (69.35 SQM) - Teaching Space: 1	Student Space (32)	
B00B - R1004 - Design L.S. - (69.55 SQM) - Teaching Space: 1	Student Space (32)	
B00B - R1008 - Design L.S. - (69.78 SQM) - Teaching Space: 1	Student Space (32)	
B00B - R1012 - Art Learning Space - (55.51 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R1013 - Art Learning Space - (56.29 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R1014 - Staff Study - (27.71 SQM)	Office (6)	
B00B - R1015 - Darkroom Space - (11.55 SQM)	Office (2)	
B00B - R1017 - Art Learning Space - (55.73 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R1019 - Movement - (131.03 SQM)	Not Applicable	Circulation or storage space.
B00B - R1023 - Commonroom - (16.38 SQM)	Office (4)	
B00B - R9003 - Movement - (13.1 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Materials Technology L.S. - (78.45 SQM) - Teaching Space: 1	Student Space (36)	
B00C - R0007 - Movement - (6.07 SQM)	Not Applicable	Circulation or storage space.
B00C - R0012 - Materials Technology L.S. - (71.81 SQM) - Teaching Space: 1	Student Space (33)	
B00C - R0022 - Commonroom - (14.19 SQM)	Office (3)	
B00C - R0026 - Materials Technology L.S. - (149.04 SQM) - Teaching Space: 1	Student Space (69)	
B00C - R0027 - Movement - (8.26 SQM)	Not Applicable	Circulation or storage space.
B00C - R0028 - Seminar - Type 2 - (21.17 SQM)	Office (5)	
B00C - R0029 - Metal Technology Bay - (10.52 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Laboratory L.S. - (86.29 SQM) - Teaching Space: 1	Student Space (40)	
B00D - R0002 - Preparation - (28.25 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Staff Study - (9.39 SQM)	Office (2)	
B00D - R0004 - Laboratory L.S. - (86.22 SQM) - Teaching Space: 1	Student Space (40)	
B00D - R0005 - General Learning Space - (52.48 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0006 - Staff Study - (26.06 SQM)	Office (6)	
B00D - R0007 - General Learning Space - (52.63 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0008 - General Learning Space - (52.56 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0012 - General Learning Space - (52.41 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0016 - Movement - (152.89 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0024 - General Learning Space - (53.17 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0025 - Commonroom - (39.18 SQM)	● Office (9)	
B00D - R0026 - Staff Study - (17.12 SQM)	● Office (4)	
B00D - R0027 - Staff Kitchen - (8.68 SQM)	● Office (2)	
B00D - R1002 - General Learning Space - (52.56 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1003 - Preparation - (23.74 SQM)	Not Applicable	Circulation or storage space.
B00D - R1005 - Laboratory L.S. - (86.21 SQM) - Teaching Space: 1	● Student Space (39)	
B00D - R1008 - General Learning Space - (66.28 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R1010 - General Learning Space - (61.15 SQM) - Teaching Space: 1	● Student Space (28)	
B00D - R1011 - General Learning Space - (52.56 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1012 - Staff Study - (12.6 SQM)	● Office (3)	
B00D - R1016 - General Learning Space - (52.56 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1018 - General Learning Space - (52.92 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1019 - Movement - (146.39 SQM)	Not Applicable	Circulation or storage space.
B00D - R1025 - Commonroom - (36.14 SQM)	● Office (9)	
B00D - R9014 - Movement - (39.89 SQM)	Not Applicable	Circulation or storage space.
B00D - R9015 - Movement - (18.04 SQM)	Not Applicable	Circulation or storage space.
B00E - R0009 - Audio Visual Workroom - (49.21 SQM)	● Student Space (22)	
B00E - R0012 - Movement - (49.46 SQM)	Not Applicable	Circulation or storage space.
B00E - R0016 - Main Area - (207.83 SQM)	Not Applicable	Circulation or storage space.
B00E - R0017 - Tiered Learning Area - (8.66 SQM)	● Student Space (4)	
B00E - R0018 - Senior Study - (13.64 SQM)	● Office (3)	
B00E - R1003 - Seminar - (16.12 SQM)	● Office (4)	
B00E - R1004 - Seminar - (16.52 SQM)	● Office (4)	
B00E - R1005 - Seminar - (16.44 SQM)	● Office (4)	
B00E - R1006 - Interview/Office - Type 1 - (16.6 SQM)	● Office (4)	
B00E - R1007 - Seminar - (16.28 SQM)	● Office (4)	
B00E - R1011 - Main Area - (239.11 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Stage - (96.19 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Multi-Purpose Space - (454.35 SQM)	● Student Space (210)	
B00F - R0006 - Public Entry - (17.71 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Student Canteen - (17.23 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Movement - (5.03 SQM)	Not Applicable	Circulation or storage space.
B00H - R1001 - Movement - (5.03 SQM)	Not Applicable	Circulation or storage space.
B00H - R9001 - Movement - (5.39 SQM)	Not Applicable	Circulation or storage space.