

VENTILATION AUDIT REPORT

SCHOOL:	Kingswood High School (8458)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Penrith
LOCAL GOVERNMENT AREA:	Penrith

8458 - Kingswood High School
Site Plan (12403)



1:1,795

Printed: 30-Jan-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Administration - Clerical - (28.51 SQM)	Office (7)	
B00A - R0003 - Administration - Clerical - (13.4 SQM)	Office (3)	
B00A - R0004 - Principal Office - (16.38 SQM)	Office (4)	
B00A - R0007 - Interview/Office - Type 1 - (13.69 SQM)	Office (3)	
B00A - R0009 - Administration - Clerical - (12.59 SQM)	Office (3)	
B00A - R0011 - Deputy Principal Office - (16.59 SQM)	Office (4)	
B00A - R0015 - Clinic - Boys - (13.58 SQM)	Office (3)	
B00A - R0016 - Clinic - Boys - (6.77 SQM)	Office (1)	
B00A - R0017 - Duplicating Workroom - (6.83 SQM)	Office (1)	
B00A - R0018 - Interview/Office - Type 1 - (14 SQM)	Office (3)	
B00A - R0022 - Administration - Clerical - (11.48 SQM)	Office (2)	
B00A - R0023 - Movement - (104.42 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Food Technology L.S. - (84.19 SQM) - Teaching Space: 1	Student Space (39)	
B00D - R0002 - Food/Research Space - (15.54 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Food Technology L.S. - (83.72 SQM) - Teaching Space: 1	Student Space (38)	
B00D - R0009 - Commonroom - (66.44 SQM)	Office (16)	
B00D - R0010 - Commonroom - (7.01 SQM)	Office (1)	
B00D - R0012 - Staff Study - (30.67 SQM)	Office (7)	
B00D - R0017 - Movement - (85.64 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - Art Learning Space - (66.58 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R1003 - Art Learning Space - (66.58 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R1006 - Design L.S. - (66.76 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R1009 - Design L.S. - (67.16 SQM) - Teaching Space: 1	Student Space (31)	
B00D - R1010 - Staff Study - (32.03 SQM)	Office (8)	
B00D - R1011 - Music Learning Space - (66.25 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R1012 - Music Learning Space - (66.8 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R1013 - Movement - (63.64 SQM)	Not Applicable	Circulation or storage space.
B00M - R0009 - Art Learning Space - (64.63 SQM) - Teaching Space: 1	Student Space (29)	
B00M - R0013 - Movement - (26.38 SQM)	Not Applicable	Circulation or storage space.
B00M - R0014 - Metal Technology Bay - (106.13 SQM)	Not Applicable	Circulation or storage space.
B00M - R0015 - Welding/Hot Metals Area - (5.33 SQM)	Not Applicable	Circulation or storage space.
B00M - R0016 - Welding/Hot Metals Area - (5.45 SQM)	Not Applicable	Circulation or storage space.
B00M - R1001 - Wood Technology Bay - (83.53 SQM)	Not Applicable	Circulation or storage space.
B00M - R1005 - Materials Technology L.S. - (83.63 SQM) - Teaching Space: 1	Student Space (38)	
B00M - R1008 - Design L.S. - (53.87 SQM) - Teaching Space: 1	Student Space (24)	
B00M - R1009 - Staff Study - (25.94 SQM)	Office (6)	
B00M - R1010 - General Learning Space - (53.49 SQM) - Teaching Space: 1	Student Space (24)	
B00M - R1013 - Movement - (57.23 SQM)	Not Applicable	Circulation or storage space.
B00S - R0001 - Darkroom Space - (19.26 SQM)	Office (4)	
B00S - R0008 - Movement - (79.73 SQM)	Not Applicable	Circulation or storage space.
B00S - R0009 - Student Canteen - (50.23 SQM)	Not Applicable	Circulation or storage space.
B00S - R0015 - Multi-Purpose Space - (309.07 SQM)	Student Space (143)	
B00S - R1009 - Movement - (70.71 SQM)	Not Applicable	Circulation or storage space.
B00T - R0001 - Materials Technology L.S. - (233.36 SQM) - Teaching Space: 1	Student Space (108)	
B00T - R0009 - Computer Room - (40.02 SQM)	Student Space (18)	
B00T - R0012 - Staff Study - (14.47 SQM)	Office (3)	
B00V - R0001 - Multi-Purpose Space - (1130.49 SQM)	Student Space (524)	
B00V - R0011 - Stage - (96.99 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00V - R0012 - Movement - (19.27 SQM)	Not Applicable	Circulation or storage space.
B00V - R0013 - Movement - (14.28 SQM)	Not Applicable	Circulation or storage space.
B00V - R0017 - Movement - (5.78 SQM)	Not Applicable	Circulation or storage space.
B00V - R0025 - Movement - (13.94 SQM)	Not Applicable	Circulation or storage space.
BOAG - R0002 - General Assistants - (12.69 SQM)	Office (3)	
BOC1 - R0001 - General Learning Space - (53.65 SQM) - Teaching Space: 1	Student Space (24)	
BOC1 - R0002 - General Learning Space - (53.07 SQM) - Teaching Space: 1	Student Space (24)	
BOC1 - R0004 - General Learning Space - (53.07 SQM) - Teaching Space: 1	Student Space (24)	
BOC1 - R0005 - Staff Study - (25.91 SQM)	Office (6)	
BOC1 - R0006 - General Learning Space - (53.65 SQM) - Teaching Space: 1	Student Space (24)	
BOC1 - R0007 - General Learning Space - (53.58 SQM) - Teaching Space: 1	Student Space (24)	
BOC1 - R0009 - Staff Study - (50.79 SQM)	Office (12)	
BOC1 - R0011 - Interview/Office - Type 1 - (10.92 SQM)	Office (2)	
BOC1 - R0018 - Movement - (85.31 SQM)	Not Applicable	Circulation or storage space.
BOC1 - R1001 - Staff Study - (39.67 SQM)	Office (9)	
BOC1 - R1002 - Interview/Office - Type 1 - (10.8 SQM)	Office (2)	
BOC1 - R1005 - Movement - (28.35 SQM)	Not Applicable	Circulation or storage space.
BOC1 - R1007 - General Learning Space - (53.73 SQM) - Teaching Space: 1	Student Space (24)	
BOC1 - R1009 - General Learning Space - (53.51 SQM) - Teaching Space: 1	Student Space (24)	
BOC1 - R1010 - General Learning Space - (53.51 SQM) - Teaching Space: 1	Student Space (24)	
BOC1 - R1011 - General Learning Space - (53.51 SQM) - Teaching Space: 1	Student Space (24)	
BOC1 - R1012 - General Learning Space - (53.51 SQM) - Teaching Space: 1	Student Space (24)	
BOC1 - R1013 - Staff Study - (19 SQM)	Office (4)	
BOC1 - R1014 - General Learning Space - (53.5 SQM) - Teaching Space: 1	Student Space (24)	
BOC1 - R1015 - General Learning Space - (53.5 SQM) - Teaching Space: 1	Student Space (24)	
BOC1 - R1016 - Movement - (17.63 SQM)	Not Applicable	Circulation or storage space.
BOC2 - R0001 - General Learning Space - (53.43 SQM) - Teaching Space: 1	Student Space (24)	
BOC2 - R0002 - General Learning Space - (52.85 SQM) - Teaching Space: 1	Student Space (24)	
BOC2 - R0003 - Duplicating Workroom - (39.38 SQM)	Office (9)	
BOC2 - R0004 - General Learning Space - (52.41 SQM) - Teaching Space: 1	Student Space (24)	
BOC2 - R0005 - General Learning Space - (53.58 SQM) - Teaching Space: 1	Student Space (24)	
BOC2 - R0006 - General Learning Space - (53.58 SQM) - Teaching Space: 1	Student Space (24)	
BOC2 - R0008 - General Learning Space - (49.98 SQM) - Teaching Space: 1	Student Space (23)	
BOC2 - R0010 - Staff Study - (11.12 SQM)	Office (2)	
BOC2 - R0017 - Movement - (85.51 SQM)	Not Applicable	Circulation or storage space.
BOC2 - R1001 - General Learning Space - (53.87 SQM) - Teaching Space: 1	Student Space (24)	
BOC2 - R1006 - Staff Study - (39.56 SQM)	Office (9)	
BOC2 - R1007 - Movement - (28.54 SQM)	Not Applicable	Circulation or storage space.
BOC2 - R1009 - General Learning Space - (53.06 SQM) - Teaching Space: 1	Student Space (24)	
BOC2 - R1010 - General Learning Space - (53.06 SQM) - Teaching Space: 1	Student Space (24)	
BOC2 - R1011 - General Learning Space - (53.21 SQM) - Teaching Space: 1	Student Space (24)	
BOC2 - R1012 - General Learning Space - (53.21 SQM) - Teaching Space: 1	Student Space (24)	
BOC2 - R1013 - Movement - (17.73 SQM)	Not Applicable	Circulation or storage space.
BOC2 - R1014 - Staff Study - (18.85 SQM)	Office (4)	
BOC2 - R1015 - Special Learning Space - (53.58 SQM) - Teaching Space: 1	Student Space (24)	
BOC2 - R1016 - Special Learning Space - (53.58 SQM) - Teaching Space: 1	Student Space (24)	
BOC3 - R0001 - Seminar - (12.41 SQM)	Office (3)	
BOC3 - R0002 - Seminar - (11.73 SQM)	Office (2)	

Entity Location	Audit Condition Classification (Capacity)	Comment
BOC3 - R0003 - Senior Study - (81.23 SQM)	Office (20)	
BOC3 - R0004 - Seminar - (17.73 SQM)	Office (4)	
BOC3 - R0005 - Seminar - (15.31 SQM)	Office (3)	
BOC3 - R0009 - Computer Room - (29.76 SQM)	Student Space (13)	
BOC3 - R0010 - Workroom - (45.61 SQM)	Office (11)	
BOC3 - R0021 - Movement - (17.72 SQM)	Not Applicable	Circulation or storage space.
BOC3 - R0022 - Computer Room - (51.84 SQM)	Student Space (24)	
BOC3 - R0023 - Computer Room - (35.98 SQM)	Student Space (16)	
BOC3 - R0024 - Entry - (25.97 SQM)	Not Applicable	Circulation or storage space.
BOC3 - R0025 - Main Area - (257.02 SQM)	Not Applicable	Circulation or storage space.
BOC3 - R0027 - General Assistants - (10.85 SQM)	Office (2)	
BOC3 - R0032 - Movement - (24.01 SQM)	Not Applicable	Circulation or storage space.
BOC3 - R0033 - Computer Room - (39.67 SQM)	Student Space (18)	
BOC3 - R0034 - Movement - (31.55 SQM)	Not Applicable	Circulation or storage space.
BOC3 - R1001 - General Learning Space - (53.72 SQM) - Teaching Space: 1	Student Space (24)	
BOC3 - R1002 - General Learning Space - (53.72 SQM) - Teaching Space: 1	Student Space (24)	
BOC3 - R1004 - Movement - (16.65 SQM)	Not Applicable	Circulation or storage space.
BOC3 - R1005 - General Learning Space - (68.02 SQM) - Teaching Space: 1	Student Space (31)	
BOC3 - R1006 - General Learning Space - (51 SQM) - Teaching Space: 1	Student Space (23)	
BOC3 - R1007 - General Learning Space - (54.53 SQM) - Teaching Space: 1	Student Space (25)	
BOC3 - R1010 - Staff Study - (40.11 SQM)	Office (10)	
BOC3 - R1013 - General Learning Space - (53.43 SQM) - Teaching Space: 1	Student Space (24)	
BOC3 - R1014 - General Learning Space - (53.5 SQM) - Teaching Space: 1	Student Space (24)	
BOC3 - R1015 - Movement - (19.66 SQM)	Not Applicable	Circulation or storage space.
BOL1 - R0001 - Laboratory L.S. - (91.84 SQM) - Teaching Space: 1	Student Space (42)	
BOL1 - R0002 - Preparation - (30.25 SQM)	Not Applicable	Circulation or storage space.
BOL1 - R0004 - Preparation - (13.72 SQM)	Not Applicable	Circulation or storage space.
BOL1 - R0006 - Laboratory L.S. - (92.03 SQM) - Teaching Space: 1	Student Space (42)	
BOL1 - R0009 - Movement - (67.05 SQM)	Not Applicable	Circulation or storage space.
BOL1 - R1001 - Laboratory L.S. - (91.46 SQM) - Teaching Space: 1	Student Space (42)	
BOL1 - R1004 - Darkroom Space - (13.71 SQM)	Office (3)	
BOL1 - R1006 - Performance Workspace - (91.72 SQM) - Teaching Space: 1	Student Space (42)	
BOL1 - R1009 - Movement - (62.88 SQM)	Not Applicable	Circulation or storage space.
BOL1 - R1010 - Staff Kitchen - (21.02 SQM)	Office (5)	
BOL2 - R0004 - Laboratory L.S. - (91.75 SQM) - Teaching Space: 1	Student Space (42)	
BOL2 - R0005 - Preparation - (30.53 SQM)	Not Applicable	Circulation or storage space.
BOL2 - R0008 - Preparation - (13.17 SQM)	Not Applicable	Circulation or storage space.
BOL2 - R0009 - Laboratory L.S. - (91.75 SQM) - Teaching Space: 1	Student Space (42)	
BOL2 - R0012 - Movement - (67.73 SQM)	Not Applicable	Circulation or storage space.
BOL2 - R1004 - Laboratory L.S. - (91.75 SQM) - Teaching Space: 1	Student Space (42)	
BOL2 - R1005 - Preparation - (30.53 SQM)	Not Applicable	Circulation or storage space.
BOL2 - R1009 - Laboratory L.S. - (91.75 SQM) - Teaching Space: 1	Student Space (42)	
BOL2 - R1012 - Movement - (63.53 SQM)	Not Applicable	Circulation or storage space.