

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Koonawarra Public School (4409)</b>
<b>AMU REGION:</b>	<b>Southern NSW</b>
<b>STATE ELECTORATE:</b>	<b>Shellharbour</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Wollongong</b>















4409 - Koonawarra Public School  
Site Plan (11103)



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0002 - Home Base - (57.75 SQM) - Teaching Space: 1	● Student Space (26)	
B001 - R0005 - Home Base - (57.52 SQM) - Teaching Space: 1	● Student Space (26)	
B001 - R0013 - Home Base - Pre - (116.37 SQM) - Teaching Space: 1	● Student Space (53)	
B002 - R0002 - Special Programs Room - (57.1 SQM)	● Student Space (26)	
B002 - R0004 - Practical Activities - 1hb - (56.8 SQM)	● Student Space (26)	
B002 - R0010 - Home Base - (56.88 SQM) - Teaching Space: 1	● Student Space (26)	
B002 - R0013 - Canteen - (56.87 SQM)	Not Applicable	Circulation or storage space.
B002 - R0016 - Movement - (6.3 SQM)	Not Applicable	Circulation or storage space.
B003 - R0002 - Home Base - (57.02 SQM) - Teaching Space: 1	● Student Space (26)	
B003 - R0009 - Home Base - (51.94 SQM) - Teaching Space: 1	● Student Space (24)	
B003 - R0011 - Withdrawal Space - 1hb - (5.08 SQM)	● Student Space (2)	
B003 - R0013 - Home Base - (57.02 SQM) - Teaching Space: 1	● Student Space (26)	
B003 - R0019 - Home Base - (51.66 SQM) - Teaching Space: 1	● Student Space (23)	
B003 - R0021 - Withdrawal Space - 1hb - (5.29 SQM)	● Student Space (2)	
B004 - R0002 - Home Base - (77.25 SQM) - Teaching Space: 1	● Student Space (35)	
B004 - R0005 - Withdrawal Space - 1hb - (8.94 SQM)	● Student Space (4)	
B004 - R0006 - Home Base - (76.48 SQM) - Teaching Space: 1	● Student Space (35)	
B004 - R0010 - Withdrawal Space - 1hb - (9.64 SQM)	● Student Space (4)	
B004 - R0011 - Home Base - (82.19 SQM) - Teaching Space: 1	● Student Space (38)	
B00A - R0002 - Movement - (5.53 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Clerical Office/Workroom - (110.14 SQM)	● Office (27)	
B00A - R0007 - Sick Bay - (22.4 SQM)	● Student Space (10)	
B00A - R0012 - Deputy Principal - (13.05 SQM)	● Office (3)	
B00A - R0016 - Staff Room Annexe - (7.68 SQM)	● Office (1)	
B00A - R0017 - Movement - (20.77 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Interview - (15.85 SQM)	● Office (3)	
B00A - R0027 - Staff Room - (63.61 SQM)	● Office (15)	
B00A - R0033 - Deputy Principal - (26.69 SQM)	● Office (6)	
B00A - R0037 - Entry Vestibule - (23.2 SQM)	Not Applicable	Circulation or storage space.
B00A - R0038 - Clerical Office - (33.65 SQM)	● Office (8)	
B00A - R0039 - Principal - (19.38 SQM)	● Office (4)	
B00B - R0001 - Home Base - (61.99 SQM) - Teaching Space: 1	● Student Space (28)	
B00B - R0002 - Home Base - (62.15 SQM) - Teaching Space: 1	● Student Space (28)	
B00B - R0003 - Home Base - (62.15 SQM) - Teaching Space: 1	● Student Space (28)	
B00B - R0004 - Home Base - (62.15 SQM) - Teaching Space: 1	● Student Space (28)	
B00B - R0007 - Seminar/Study - (18.02 SQM)	● Office (4)	
B00B - R0008 - Movement - (33.67 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Movement - (44.23 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Raised Platform - (38.81 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Movement - (9.37 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Communal Space - (132.36 SQM)	● Student Space (61)	
B00B - R0015 - Movement - (55.53 SQM)	Not Applicable	Circulation or storage space.
B00B - R0035 - Staff Kitchen - (5.43 SQM)	● Office (1)	
B00B - R0040 - Reading Area - (246.51 SQM)	● Student Space (114)	
B00B - R1001 - Home Base - (61.92 SQM) - Teaching Space: 1	● Student Space (28)	
B00B - R1003 - Staff Room Annexe - (18.44 SQM)	● Office (4)	
B00B - R1004 - Home Base - (62 SQM) - Teaching Space: 1	● Student Space (28)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R1005 - Home Base - (62 SQM) - Teaching Space: 1	 Student Space (28)	
B00B - R1007 - Home Base - (62 SQM) - Teaching Space: 1	 Student Space (28)	
B00B - R1010 - Home Base - (62.38 SQM) - Teaching Space: 1	 Student Space (28)	
B00B - R1011 - Home Base - (62.46 SQM) - Teaching Space: 1	 Student Space (28)	
B00B - R1012 - Home Base - (62.07 SQM) - Teaching Space: 1	 Student Space (28)	
B00B - R1013 - Home Base - (61.98 SQM) - Teaching Space: 1	 Student Space (28)	
B00B - R1016 - Home Base - (61.99 SQM) - Teaching Space: 1	 Student Space (28)	
B00B - R1017 - Home Base - (61.99 SQM) - Teaching Space: 1	 Student Space (28)	
B00B - R1020 - Home Base - (62.07 SQM) - Teaching Space: 1	 Student Space (28)	
B00B - R1021 - Home Base - (62.07 SQM) - Teaching Space: 1	 Student Space (28)	
B00B - R1025 - Movement - (211.43 SQM)	Not Applicable	Circulation or storage space.
B00D - M0009 - Withdrawal - Pre - (15.03 SQM)	 Student Space (6)	
B00D - R0002 - Staff Room - (24.73 SQM)	 Office (6)	
B00D - R0005 - Home Base - Pre - (61.82 SQM) - Teaching Space: 1	 Student Space (28)	
B00G - R0001 - Communal Space - (198.13 SQM)	 Student Space (91)	
B00G - R0002 - Raised Platform - (58.25 SQM)	Not Applicable	Circulation or storage space.
B00G - R0016 - Movement - (7.18 SQM)	Not Applicable	Circulation or storage space.
B00G - R0017 - Movement - (18.44 SQM)	Not Applicable	Circulation or storage space.