


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Kotara High School (8423)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Charlestown</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Newcastle</b>

8423 - Kotara High School  
Site Plan (11875)



1:1,443

Printed: 14-Aug-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - General Learning Space - (58.76 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0002 - Staff Study - (39.52 SQM)	Office (9)	
B00A - R0003 - Movement - (9.21 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Laboratory L.S. - (85.78 SQM) - Teaching Space: 1	Student Space (39)	
B00A - R0024 - Growing/Breeding - (8.94 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Preparation - (29.71 SQM)	Not Applicable	Circulation or storage space.
B00A - R0026 - Laboratory L.S. - (93.42 SQM) - Teaching Space: 1	Student Space (43)	
B00A - R0030 - General Learning Space - (53.11 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0038 - Movement - (170.46 SQM)	Not Applicable	Circulation or storage space.
B00A - R0039 - Administration - Clerical - (60.65 SQM)	Office (15)	
B00A - R0041 - General Learning Space - (52.24 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0042 - Staff Study - (26.01 SQM)	Office (6)	
B00A - R0043 - Staff Study - (15.45 SQM)	Office (3)	
B00A - R0044 - Staff Study - (15.13 SQM)	Office (3)	
B00A - R0045 - Computer Room - (31.05 SQM)	Student Space (14)	
B00A - R0046 - Movement - (33.17 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Textiles Technology L.S. - (78.56 SQM) - Teaching Space: 1	Student Space (36)	
B00A - R1003 - Computer Learning Space - (66.26 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1007 - Computer Learning Space - (58.76 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1010 - General Learning Space - (52.09 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1015 - General Learning Space - (52.81 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1016 - General Learning Space - (52.45 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1020 - General Learning Space - (52.81 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1023 - Movement - (170.23 SQM)	Not Applicable	Circulation or storage space.
B00A - R1026 - General Learning Space - (59.58 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1027 - Staff Kitchen - (15.46 SQM)	Office (3)	
B00A - R1028 - Staff Study - (15.37 SQM)	Office (3)	
B00A - R1029 - Staff Lounge - (79.45 SQM)	Office (19)	
B00A - R1030 - Interview/Meeting - (17.18 SQM)	Office (4)	
B00A - R1031 - Interview/Meeting - (8.3 SQM)	Office (2)	
B00B - R0001 - Food/Research Space - (22.22 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Food Technology L.S. - (79.63 SQM) - Teaching Space: 1	Student Space (36)	
B00B - R0007 - Food Technology L.S. - (65.98 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R0010 - General Learning Space - (52.08 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0014 - General Learning Space - (58.77 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0021 - General Learning Space - (52.96 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0036 - Outdoor Workshop - (82.8 SQM)	Not Applicable	Circulation or storage space.
B00B - R0037 - Movement - (243.17 SQM)	Not Applicable	Circulation or storage space.
B00B - R0038 - Staff Study - (59.48 SQM)	Office (14)	
B00B - R0039 - General Learning Space - (142.93 SQM) - Teaching Space: 1	Student Space (66)	
B00B - R0040 - General Learning Space - (75.6 SQM) - Teaching Space: 1	Student Space (35)	
B00B - R1001 - Art Learning Space - (72.01 SQM) - Teaching Space: 1	Student Space (33)	
B00B - R1004 - Art Learning Space - (53.04 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1005 - Art Learning Space - (52.83 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1008 - Staff Study - (45.2 SQM)	Office (11)	
B00B - R1011 - Music Learning Space - (52.53 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1015 - Workshop - (17.45 SQM)	Student Space (8)	
B00B - R1023 - Music Learning Space - (52.53 SQM) - Teaching Space: 1	Student Space (24)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R1026 - Movement - (185.5 SQM)	Not Applicable	Circulation or storage space.
B00B - R1029 - Materials Technology L.S. - (124.35 SQM) - Teaching Space: 1	● Student Space (57)	
B00B - R1030 - Welding Area - (7.55 SQM)	Not Applicable	Circulation or storage space.
B00B - R1032 - Design L.S. - (75.38 SQM) - Teaching Space: 1	● Student Space (34)	
B00B - R1035 - Practice/Seminar - (21.01 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Darkroom Space - (25.93 SQM)	● Office (6)	
B00C - R0003 - Staff Study - (39.38 SQM)	● Office (9)	
B00C - R0005 - Duplicating Workroom - (17.95 SQM)	● Office (4)	
B00C - R0006 - Laboratory L.S. - (93.08 SQM) - Teaching Space: 1	● Student Space (43)	
B00C - R0009 - General Learning Space - (53.03 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0013 - Laboratory L.S. - (85.42 SQM) - Teaching Space: 1	● Student Space (39)	
B00C - R0016 - Laboratory L.S. - (92.43 SQM) - Teaching Space: 1	● Student Space (42)	
B00C - R0017 - General Learning Space - (58 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0018 - General Learning Space - (52.83 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0021 - Movement - (217.43 SQM)	Not Applicable	Circulation or storage space.
B00C - R0024 - Preparation - (39.3 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - General Learning Space - (58.85 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R1003 - General Learning Space - (53.26 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1004 - Performance Workshop - (53.4 SQM)	● Student Space (24)	
B00C - R1005 - Stage - (24.73 SQM)	Not Applicable	Circulation or storage space.
B00C - R1011 - General Learning Space - (51.88 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1020 - General Learning Space - (53.19 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1021 - General Learning Space - (53.18 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1022 - General Learning Space - (58.76 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R1025 - General Learning Space - (52.82 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1028 - Movement - (189.04 SQM)	Not Applicable	Circulation or storage space.
B00C - R1031 - Staff Study - (45.78 SQM)	● Office (11)	
B00C - R1034 - General Learning Space - (58.39 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R1035 - Staff Study - (52.88 SQM)	● Office (13)	
B00D - R0001 - Seminar - (13.4 SQM)	● Office (3)	
B00D - R0002 - Seminar - (13.22 SQM)	● Office (3)	
B00D - R0003 - Main Area - (351.29 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Entry - (14.69 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Workroom - (30.12 SQM)	● Office (7)	
B00D - R0007 - Seminar - (13.29 SQM)	● Office (3)	
B00D - R0008 - Audio Visual Workroom - (25.35 SQM)	● Student Space (11)	
B00D - R0012 - Seminar - (30.8 SQM)	● Office (7)	
B00D - R0018 - Staff Study - (25.69 SQM)	● Office (6)	
B00D - R0019 - General Learning Space - (58.36 SQM)	● Student Space (27)	
B00D - R0020 - General Learning Space - (50.21 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R0024 - Movement - (190.59 SQM)	Not Applicable	Circulation or storage space.
B00D - R0027 - Special Learning Space - (47.54 SQM)	● Student Space (22)	
B00D - R0028 - Computer Room - (44.12 SQM)	● Student Space (20)	
B00D - R0029 - Outdoor Learning Area - (48.32 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - General Learning Space - (57.02 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R1002 - Staff Study - (25.58 SQM)	● Office (6)	
B00D - R1003 - General Learning Space - (52.24 SQM) - Teaching Space: 1	● Student Space (24)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R1004 - General Learning Space - (52.18 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1005 - General Learning Space - (57.96 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R1009 - General Learning Space - (50.94 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R1012 - Laboratory L.S. - (84.51 SQM) - Teaching Space: 1	● Student Space (39)	
B00D - R1013 - Preparation - (22.46 SQM)	Not Applicable	Circulation or storage space.
B00D - R1016 - Laboratory L.S. - (92.99 SQM) - Teaching Space: 1	● Student Space (43)	
B00D - R1021 - General Learning Space - (50.94 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R1024 - Movement - (177.55 SQM)	Not Applicable	Circulation or storage space.
B00D - R1027 - General Learning Space - (31.86 SQM) - Teaching Space: 1	● Student Space (14)	
B00E - R0006 - General Assistants - (22.05 SQM)	● Office (5)	
B00E - R0008 - Movement - (7.25 SQM)	Not Applicable	Circulation or storage space.
B00E - R0019 - Movement - (47.7 SQM)	Not Applicable	Circulation or storage space.
B00E - R0022 - Student Canteen - (25.83 SQM)	Not Applicable	Circulation or storage space.
B00E - R0024 - Student Canteen - (39.58 SQM)	Not Applicable	Circulation or storage space.
B00E - R0025 - Movement - (327.83 SQM)	Not Applicable	Circulation or storage space.
B00E - R0026 - Movement - (10.54 SQM)	Not Applicable	Circulation or storage space.
B00E - R0027 - Movement - (16.85 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - Movement - (12.44 SQM)	Not Applicable	Circulation or storage space.
B00E - R1014 - Movement - (12.5 SQM)	Not Applicable	Circulation or storage space.
B00F - M0002 - Movement - (5.38 SQM)	Not Applicable	Circulation or storage space.
B00F - M0003 - Movement - (5.34 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Student Canteen - (15.25 SQM)	Not Applicable	Circulation or storage space.
B00F - R0015 - Movement - (9.64 SQM)	Not Applicable	Circulation or storage space.
B00F - R0016 - Movement - (9.53 SQM)	Not Applicable	Circulation or storage space.
B00F - R0017 - Stage - (109.16 SQM)	Not Applicable	Circulation or storage space.
B00F - R0018 - Multi-Purpose Space - (600.56 SQM)	● Student Space (278)	
B00F - R0019 - Movement - (214.89 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Public Reception - (22.72 SQM)	Not Applicable	Circulation or storage space.
B00J - R0002 - Interview/Meeting - (17.89 SQM)	● Office (4)	
B00J - R0003 - Principal Office - (19.67 SQM)	● Office (4)	
B00J - R0004 - Deputy Principal Office - (12.23 SQM)	● Office (3)	
B00J - R0005 - Deputy Principal Office - (12.82 SQM)	● Office (3)	
B00J - R0006 - Interview/Meeting - (12.85 SQM)	● Office (3)	
B00J - R0007 - Movement - (58.67 SQM)	Not Applicable	Circulation or storage space.
B00J - R0011 - Administration - Clerical - (61.03 SQM)	● Office (15)	
B00J - R0012 - Student Reception - (26.42 SQM)	Not Applicable	Circulation or storage space.
B00J - R0013 - Interview/Meeting - (12.92 SQM)	● Office (3)	
B00J - R0014 - Administration - Executive - (12.36 SQM)	● Office (3)	
B00J - R0016 - Clinic - (12.3 SQM)	● Office (3)	
OS 601 10684 - OS 601 10684 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 12515 - OS 601 12515 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 13207 - OS 601 13207 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 13749 - OS 601 13749 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 13872 - OS 601 13872 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 760 11798 - OS 760 11798 - Woodwork/Store - (114 SQM)	Not Applicable	Circulation or storage space.