

VENTILATION AUDIT REPORT

SCHOOL:	Ku-ring-gai High School (8416)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Ku-Ring-Gai
LOCAL GOVERNMENT AREA:	Ku-Ring-Gai

8416 - Ku-ring-gai High School
Site Plan (11557)



1:1,749

Printed: 13-Jan-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Clinic - (8.97 SQM)	Office (2)	
B00A - R0003 - Art Learning Space - (86.2 SQM) - Teaching Space: 1	Student Space (39)	
B00A - R0004 - Interview/Meeting - (19.13 SQM)	Office (4)	
B00A - R0007 - General Learning Space - (59.1 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0009 - Public Reception - (59.09 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Administration - Clerical - (9.56 SQM)	Office (2)	
B00A - R0013 - Movement - (7.61 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Principal Office - (17.62 SQM)	Office (4)	
B00A - R0017 - Administration - Clerical - (52.27 SQM)	Office (13)	
B00A - R0018 - Staff Kitchen - (15.25 SQM)	Office (3)	
B00A - R0025 - Pupil Entry - (17.95 SQM)	Not Applicable	Circulation or storage space.
B00A - R0027 - Movement - (6.5 SQM)	Not Applicable	Circulation or storage space.
B00A - R0033 - Staff Study - (33.19 SQM)	Office (8)	
B00A - R1001 - Art Learning Space - (65.02 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1003 - General Learning Space - (59.32 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1004 - General Learning Space - (52.8 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1005 - General Learning Space - (52.87 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1006 - Computer Learning Space - (59.25 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1008 - General Learning Space - (40.37 SQM) - Teaching Space: 1	Student Space (18)	
B00A - R1009 - Staff Study - (38.61 SQM)	Office (9)	
B00A - R1010 - Interview/Meeting - (9.65 SQM)	Office (2)	
B00A - R1011 - Staff Lounge - (61.09 SQM)	Office (15)	
B00A - R1013 - Staff Kitchen - (18.26 SQM)	Office (4)	
B00A - R1014 - Deputy Principal Office - (19.25 SQM)	Office (4)	
B00A - R1017 - General Learning Space - (38.47 SQM) - Teaching Space: 1	Student Space (17)	
B00A - R1018 - General Learning Space - (45.78 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R1022 - Movement - (5.44 SQM)	Not Applicable	Circulation or storage space.
B00A - R1025 - Leading Teacher - (13.58 SQM)	Office (3)	
B00B - R0003 - Metal Technology L.S. - (92.11 SQM) - Teaching Space: 1	Student Space (42)	
B00B - R0004 - Welding Area - (10.77 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Performance Workshop - (103.16 SQM)	Student Space (47)	
B00B - R0011 - General Learning Space - (53.9 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R0014 - Food Technology L.S. - (71.98 SQM) - Teaching Space: 1	Student Space (33)	
B00B - R0017 - Food Technology L.S. - (77.44 SQM) - Teaching Space: 1	Student Space (35)	
B00B - R0024 - Food/Research Space - (45.22 SQM)	Not Applicable	Circulation or storage space.
B00B - R0025 - Preparation - Materials - (25.67 SQM)	Not Applicable	Circulation or storage space.
B00B - R0029 - Outdoor Learning Area - (121.31 SQM)	Not Applicable	Circulation or storage space.
B00B - R1002 - Design/Technology L.S. - (66.97 SQM) - Teaching Space: 1	Student Space (31)	
B00B - R1007 - Wood Technology L.S. - (79.57 SQM) - Teaching Space: 1	Student Space (36)	
B00B - R1010 - Music Learning Space - (50.68 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R1013 - Music Learning Space - (59.25 SQM)	Student Space (27)	
B00B - R1014 - Practice/Seminar - (26 SQM)	Not Applicable	Circulation or storage space.
B00B - R1028 - Wood Technology L.S. - (79.46 SQM) - Teaching Space: 1	Student Space (36)	
B00B - R1030 - Art Learning Space - (65.97 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R1031 - Staff Study - (34.67 SQM)	Office (8)	
B00B - R1033 - Music Learning Space - (83.45 SQM) - Teaching Space: 1	Student Space (38)	
B00C - R0008 - General Assistants - (20.02 SQM)	Office (5)	
B00C - R0013 - Tea Room - (5.45 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0018 - Student Canteen - (62.52 SQM)	Not Applicable	Circulation or storage space.
B00C - R0019 - Movement - (11.04 SQM)	Not Applicable	Circulation or storage space.
B00C - R0022 - Movement - (12.82 SQM)	Not Applicable	Circulation or storage space.
B00C - R0023 - Movement - (19.5 SQM)	Not Applicable	Circulation or storage space.
B00C - R0024 - Movement - (13 SQM)	Not Applicable	Circulation or storage space.
B00C - R1004 - Movement - (8.85 SQM)	Not Applicable	Circulation or storage space.
B00C - R1008 - Movement - (8.92 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Main Area - (297.3 SQM)	Not Applicable	Circulation or storage space.
B00D - R0012 - Laboratory L.S. - (92.62 SQM) - Teaching Space: 1	● Student Space (42)	
B00D - R0015 - Laboratory L.S. - (86.24 SQM) - Teaching Space: 1	● Student Space (40)	
B00D - R0023 - Staff Study - (25.96 SQM)	○ Office (6)	
B00D - R0030 - Staff Study - (59.19 SQM)	○ Office (14)	
B00D - R0031 - Staff Kitchen - (6.96 SQM)	○ Office (1)	
B00D - R0033 - Movement - (5.98 SQM)	Not Applicable	Circulation or storage space.
B00D - R0035 - General Learning Space - (49.45 SQM) - Teaching Space: 1	● Student Space (22)	
B00D - R0038 - Preparation - Science - (39.23 SQM)	Not Applicable	Circulation or storage space.
B00D - R0040 - Tea Room - (5 SQM)	Not Applicable	Circulation or storage space.
B00D - R0041 - Seminar - Type 1 - (11.57 SQM)	○ Office (2)	
B00D - R0042 - Seminar - Type 1 - (11.3 SQM)	○ Office (2)	
B00D - R0044 - General Learning Space - (86.17 SQM) - Teaching Space: 1	● Student Space (39)	
B00D - R1001 - Interview/Office - Type 1 - (12.82 SQM)	○ Office (3)	
B00D - R1003 - General Learning Space - (53.61 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1006 - General Learning Space - (59.01 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R1007 - General Learning Space - (52.07 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1008 - General Learning Space - (52.37 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1018 - General Learning Space - (53.68 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1019 - Staff Study - (26.11 SQM)	○ Office (6)	
B00D - R1020 - Computer Learning Space - (72.82 SQM) - Teaching Space: 1	● Student Space (33)	
B00D - R1023 - General Learning Space - (53.9 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R1024 - General Learning Space - (53.83 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1025 - General Learning Space - (52.73 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1026 - General Learning Space - (59.02 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R1032 - General Learning Space - (152.57 SQM) - Teaching Space: 1	● Student Space (70)	
B00E - R0001 - General Learning Space - (65.34 SQM) - Teaching Space: 1	● Student Space (30)	
B00E - R0003 - Laboratory L.S. - (98.09 SQM) - Teaching Space: 1	● Student Space (45)	
B00E - R0006 - Laboratory L.S. - (84.64 SQM) - Teaching Space: 1	● Student Space (39)	
B00E - R0008 - Laboratory L.S. - (79.82 SQM) - Teaching Space: 1	● Student Space (37)	
B00E - R0012 - Deputy Principal Office - (15.06 SQM)	○ Office (3)	
B00E - R0020 - General Learning Space - (59.4 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R0024 - Preparation - Science - (39.16 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - General Learning Space - (65.58 SQM) - Teaching Space: 1	● Student Space (30)	
B00E - R1003 - Computer Learning Space - (59.47 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R1004 - General Learning Space - (53.02 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1005 - General Learning Space - (52.87 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1006 - General Learning Space - (59.39 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R1011 - General Learning Space - (59.41 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R1012 - Movement Studio - (106.04 SQM)	Not Applicable	Circulation or storage space.
B00E - R1013 - General Learning Space - (59.25 SQM) - Teaching Space: 1	● Student Space (27)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R1019 - Staff Study - (50.15 SQM)	Office (12)	
B00F - R0004 - Photographic Studio - (21.69 SQM)	Office (5)	
B00F - R0005 - Dark Room - (22.3 SQM)	Office (5)	
B00F - R0007 - Workshop - (32.95 SQM)	Student Space (15)	
B00F - R0018 - Movement - (7.2 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Performance Workshop - (70.08 SQM)	Student Space (32)	
B00G - R0005 - Performance Workspace - (40.14 SQM) - Teaching Space: 1	Student Space (18)	
B00H - R0005 - Staff Kitchen - (19.07 SQM)	Office (4)	
B00H - R0014 - Stage - (70.74 SQM)	Not Applicable	Circulation or storage space.
B00H - R0017 - Multi-Purpose Space - (580.95 SQM)	Student Space (269)	
B00N - R0001 - Gymnasium - (733.58 SQM)	Student Space (340)	
B00N - R0005 - Clinic - (13.66 SQM)	Office (3)	
B00N - R0012 - Staff Study - (11.18 SQM)	Office (2)	
B00N - R0019 - Visual Arts Workshop - (97.78 SQM)	Student Space (45)	
B00N - R0020 - Performance Workshop - (111.89 SQM)	Student Space (51)	
B00N - R0021 - Stage - (134.98 SQM)	Not Applicable	Circulation or storage space.
B00N - R0032 - Movement - (12.57 SQM)	Not Applicable	Circulation or storage space.
B00N - R0033 - Movement - (72.47 SQM)	Not Applicable	Circulation or storage space.
OS 600 19622 - OS 600 19622 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 600 19623 - OS 600 19623 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 600 19624 - OS 600 19624 - Learning Unit - Small - (57 SQM)	Student Space (26)	