

VENTILATION AUDIT REPORT

SCHOOL:	Kurmond Public School (2340)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Hawkesbury
LOCAL GOVERNMENT AREA:	Hawkesbury

2340 - Kurmond Public School
Site Plan (12599)



1:701

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (34.49 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Practical Activities - 1hb - (14.77 SQM)	● Student Space (6)	
B00A - R0003 - Home Base - (62.18 SQM) - Teaching Space: 1	● Student Space (28)	
B00A - R0005 - Movement - (13.8 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Withdrawal Space - 1hb - (11.8 SQM)	● Student Space (5)	
B00A - R0007 - Movement - (13.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Home Base - (61.91 SQM) - Teaching Space: 1	● Student Space (28)	
B00A - R0010 - Practical Activities - 1hb - (14.77 SQM)	● Student Space (6)	
B00B - R0001 - Staff Room Annexe - (9.66 SQM)	● Office (2)	
B00B - R0002 - Withdrawal Space - 1hb - (37.78 SQM)	● Student Space (17)	
B00B - R0003 - Withdrawal Space - 1hb - (35.32 SQM)	● Student Space (16)	
B00B - R0007 - Movement - (17.73 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Home Base - (47.08 SQM) - Teaching Space: 1	● Student Space (21)	
B00C - R0002 - Movement - (12.21 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Canteen - (18.99 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Movement - (7.59 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Movement - (66.22 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Practical Activities - 1hb - (13.87 SQM)	● Student Space (6)	
B00E - R0004 - Home Base - (81.32 SQM) - Teaching Space: 1	● Student Space (37)	
B00E - R0005 - Home Base - (47.58 SQM) - Teaching Space: 1	● Student Space (22)	
B00E - R0006 - Practical Activities - 1hb - (21.71 SQM)	● Student Space (10)	
B00F - R0008 - Movement - (7.27 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Reading Area - (165.97 SQM)	● Student Space (77)	
OS 503 14331 - OS 503 14331 - Admin Lib Staff/Principal/Clerk/Store - (152 SQM)	● Office (38)	
OS 602 11659 - OS 602 11659 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 603 10160 - OS 603 10160 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	