

VENTILATION AUDIT REPORT

SCHOOL:	Kurrambee School (5621)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Londonderry
LOCAL GOVERNMENT AREA:	Penrith

Siteplan

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Entry Vestibule - (13.57 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Interview - (12.82 SQM)	Office (3)	
B00A - R0004 - Principal - (12.82 SQM)	Office (3)	
B00A - R0005 - Movement - (21.03 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Clerical Office - (17.47 SQM)	Office (4)	
B00A - R0008 - Sick Bay - (6.63 SQM)	Student Space (3)	
B00A - R0013 - Staff Room Annexe - (13.81 SQM)	Office (3)	
B00A - R0017 - Staff Room - (62.27 SQM)	Office (15)	
B00A - R0018 - Staff Room Annexe - (25.16 SQM)	Office (6)	
B00A - R0023 - Reading Area - (99.28 SQM)	Student Space (46)	
B00A - R0028 - Staff Room Annexe - (22.95 SQM)	Office (5)	
B00B - R0009 - Practical Activities - S - 1hb - (30.61 SQM)	Student Space (14)	
B00B - R0010 - Home Base - S - (28.05 SQM) - Teaching Space: 1	Student Space (13)	
B00B - R0011 - Practical Activities - S - 1hb - (30.33 SQM)	Student Space (14)	
B00C - R0008 - Home Base - S - (28.58 SQM) - Teaching Space: 1	Student Space (13)	
B00C - R0009 - Practical Activities - S - 1hb - (31.81 SQM)	Student Space (14)	
B00C - R0010 - Home Base - S - (22.47 SQM) - Teaching Space: 1	Student Space (10)	
B00C - R0011 - Practical Activities - S - 1hb - (34.31 SQM)	Student Space (15)	
B00D - R0005 - Home Base - S - (31.5 SQM) - Teaching Space: 1	Student Space (14)	
B00D - R0006 - Home Base - S - (28.06 SQM) - Teaching Space: 1	Student Space (13)	
B00E - R0001 - Practical Activities - (22.56 SQM)	Student Space (10)	
B00E - R0002 - Home Base - (58.62 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0005 - Withdrawal Space - 1hb - (9.74 SQM)	Student Space (4)	
B00E - R0006 - Breakout Area - (17.89 SQM)	Not Applicable	Circulation or storage space.
B00E - R0010 - Practical Activities - (22.61 SQM)	Student Space (10)	
B00E - R0011 - Home Base - (58.85 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0014 - Withdrawal Space - 1hb - (9.71 SQM)	Student Space (4)	
B00E - R0015 - Breakout Area - (17.92 SQM)	Not Applicable	Circulation or storage space.
B00E - R0018 - Withdrawal Space - 1hb - (9.68 SQM)	Student Space (4)	
B00E - R0019 - Breakout Area - (17.9 SQM)	Not Applicable	Circulation or storage space.
B00E - R0020 - Practical Activities - (22.42 SQM)	Student Space (10)	
B00E - R0021 - Home Base - (58.55 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0025 - Practical Activities - (22.56 SQM)	Student Space (10)	
B00E - R0026 - Home Base - (58.92 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0028 - Withdrawal Space - 1hb - (9.77 SQM)	Student Space (4)	
B00E - R0029 - Breakout Area - (18.08 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Practical Activities - (22.58 SQM)	Student Space (10)	
B00F - R0002 - Home Base - (58.77 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0005 - Withdrawal Space - 1hb - (9.74 SQM)	Student Space (4)	
B00F - R0006 - Breakout Area - (17.93 SQM)	Not Applicable	Circulation or storage space.
B00F - R0010 - Practical Activities - (22.55 SQM)	Student Space (10)	
B00F - R0011 - Home Base - (58.62 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R0014 - Withdrawal Space - 1hb - (9.74 SQM)	Student Space (4)	
B00F - R0015 - Breakout Area - (17.85 SQM)	Not Applicable	Circulation or storage space.
B00F - R0018 - Withdrawal Space - 1hb - (9.64 SQM)	Student Space (4)	
B00F - R0019 - Breakout Area - (17.78 SQM)	Not Applicable	Circulation or storage space.
B00F - R0020 - Practical Activities - (22.57 SQM)	Student Space (10)	
B00F - R0021 - Home Base - (58.39 SQM) - Teaching Space: 1	Student Space (27)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0025 - Practical Activities - (22.64 SQM)	● Student Space (10)	
B00F - R0026 - Home Base - (58.62 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0028 - Withdrawal Space - 1hb - (9.74 SQM)	● Student Space (4)	
B00F - R0029 - Breakout Area - (17.91 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Practical Activities - (22.71 SQM)	● Student Space (10)	
B00G - R0002 - Home Base - (58.46 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0005 - Withdrawal Space - 1hb - (9.8 SQM)	● Student Space (4)	
B00G - R0006 - Breakout Area - (17.89 SQM)	Not Applicable	Circulation or storage space.
B00G - R0010 - Practical Activities - (22.76 SQM)	● Student Space (10)	
B00G - R0011 - Home Base - (58.68 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0014 - Withdrawal Space - 1hb - (9.77 SQM)	● Student Space (4)	
B00G - R0015 - Breakout Area - (17.92 SQM)	Not Applicable	Circulation or storage space.
B00G - R0018 - Withdrawal Space - 1hb - (9.71 SQM)	● Student Space (4)	
B00G - R0019 - Breakout Area - (17.85 SQM)	Not Applicable	Circulation or storage space.
B00G - R0020 - Practical Activities - (22.71 SQM)	● Student Space (10)	
B00G - R0021 - Home Base - (58.54 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0025 - Practical Activities - (22.84 SQM)	● Student Space (10)	
B00G - R0026 - Home Base - (58.53 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0028 - Withdrawal Space - 1hb - (9.74 SQM)	● Student Space (4)	
B00G - R0029 - Breakout Area - (17.86 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Communal Space - (118.64 SQM)	● Student Space (55)	
B00H - R0004 - Special Programs Room - (29.51 SQM)	● Student Space (13)	
B00I - R0001 - Movement - (7.73 SQM)	Not Applicable	Circulation or storage space.
B00I - R0002 - Hydrotherapy - (15.98 SQM)	Not Applicable	Circulation or storage space.
B00I - R0003 - Movement - (95.84 SQM)	Not Applicable	Circulation or storage space.
B00I - R0004 - Hydrotherapy - Pool - (64.58 SQM)	Not Applicable	Circulation or storage space.
B00J - R0007 - Movement - (9.59 SQM)	Not Applicable	Circulation or storage space.