


VENTILATION AUDIT REPORT

SCHOOL:	Kurri Kurri High School (8177)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Cessnock
LOCAL GOVERNMENT AREA:	Cessnock

8177 - Kurri Kurri High School
Site Plan (13443)



1:1,562

Printed: 24-Jun-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Study - (17.63 SQM)	Office (4)	
B00A - R0002 - General Learning Space - (49.08 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0003 - General Learning Space - (49.08 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0004 - General Learning Space - (49.08 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0005 - General Learning Space - (49.08 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0006 - General Learning Space - (49.08 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0007 - General Learning Space - (49.08 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0008 - General Learning Space - (49.08 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0009 - General Learning Space - (49.08 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0011 - Clinic - Boys - (14.74 SQM)	Office (3)	
B00A - R0014 - Clinic - Girls - (14.59 SQM)	Office (3)	
B00A - R0017 - Staff Study - (12.91 SQM)	Office (3)	
B00A - R0020 - Staff Study - (13.18 SQM)	Office (3)	
B00A - R0024 - Movement - (248.24 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Staff Study - (20.27 SQM)	Office (5)	
B00A - R0031 - Movement - (10.63 SQM)	Not Applicable	Circulation or storage space.
B00A - R0032 - Multi-Purpose Space - (278.08 SQM)	Student Space (129)	
B00A - R0033 - Movement - (8.62 SQM)	Not Applicable	Circulation or storage space.
B00A - R0036 - Stage - (74.75 SQM)	Not Applicable	Circulation or storage space.
B00A - R0041 - Deputy Principal Office - (12.71 SQM)	Office (3)	
B00A - R0042 - Interview/Meeting - (12.75 SQM)	Office (3)	
B00A - R0047 - Administration - Clerical - (12.81 SQM)	Office (3)	
B00A - R0052 - Stage - (13.55 SQM)	Not Applicable	Circulation or storage space.
B00A - R0055 - Movement - (10.14 SQM)	Not Applicable	Circulation or storage space.
B00A - R0068 - Administration - Clerical - (74.96 SQM)	Office (18)	
B00A - R0069 - Public Reception - (38.41 SQM)	Not Applicable	Circulation or storage space.
B00A - R0070 - Movement - (29.6 SQM)	Not Applicable	Circulation or storage space.
B00A - R0073 - Deputy Principal Office - (18.06 SQM)	Office (4)	
B00A - R0074 - Interview/Meeting - (21.4 SQM)	Office (5)	
B00A - R0076 - Movement - (22.85 SQM)	Not Applicable	Circulation or storage space.
B00A - R0077 - Movement - (13.61 SQM)	Not Applicable	Circulation or storage space.
B00A - R0078 - Commonroom - (13.3 SQM)	Office (3)	
B00A - R0079 - Staff Kitchen - (5.29 SQM)	Office (1)	
B00A - R0080 - Principal Office - (25.01 SQM)	Office (6)	
B00A - R0081 - Interview/Meeting - (14.55 SQM)	Office (3)	
B00A - R1001 - Movement - (10.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R1003 - General Learning Space - (50.2 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1004 - General Learning Space - (49.39 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1005 - General Learning Space - (49.31 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1006 - General Learning Space - (49.31 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1007 - Laboratory L.S. - (83.79 SQM) - Teaching Space: 1	Student Space (38)	
B00A - R1008 - Preparation - (16.56 SQM)	Not Applicable	Circulation or storage space.
B00A - R1009 - General Learning Space - (49.67 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1010 - Preparation - (16.47 SQM)	Not Applicable	Circulation or storage space.
B00A - R1011 - Laboratory L.S. - (83.86 SQM) - Teaching Space: 1	Student Space (38)	
B00A - R1013 - Staff Study - (32.4 SQM)	Office (8)	
B00A - R1014 - Commonroom - (106.86 SQM)	Office (26)	
B00A - R1015 - Movement - (8.74 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R1018 - Staff Study - (28.32 SQM)	Office (7)	
B00A - R1019 - Staff Study - (46.78 SQM)	Office (11)	
B00A - R1021 - Commonroom - (35.33 SQM)	Office (8)	
B00A - R1023 - Staff Study - (35.01 SQM)	Office (8)	
B00A - R1025 - Movement - (244.06 SQM)	Not Applicable	Circulation or storage space.
B00A - R9001 - Staff Study - (9.26 SQM)	Office (2)	
B00A - R9009 - Movement - (22.68 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Laboratory L.S. - (92.68 SQM) - Teaching Space: 1	Student Space (42)	
B00B - R0004 - Preparation - (29.07 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - General Learning Space - (52.74 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0007 - Food/Research Space - (8.15 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Food/Research Space - (8.4 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Food Technology L.S. - (89.01 SQM) - Teaching Space: 1	Student Space (41)	
B00B - R0011 - Staff Study - (24.11 SQM)	Office (6)	
B00B - R0012 - General Learning Space - (52.6 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0016 - Movement - (176.37 SQM)	Not Applicable	Circulation or storage space.
B00B - R1002 - Seminar - (12.39 SQM)	Office (3)	
B00B - R1003 - Staff Study - (12.25 SQM)	Office (3)	
B00B - R1006 - Staff Study - (25.53 SQM)	Office (6)	
B00B - R1007 - Art Learning Space - (65.53 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R1011 - Art Learning Space - (51.37 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R1012 - Art Learning Space - (59.86 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R1013 - Darkroom Space - (10.09 SQM)	Office (2)	
B00B - R1016 - Art Learning Space - (52.61 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1017 - Movement - (179.57 SQM)	Not Applicable	Circulation or storage space.
B00B - R1018 - Darkroom Space - (35.19 SQM)	Office (8)	
B00C - R0003 - Music Learning Space - (52.6 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0004 - Music Learning Space - (52.6 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0005 - Movement - (9.19 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Practice/Seminar - (11.99 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Laboratory L.S. - (85.84 SQM) - Teaching Space: 1	Student Space (39)	
B00C - R0011 - Laboratory L.S. - (86.21 SQM) - Teaching Space: 1	Student Space (39)	
B00C - R0015 - Movement - (116.11 SQM)	Not Applicable	Circulation or storage space.
B00C - R0016 - Movement - (11.92 SQM)	Not Applicable	Circulation or storage space.
B00C - R0019 - Preparation - (39.08 SQM)	Not Applicable	Circulation or storage space.
B00C - R1003 - General Learning Space - (52.61 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1004 - General Learning Space - (52.38 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1005 - Staff Study - (31.06 SQM)	Office (7)	
B00C - R1006 - General Learning Space - (52.46 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1007 - General Learning Space - (52.53 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1008 - General Learning Space - (52.53 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1009 - Computer Learning Space - (52.53 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1013 - Movement - (116.11 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Movement - (60.26 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Movement - (152.02 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Student Canteen - (84.12 SQM)	Not Applicable	Circulation or storage space.
B00D - R0012 - Movement - (61.82 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Food Technology L.S. - (79.04 SQM) - Teaching Space: 1	Student Space (36)	
B00E - R0004 - Food/Research Space - (18.83 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Food Technology L.S. - (88.48 SQM) - Teaching Space: 1	Student Space (41)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0008 - Staff Study - (9.84 SQM)	Office (2)	
B00E - R0010 - Movement - (26.1 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Staff Study - (36.51 SQM)	Office (9)	
B00F - R0004 - Computer Learning Space - (77.58 SQM) - Teaching Space: 1	Student Space (35)	
B00F - R0005 - Staff Study - (11.72 SQM)	Office (2)	
B00F - R0007 - Materials Technology L.S. - (104.03 SQM) - Teaching Space: 1	Student Space (48)	
B00F - R0009 - Staff Study - (7.16 SQM)	Office (1)	
B00F - R0011 - Materials Technology L.S. - (140.43 SQM) - Teaching Space: 1	Student Space (65)	
B00F - R0013 - Staff Study - (7.21 SQM)	Office (1)	
B00F - R0014 - Materials Technology L.S. - (118.21 SQM) - Teaching Space: 1	Student Space (54)	
B00F - R0015 - Welding Area - (6.06 SQM)	Not Applicable	Circulation or storage space.
B00F - R0016 - Movement - (116.53 SQM)	Not Applicable	Circulation or storage space.
B00F - R0017 - Movement - (7.73 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Movement - (32.25 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Materials Technology L.S. - (67.76 SQM) - Teaching Space: 1	Student Space (31)	
B00G - R0006 - Design L.S. - (67.83 SQM) - Teaching Space: 1	Student Space (31)	
B00L - R0002 - Main Area - (396.69 SQM)	Not Applicable	Circulation or storage space.
B00L - R0004 - Audio Visual Workroom - (34.29 SQM)	Student Space (15)	
B00L - R0005 - Workroom - (39.89 SQM)	Office (9)	
B00L - R0007 - Pupil Entry - (16.31 SQM)	Not Applicable	Circulation or storage space.
B00L - R0012 - Seminar - (13.4 SQM)	Office (3)	
B00L - R0014 - Seminar - (20.63 SQM)	Office (5)	
B00L - R0015 - Movement - (168.24 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - General Learning Space - (42.39 SQM) - Teaching Space: 1	Student Space (19)	
B00M - R0003 - Practical Activity Area - (29.32 SQM)	Student Space (13)	
B00M - R0004 - General Learning Space - (40.41 SQM) - Teaching Space: 1	Student Space (18)	
B00N - R0001 - Music Learning Space - (64.77 SQM) - Teaching Space: 1	Student Space (30)	
B00N - R0002 - Performance Workshop - (65.49 SQM)	Student Space (30)	
B00N - R0007 - Staff Study - (10.91 SQM)	Office (2)	
B00O - R0001 - Workshop Area - (235.12 SQM)	Student Space (109)	
B00P - R0001 - Gymnasium - (621.4 SQM)	Student Space (288)	
OS 600 19761 - OS 600 19761 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 601 11814 - OS 601 11814 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 12887 - OS 601 12887 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 12950 - OS 601 12950 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 13235 - OS 601 13235 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 16809 - OS 601 16809 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 730 15959 - OS 730 15959 - Needlework Textile Learning/Str/Fitting - (95 SQM)	Not Applicable	Circulation or storage space.