

VENTILATION AUDIT REPORT

| | |
|-------------------------------|---|
| SCHOOL: | Kurri Kurri Public School (7422) |
| AMU REGION: | Hunter/Central Coast |
| STATE ELECTORATE: | Cessnock |
| LOCAL GOVERNMENT AREA: | Cessnock |

7422 - Kurri Kurri Public School
Site Plan (12606)



1:910

Printed: 24-Dec-2020

Ventilation Audit Key

| Category | Description |
|---|--|
|  | Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings. |
|  | Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces. |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|--|---|-------------------------------|
| B00A - R0001 - Movement - (117.48 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0003 - Staff Room Annexe - (16.53 SQM) | Office (4) | |
| B00A - R0004 - Movement - (6.08 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0006 - Staff Room Annexe - (9.16 SQM) | Office (2) | |
| B00A - R0007 - Home Base - (55.46 SQM) - Teaching Space: 1 | Student Space (25) | |
| B00A - R0008 - Movement - (23.16 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0009 - Home Base - (55.27 SQM) - Teaching Space: 1 | Student Space (25) | |
| B00A - R0010 - Movement - (20.6 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0011 - Home Base - (55.12 SQM) - Teaching Space: 1 | Student Space (25) | |
| B00A - R0014 - Movement - (28.69 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0015 - Movement - (24.51 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0016 - Home Base - (54.22 SQM) - Teaching Space: 1 | Student Space (25) | |
| B00A - R0018 - Movement - (24.28 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0025 - Movement - (42.37 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0026 - Practical Activities - 1hb - (74.57 SQM) | Student Space (34) | |
| B00A - R0027 - Home Base - (46.66 SQM) - Teaching Space: 1 | Student Space (21) | |
| B00A - R0028 - Home Base - (46.91 SQM) - Teaching Space: 1 | Student Space (21) | |
| B00A - R0029 - Home Base - (46.97 SQM) - Teaching Space: 1 | Student Space (21) | |
| B00A - R0030 - Home Base - (46.99 SQM) - Teaching Space: 1 | Student Space (21) | |
| B00A - R0032 - Movement - (18.29 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0036 - Home Base - (60.15 SQM) - Teaching Space: 1 | Student Space (27) | |
| B00A - R0037 - Practical Activities - 1hb - (15.07 SQM) | Student Space (6) | |
| B00A - R0038 - Home Base - (57.76 SQM) - Teaching Space: 1 | Student Space (26) | |
| B00A - R0039 - Practical Activities - 1hb - (20.3 SQM) | Student Space (9) | |
| B00A - R0040 - Home Base - (60.28 SQM) - Teaching Space: 1 | Student Space (27) | |
| B00B - R0007 - Movement - (10.47 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0008 - Principal - (23.39 SQM) | Office (5) | |
| B00B - R0009 - Clerical Office - (10.64 SQM) | Office (2) | |
| B00B - R0010 - Clerical Office - (11.46 SQM) | Office (2) | |
| B00B - R0011 - Duplicating Workroom - (8.71 SQM) | Office (2) | |
| B00B - R0012 - Entry Vestibule - (6.78 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R0001 - Movement - (23.07 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R0002 - Interview - (9 SQM) | Office (2) | |
| B00C - R0003 - Movement - (6.3 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R0005 - Staff Room - (42.38 SQM) | Office (10) | |
| B00C - R0006 - Staff Room - (42.13 SQM) | Office (10) | |
| B00C - R0008 - Special Programs Room - (41.54 SQM) | Student Space (19) | |
| B00C - R0010 - Seminar/Study - (14.16 SQM) | Office (3) | |
| B00C - R0011 - Seminar/Study - (12.57 SQM) | Office (3) | |
| B00C - R0012 - Reading Area - (47.71 SQM) | Student Space (22) | |
| B00C - R0013 - Reading Area - (51.48 SQM) | Student Space (23) | |
| B00C - R0014 - Reading Area - (42.32 SQM) | Student Space (19) | |
| B00C - R0020 - Movement - (10.53 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R0022 - Reading Area - (14.1 SQM) | Student Space (6) | |
| B00C - R0025 - Movement - (22.27 SQM) | Not Applicable | Circulation or storage space. |
| B00C - R0026 - Staff Room Annexe - (16.25 SQM) | Office (4) | |
| B00C - R0027 - Special Programs Room - (59.34 SQM) | Student Space (27) | |
| B00D - R0001 - Movement - (31.56 SQM) | Not Applicable | Circulation or storage space. |
| B00D - R0002 - Clerical Office - (16.74 SQM) | Office (4) | |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|--|---|-------------------------------|
| B00D - R0003 - Movement - (6.15 SQM) | Not Applicable | Circulation or storage space. |
| B00D - R0004 - Staff Room Annexe - (16.34 SQM) | Office (4) | |
| B00D - R0005 - Movement - (75.28 SQM) | Not Applicable | Circulation or storage space. |
| B00D - R0006 - Home Base - (47.41 SQM) - Teaching Space: 1 | Student Space (21) | |
| B00D - R0007 - Home Base - (47.34 SQM) - Teaching Space: 1 | Student Space (21) | |
| B00D - R0008 - Home Base - (67.11 SQM) - Teaching Space: 1 | Student Space (31) | |
| B00D - R0009 - Practical Activities - 1hb - (6.68 SQM) | Student Space (3) | |
| B00D - R0010 - Home Base - (67.62 SQM) - Teaching Space: 1 | Student Space (31) | |
| B00D - R0011 - Practical Activities - 1hb - (6.73 SQM) | Student Space (3) | |
| B00D - R0012 - Home Base - (51.66 SQM) - Teaching Space: 1 | Student Space (23) | |
| B00D - R0013 - Practical Activities - 1hb - (37.39 SQM) | Student Space (17) | |
| B00D - R0014 - Home Base - (67.73 SQM) - Teaching Space: 1 | Student Space (31) | |
| B00D - R0015 - Home Base - (77.19 SQM) - Teaching Space: 1 | Student Space (35) | |
| B00D - R0017 - Movement - (16.25 SQM) | Not Applicable | Circulation or storage space. |
| B00D - R0020 - Home Base - (47.54 SQM) - Teaching Space: 1 | Student Space (22) | |
| B00D - R0023 - Home Base - (47.52 SQM) - Teaching Space: 1 | Student Space (22) | |
| B00D - R0024 - Movement - (29.83 SQM) | Not Applicable | Circulation or storage space. |
| B00D - R0026 - Special Programs Room - (31.41 SQM) | Student Space (14) | |
| B00D - R0027 - Home Base - (47.25 SQM) - Teaching Space: 1 | Student Space (21) | |
| B00D - R0032 - Movement - (13.91 SQM) | Not Applicable | Circulation or storage space. |
| B00D - R0037 - Movement - (17.26 SQM) | Not Applicable | Circulation or storage space. |
| B00E - R0001 - Movement - (5.19 SQM) | Not Applicable | Circulation or storage space. |
| B00E - R0002 - Home Base - (61.01 SQM) - Teaching Space: 1 | Student Space (28) | |
| B00E - R0003 - Home Base - (58.14 SQM) - Teaching Space: 1 | Student Space (26) | |
| B00E - R0004 - Practical Activities - 1hb - (14.05 SQM) | Student Space (6) | |
| B00E - R0006 - Movement - (5.07 SQM) | Not Applicable | Circulation or storage space. |
| B00E - R0007 - Home Base - (73.73 SQM) - Teaching Space: 1 | Student Space (34) | |
| B00F - R0001 - Movement - (38.44 SQM) | Not Applicable | Circulation or storage space. |
| B00F - R0002 - Canteen - (46.61 SQM) | Not Applicable | Circulation or storage space. |
| B00G - R0004 - Special Programs Room - (31.93 SQM) | Student Space (14) | |
| B00G - R0006 - Movement - (5.9 SQM) | Not Applicable | Circulation or storage space. |
| B00G - R0007 - Home Base - S - (47.15 SQM) - Teaching Space: 1 | Student Space (21) | |
| B00G - R0010 - Practical Activities - 1hb - (16.39 SQM) | Student Space (7) | |
| B00G - R0011 - Movement - (5.83 SQM) | Not Applicable | Circulation or storage space. |
| B00G - R0012 - Home Base - (50.25 SQM) - Teaching Space: 1 | Student Space (23) | |
| B00J - R0001 - Movement - (38.48 SQM) | Not Applicable | Circulation or storage space. |
| B00J - R0002 - Practical Activities - 1hb - (19.4 SQM) | Student Space (9) | |
| B00J - R0004 - Home Base - (59.2 SQM) - Teaching Space: 1 | Student Space (27) | |
| B00J - R0005 - Withdrawal Space - 2hb - (11.35 SQM) | Student Space (5) | |
| B00J - R0006 - Home Base - (59.19 SQM) - Teaching Space: 1 | Student Space (27) | |
| B00J - R0008 - Practical Activities - 1hb - (19.4 SQM) | Student Space (9) | |
| B00K - R0002 - Home Base - (58.47 SQM) - Teaching Space: 1 | Student Space (27) | |
| B00K - R0003 - Withdrawal Space - 1hb - (9.63 SQM) | Student Space (4) | |
| B00K - R0005 - Practical Activities - 2hb - (38.21 SQM) | Student Space (17) | |
| B00K - R0010 - Home Base - (57.92 SQM) - Teaching Space: 1 | Student Space (26) | |
| B00K - R0011 - Withdrawal Space - 1hb - (9.61 SQM) | Student Space (4) | |
| B00L - R0002 - Communal Space - (198.88 SQM) | Student Space (92) | |
| B00L - R0003 - Movement - (6.34 SQM) | Not Applicable | Circulation or storage space. |
| B00L - R0004 - Raised Platform - (58.55 SQM) | Not Applicable | Circulation or storage space. |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|---------------------------------------|--|-------------------------------|
| B00L - R0006 - Movement - (17.13 SQM) | Not Applicable | Circulation or storage space. |