

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Laggan Public School (2354)</b>
<b>AMU REGION:</b>	<b>Southern NSW</b>
<b>STATE ELECTORATE:</b>	<b>Goulburn</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Upper Lachlan</b>

2354 - Laggan Public School  
Site Plan (13171)


















1:564

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Principal - (16.29 SQM)	 Office (4)	
B00A - R0002 - Sick Bay - (7.97 SQM)	 Student Space (3)	
B00A - R0003 - Entry Vestibule - (12.11 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Clerical Office/Workroom - (12.11 SQM)	 Office (3)	
B00A - R0005 - Duplicating Workroom - (11.19 SQM)	 Office (2)	
B00A - R0007 - Staff Room - (12.11 SQM)	 Office (3)	
B00B - R0003 - Reading Area - (59.72 SQM)	 Student Space (27)	
B00B - R0006 - Practical Activities - 1hb - (11.09 SQM)	 Student Space (5)	
B00B - R0008 - Home Base - (49.18 SQM) - Teaching Space: 1	 Student Space (22)	
B00D - R0002 - Practical Activities - 1hb - (45.07 SQM)	 Student Space (20)	
B00D - R0005 - Home Base - (57.5 SQM) - Teaching Space: 1	 Student Space (26)	
B00D - R0006 - Home Base - (57.49 SQM) - Teaching Space: 1	 Student Space (26)	
B00D - R0009 - Withdrawal Space - 1hb - (12.32 SQM)	 Student Space (5)	
B00E - R0001 - Raised Platform - (22.58 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Communal Space - (139.37 SQM)	 Student Space (64)	
B00F - R0001 - Communal Space - (61.19 SQM)	 Student Space (28)	
B00F - R0003 - Practical Activities - (6.25 SQM)	 Student Space (2)	