


VENTILATION AUDIT REPORT

SCHOOL:	Lake Cathie Public School (4654)
AMU REGION:	North Coast
STATE ELECTORATE:	Port Macquarie
LOCAL GOVERNMENT AREA:	Port Macquarie-Hastings

4654 - Lake Cathie Public School
Site Plan (15699)



1:1,183

Printed: 11-Sep-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Clerical/Printing - (53.58 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Entry Vestibule - (23.63 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Principal - (16.43 SQM)	Office (4)	
B00A - R0004 - Sick Bay - (9.45 SQM)	Student Space (4)	
B00A - R0005 - Deputy Principal - Type 1 - (13.49 SQM)	Office (3)	
B00A - R0006 - Interview - (12.42 SQM)	Office (3)	
B00A - R0007 - Interview - (16.43 SQM)	Office (4)	
B00A - R0013 - Staff Room - (59.19 SQM)	Office (14)	
B00A - R0016 - Staff Kitchen - (8.51 SQM)	Office (2)	
B00A - R0018 - Movement - (37.07 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Reading Area - (198.18 SQM)	Student Space (91)	
B00B - R0005 - Special Programs Room - (31.33 SQM)	Student Space (14)	
B00C - R0011 - Movement - (15.21 SQM)	Not Applicable	Circulation or storage space.
B00C - R0016 - Raised Platform - (61.51 SQM)	Not Applicable	Circulation or storage space.
B00C - R0017 - Communal Space - (149.22 SQM)	Student Space (69)	
B00C - R0021 - Special Programs Room - (37.8 SQM)	Student Space (17)	
B00C - R0022 - Movement - (13.04 SQM)	Not Applicable	Circulation or storage space.
B00C - R0023 - Reading Area - (63.9 SQM)	Student Space (29)	
B00D - R0001 - Canteen - (26.34 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Withdrawal Space - 2hb - (15.73 SQM)	Student Space (7)	
B00E - R0002 - Practical Activities - (16.97 SQM)	Student Space (7)	
B00E - R0003 - Outdoor Learning Area - (64.31 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Withdrawal Space - 1hb - (12.36 SQM)	Student Space (5)	
B00E - R0005 - Outdoor Learning Area - (30.62 SQM)	Not Applicable	Circulation or storage space.
B00E - R0006 - Home Base - (63.93 SQM) - Teaching Space: 1	Student Space (29)	
B00E - R0008 - Collaboration Space - (99.57 SQM)	Student Space (46)	
B00E - R0009 - Home Base - (63.37 SQM) - Teaching Space: 1	Student Space (29)	
B00E - R0010 - Outdoor Learning Area - (29.1 SQM)	Not Applicable	Circulation or storage space.
B00E - R0011 - Withdrawal Space - 1hb - (12.4 SQM)	Student Space (5)	
B00E - R0012 - Home Base - (64.62 SQM) - Teaching Space: 1	Student Space (29)	
B00E - R0013 - Practical Activities - (16.72 SQM)	Student Space (7)	
B00E - R0015 - Withdrawal Space - 1hb - (12.49 SQM)	Student Space (5)	
B00F - R0001 - Withdrawal Space - 1hb - (12.41 SQM)	Student Space (5)	
B00F - R0002 - Practical Activities - (16.24 SQM)	Student Space (7)	
B00F - R0004 - Home Base - (64.57 SQM) - Teaching Space: 1	Student Space (29)	
B00F - R0005 - Withdrawal Space - 1hb - (12.81 SQM)	Student Space (5)	
B00F - R0006 - Outdoor Learning Area - (29.42 SQM)	Not Applicable	Circulation or storage space.
B00F - R0007 - Home Base - (64.12 SQM) - Teaching Space: 1	Student Space (29)	
B00F - R0009 - Collaboration Space - (99.84 SQM)	Student Space (46)	
B00F - R0010 - Home Base - (64.01 SQM) - Teaching Space: 1	Student Space (29)	
B00F - R0011 - Outdoor Learning Area - (28.76 SQM)	Not Applicable	Circulation or storage space.
B00F - R0012 - Withdrawal Space - 1hb - (12.77 SQM)	Student Space (5)	
B00F - R0013 - Home Base - (64.58 SQM) - Teaching Space: 1	Student Space (29)	
B00F - R0014 - Practical Activities - (16.34 SQM)	Student Space (7)	
B00F - R0015 - Withdrawal Space - 1hb - (15.74 SQM)	Student Space (7)	
B00G - R0001 - Withdrawal Space - 1hb - (12.21 SQM)	Student Space (5)	
B00G - R0002 - Practical Activities - (17.31 SQM)	Student Space (8)	
B00G - R0004 - Home Base - (67.48 SQM) - Teaching Space: 1	Student Space (31)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0005 - Withdrawal Space - 1hb - (14.05 SQM)	● Student Space (6)	
B00G - R0006 - Outdoor Learning Area - (29.05 SQM)	Not Applicable	Circulation or storage space.
B00G - R0007 - Home Base - (65.3 SQM) - Teaching Space: 1	● Student Space (30)	
B00G - R0009 - Collaboration Space - (98.96 SQM)	● Student Space (45)	
B00G - R0010 - Home Base - (64.47 SQM) - Teaching Space: 1	● Student Space (29)	
B00G - R0011 - Outdoor Learning Area - (29.19 SQM)	Not Applicable	Circulation or storage space.
B00G - R0012 - Withdrawal Space - 1hb - (14.2 SQM)	● Student Space (6)	
B00G - R0013 - Home Base - (69.69 SQM) - Teaching Space: 1	● Student Space (32)	
B00G - R0014 - Practical Activities - (17.35 SQM)	● Student Space (8)	
B00G - R0015 - Withdrawal Space - 1hb - (15.45 SQM)	● Student Space (7)	
B00G - R0016 - Outdoor Learning Area - (48.71 SQM)	Not Applicable	Circulation or storage space.
B00G - R1001 - Withdrawal Space - 1hb - (12.31 SQM)	● Student Space (5)	
B00G - R1002 - Practical Activities - (18.21 SQM)	● Student Space (8)	
B00G - R1004 - Home Base - (69.2 SQM) - Teaching Space: 1	● Student Space (32)	
B00G - R1005 - Withdrawal Space - 1hb - (14.38 SQM)	● Student Space (6)	
B00G - R1006 - Outdoor Learning Area - (32.6 SQM)	Not Applicable	Circulation or storage space.
B00G - R1007 - Home Base - (68.93 SQM) - Teaching Space: 1	● Student Space (31)	
B00G - R1008 - Collaboration Space - (86.59 SQM)	● Student Space (40)	
B00G - R1009 - Home Base - (68.61 SQM) - Teaching Space: 1	● Student Space (31)	
B00G - R1010 - Outdoor Learning Area - (32.3 SQM)	Not Applicable	Circulation or storage space.
B00G - R1011 - Withdrawal Space - 1hb - (14.1 SQM)	● Student Space (6)	
B00G - R1012 - Home Base - (69.33 SQM) - Teaching Space: 1	● Student Space (32)	
B00G - R1013 - Practical Activities - (18.39 SQM)	● Student Space (8)	
B00G - R1014 - Withdrawal Space - 1hb - (15.39 SQM)	● Student Space (7)	
B00G - R1015 - Outdoor Learning Area - (48.71 SQM)	Not Applicable	Circulation or storage space.
NS 100 11968 - NS 100 11968 - Learning Unit - Single Primary/PAA - (76 SQM)	● Student Space (35)	
NS 100 12377 - NS 100 12377 - Learning Unit - Single Primary/PAA - (76 SQM)	● Student Space (35)	
NS 100 12432 - NS 100 12432 - Learning Unit - Single Primary/PAA - (76 SQM)	● Student Space (35)	
NS 100 15487 - NS 100 15487 - Learning Unit - Single Primary/PAA - (76 SQM)	● Student Space (35)	
NS 100 15887 - NS 100 15887 - Learning Unit - Single Primary/PAA - (76 SQM)	● Student Space (35)	
NS 100 16170 - NS 100 16170 - Learning Unit - Single Primary/PAA - (76 SQM)	● Student Space (35)	
NS 100 16821 - NS 100 16821 - Learning Unit - Single Primary/PAA - (76 SQM)	● Student Space (35)	
NS 100 16904 - NS 100 16904 - Learning Unit - Single Primary/PAA - (76 SQM)	● Student Space (35)	
NS 100 16905 - NS 100 16905 - Learning Unit - Single Primary/PAA - (76 SQM)	● Student Space (35)	
NS 100 16906 - NS 100 16906 - Learning Unit - Single Primary/PAA - (76 SQM)	● Student Space (35)	
NS 100 16907 - NS 100 16907 - Learning Unit - Single Primary/PAA - (76 SQM)	● Student Space (35)	
NS 100 16908 - NS 100 16908 - Learning Unit - Single Primary/PAA - (76 SQM)	● Student Space (35)	
OS 606 19263 - OS 606 19263 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19270 - OS 606 19270 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19581 - OS 606 19581 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	