


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Lake Macquarie High School (8210)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Lake Macquarie</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Lake Macquarie</b>

























## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (118.08 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Movement - (149.27 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Multi-Purpose Space - (10.91 SQM)	● Student Space (5)	
B00A - R0010 - Student Canteen - (49.12 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Movement - (192.54 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Performance Workspace - (71.09 SQM)	● Student Space (32)	
B00A - R0018 - Multi-Purpose Space - (70.64 SQM)	● Student Space (32)	
B00A - R0023 - Movement - (5.12 SQM)	Not Applicable	Circulation or storage space.
B00A - R0026 - Movement - (16.33 SQM)	Not Applicable	Circulation or storage space.
B00A - R0027 - Movement - (11.04 SQM)	Not Applicable	Circulation or storage space.
B00A - R0031 - Movement - (40.29 SQM)	Not Applicable	Circulation or storage space.
B00A - R0034 - Art Learning Space - (71.71 SQM) - Teaching Space: 1	● Student Space (33)	
B00A - R0036 - Isolation Space - (23.78 SQM)	● Office (5)	
B00A - R0039 - Practical Activities - (43.98 SQM)	● Student Space (20)	
B00A - R0043 - Movement - (8.86 SQM)	Not Applicable	Circulation or storage space.
B00A - R0044 - Movement - (37.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Computer Learning Space - (56.81 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R1002 - Staff Study - (38.1 SQM)	● Office (9)	
B00A - R1003 - Staff Study - (18.32 SQM)	● Office (4)	
B00A - R1004 - Staff Study - (34.55 SQM)	● Office (8)	
B00A - R1008 - General Learning Space - (50.33 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1009 - General Learning Space - (50.27 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1010 - General Learning Space - (50.33 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1011 - General Learning Space - (50.33 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1012 - General Learning Space - (50.26 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1013 - General Learning Space - (50.33 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1014 - Duplicating Workroom - (27.23 SQM)	● Office (6)	
B00A - R1015 - Deputy Principal Office - (13.7 SQM)	● Office (3)	
B00A - R1016 - Multi-Purpose Space - (7.43 SQM)	● Student Space (3)	
B00A - R1021 - Stage - (92.51 SQM)	Not Applicable	Circulation or storage space.
B00A - R1022 - Multi-Purpose Space - (260.45 SQM)	● Student Space (120)	
B00A - R1024 - Interview/Office - Type 1 - (15.59 SQM)	● Office (3)	
B00A - R1025 - Public Entry - (71.49 SQM)	Not Applicable	Circulation or storage space.
B00A - R1027 - Ancillary Staff - (19.88 SQM)	● Office (4)	
B00A - R1032 - Principal Office - (16.55 SQM)	● Office (4)	
B00A - R1035 - Clinic - Girls - (5.64 SQM)	● Office (1)	
B00A - R1036 - Clinic - Boys - (5.34 SQM)	● Office (1)	
B00A - R1041 - Administration - Clerical - (10.55 SQM)	● Office (2)	
B00A - R1050 - Student Canteen - (13.64 SQM)	Not Applicable	Circulation or storage space.
B00A - R1051 - Student Canteen - (69.65 SQM)	Not Applicable	Circulation or storage space.
B00A - R1054 - Movement - (19.49 SQM)	Not Applicable	Circulation or storage space.
B00A - R1055 - Movement - (223.63 SQM)	Not Applicable	Circulation or storage space.
B00A - R1056 - Administration - Clerical - (60.42 SQM)	● Office (15)	
B00A - R1057 - Movement - (19.42 SQM)	Not Applicable	Circulation or storage space.
B00A - R2001 - Staff Study - (29.75 SQM)	● Office (7)	
B00A - R2002 - Staff Study - (34.47 SQM)	● Office (8)	
B00A - R2003 - Staff Study - (8.46 SQM)	● Office (2)	
B00A - R2006 - General Learning Space - (50.09 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R2007 - General Learning Space - (49.98 SQM) - Teaching Space: 1	● Student Space (23)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R2008 - General Learning Space - (50.03 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R2009 - General Learning Space - (49.97 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R2010 - General Learning Space - (49.96 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R2011 - General Learning Space - (49.64 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R2013 - General Learning Space - (50.42 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R2014 - Leading Teacher - (15.25 SQM)	● Office (3)	
B00A - R2016 - Multi-Purpose Space - (13.94 SQM)	● Student Space (6)	
B00A - R2017 - Commonroom - (129.88 SQM)	● Office (32)	
B00A - R2018 - Movement - (193.48 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Food Technology L.S. - (115.27 SQM) - Teaching Space: 1	● Student Space (53)	
B00B - R0003 - Preparation - (15.41 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Food Technology L.S. - (110.01 SQM) - Teaching Space: 1	● Student Space (51)	
B00B - R0005 - Movement - (6.61 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Staff Study - (14.6 SQM)	● Office (3)	
B00B - R0008 - Food/Research Space - (11.78 SQM)	Not Applicable	Circulation or storage space.
B00B - R0010 - Food/Research Space - (5.69 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - General Learning Space - (55.07 SQM)	● Student Space (25)	
B00B - R1002 - Materials Technology L.S. - (59.5 SQM)	● Student Space (27)	
B00B - R1007 - Art Learning Space - (62.66 SQM) - Teaching Space: 1	● Student Space (29)	
B00B - R1008 - Interview/Office - Type 1 - (7.19 SQM)	● Office (1)	
B00B - R1012 - Movement - (53.35 SQM)	Not Applicable	Circulation or storage space.
B00B - R1016 - Performance Workspace - (115.78 SQM) - Teaching Space: 1	● Student Space (53)	
B00C - R0004 - Movement - (9.25 SQM)	Not Applicable	Circulation or storage space.
B00C - R0012 - General Learning Space - (36.08 SQM) - Teaching Space: 1	● Student Space (16)	
B00C - R0013 - Workshop Area - (163.93 SQM)	● Student Space (76)	
B00C - R0017 - General Learning Space - (57.01 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0018 - Workshop Area - (44.24 SQM)	● Student Space (20)	
B00C - R1001 - Materials Technology L.S. - (105.34 SQM) - Teaching Space: 1	● Student Space (48)	
B00C - R1002 - Movement - (8.43 SQM)	Not Applicable	Circulation or storage space.
B00C - R1003 - Staff Study - (20.35 SQM)	● Office (5)	
B00C - R1007 - Movement - (59.72 SQM)	Not Applicable	Circulation or storage space.
B00C - R1008 - Materials Technology L.S. - (132.3 SQM) - Teaching Space: 1	● Student Space (61)	
B00C - R1009 - Staff Study - (9.19 SQM)	● Office (2)	
B00C - R1011 - Staff Study - (9.07 SQM)	● Office (2)	
B00C - R1013 - Design L.S. - (52.16 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1014 - General Learning Space - (51.28 SQM) - Teaching Space: 1	● Student Space (23)	
B00C - R1017 - Staff Study - (8.61 SQM)	● Office (2)	
B00D - R0001 - Main Area - (402.32 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Audio Visual Workroom - (34.78 SQM)	● Student Space (16)	
B00D - R0004 - Workroom - (40.57 SQM)	● Office (10)	
B00D - R0006 - Entry - (16 SQM)	Not Applicable	Circulation or storage space.
B00D - R0011 - Seminar - (13.47 SQM)	● Office (3)	
B00D - R0012 - Seminar - (20.71 SQM)	● Office (5)	
B00E - R0002 - Preparation - (37.58 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - General Learning Space - (52.6 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0005 - General Learning Space - (52.89 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0010 - Laboratory L.S. - (85.78 SQM) - Teaching Space: 1	● Student Space (39)	
B00E - R0011 - Preparation - (38.8 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0012 - Laboratory L.S. - (86.09 SQM) - Teaching Space: 1	 Student Space (39)	
B00E - R0015 - Movement - (123.74 SQM)	Not Applicable	Circulation or storage space.
B00E - R0016 - Movement - (97.36 SQM)	Not Applicable	Circulation or storage space.
B00E - R0017 - Movement - (6.3 SQM)	Not Applicable	Circulation or storage space.
B00E - R0020 - Movement - (7.59 SQM)	Not Applicable	Circulation or storage space.
B00E - R0024 - Movement - (6.31 SQM)	Not Applicable	Circulation or storage space.
B00E - R0025 - General Learning Space - Type 3 - (40.15 SQM) - Teaching Space: 1	 Student Space (18)	
B00E - R0026 - Science Laboratory - (45.58 SQM)	 Student Space (21)	
B00E - R0027 - Science Laboratory - (46.82 SQM)	 Student Space (21)	
B00E - R0028 - General Learning Space - Type 3 - (40.31 SQM) - Teaching Space: 1	 Student Space (18)	
B00E - R1001 - Music Learning Space - (66.28 SQM) - Teaching Space: 1	 Student Space (30)	
B00E - R1003 - Music Learning Space - (52.53 SQM) - Teaching Space: 1	 Student Space (24)	
B00E - R1005 - Darkroom Space - (6.23 SQM)	 Office (1)	
B00E - R1006 - Darkroom Space - (13.6 SQM)	 Office (3)	
B00E - R1007 - Workroom - (11.41 SQM)	 Office (2)	
B00E - R1009 - Art Learning Space - (95.82 SQM) - Teaching Space: 1	 Student Space (44)	
B00E - R1011 - Staff Study - (26.23 SQM)	 Office (6)	
B00E - R1014 - Staff Study - (39.45 SQM)	 Office (9)	
B00E - R1018 - Computer Learning Space - (52.53 SQM) - Teaching Space: 1	 Student Space (24)	
B00E - R1019 - Workroom - (12.72 SQM)	 Office (3)	
B00E - R1020 - Staff Study - (12.79 SQM)	 Office (3)	
B00E - R1021 - Senior Study - (65.38 SQM)	 Office (16)	
B00E - R1022 - Staff Study - (12.82 SQM)	 Office (3)	
B00E - R1024 - Staff Study - (11.87 SQM)	 Office (2)	
B00E - R1026 - Movement - (109.04 SQM)	Not Applicable	Circulation or storage space.
B00E - R1031 - Movement - (82.6 SQM)	Not Applicable	Circulation or storage space.
B00E - R9004 - Movement - (15.76 SQM)	Not Applicable	Circulation or storage space.
B00E - R9006 - Movement - (17.77 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Staff Kitchen - (10.94 SQM)	 Office (2)	
B00G - R0007 - Staff Study - (47.83 SQM)	 Office (11)	
B00J - R0001 - General Assistants - (34.63 SQM)	 Office (8)	