


VENTILATION AUDIT REPORT

SCHOOL:	Lake Munmorah Public School (2362)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Swansea
LOCAL GOVERNMENT AREA:	Central Coast



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (15.1 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Special Programs Room - (16.61 SQM)	● Student Space (7)	
B00A - R0004 - Movement - (25.62 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Canteen - (44.12 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Communal Space - (228.76 SQM)	● Student Space (106)	
B00A - R0013 - Communal Space - (36.44 SQM)	● Student Space (16)	
B00B - R0001 - Clerical Office - (17.74 SQM)	● Office (4)	
B00B - R0002 - Entry Vestibule - (13.14 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Duplicating Workroom - (32.66 SQM)	● Office (8)	
B00B - R0004 - Principal - (16.78 SQM)	● Office (4)	
B00B - R0011 - Staff Room Annexe - (25.34 SQM)	● Office (6)	
B00B - R0012 - Staff Room - (58.93 SQM)	● Office (14)	
B00B - R0013 - Movement - (32.12 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Deputy Principal - (13.13 SQM)	● Office (3)	
B00B - R0015 - Deputy Principal - (13.17 SQM)	● Office (3)	
B00B - R0016 - Interview - (11.96 SQM)	● Office (2)	
B00B - R0019 - Sick Bay - (8.64 SQM)	● Student Space (4)	
B00C - R0006 - Withdrawal Space - 1hb - (5.8 SQM)	● Student Space (2)	
B00C - R0008 - Home Base - (51.08 SQM) - Teaching Space: 1	● Student Space (23)	
B00C - R0009 - Practical Activities - 1hb - (27.99 SQM)	● Student Space (12)	
B00C - R0010 - Practical Activities - 1hb - (27.89 SQM)	● Student Space (12)	
B00C - R0011 - Home Base - (51 SQM) - Teaching Space: 1	● Student Space (23)	
B00C - R0013 - Withdrawal Space - 1hb - (5.85 SQM)	● Student Space (2)	
B00D - R0003 - Practical Activities - 1hb - (27.58 SQM)	● Student Space (12)	
B00D - R0005 - Withdrawal Space - 1hb - (5.85 SQM)	● Student Space (2)	
B00D - R0006 - Home Base - (50.95 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R0007 - Home Base - (50.94 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R0008 - Withdrawal Space - 1hb - (5.82 SQM)	● Student Space (2)	
B00D - R0010 - Practical Activities - 1hb - (27.97 SQM)	● Student Space (12)	
B00D - R0011 - Practical Activities - 1hb - (28 SQM)	● Student Space (12)	
B00D - R0013 - Withdrawal Space - 1hb - (5.88 SQM)	● Student Space (2)	
B00D - R0014 - Home Base - (50.94 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R0015 - Home Base - (51.3 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R0016 - Withdrawal Space - 1hb - (5.88 SQM)	● Student Space (2)	
B00D - R0018 - Practical Activities - 1hb - (27.51 SQM)	● Student Space (12)	
B00E - R0002 - Special Programs Room - (40.18 SQM)	● Student Space (18)	
B00E - R0006 - Withdrawal Space - 1hb - (5.87 SQM)	● Student Space (2)	
B00E - R0008 - Home Base - (51.1 SQM) - Teaching Space: 1	● Student Space (23)	
B00E - R0009 - Practical Activities - 1hb - (27.33 SQM)	● Student Space (12)	
B00E - R0011 - Practical Activities - 1hb - (28.07 SQM)	● Student Space (13)	
B00E - R0012 - Home Base - (51.16 SQM) - Teaching Space: 1	● Student Space (23)	
B00E - R0013 - Withdrawal Space - 1hb - (5.87 SQM)	● Student Space (2)	
B00E - R0015 - Withdrawal Space - 1hb - (5.85 SQM)	● Student Space (2)	
B00E - R0017 - Home Base - (51.09 SQM) - Teaching Space: 1	● Student Space (23)	
B00E - R0018 - Practical Activities - 1hb - (27.96 SQM)	● Student Space (12)	
B00E - R0019 - Practical Activities - 1hb - (27.45 SQM)	● Student Space (12)	
B00E - R0020 - Home Base - (50.94 SQM) - Teaching Space: 1	● Student Space (23)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0022 - Withdrawal Space - 1hb - (5.89 SQM)	Student Space (2)	
B00F - R0006 - Practical Activities - 1hb - (27.63 SQM)	Student Space (12)	
B00F - R0008 - Withdrawal Space - 1hb - (5.82 SQM)	Student Space (2)	
B00F - R0009 - Home Base - (50.94 SQM) - Teaching Space: 1	Student Space (23)	
B00F - R0010 - Home Base - (50.8 SQM) - Teaching Space: 1	Student Space (23)	
B00F - R0011 - Withdrawal Space - 1hb - (5.89 SQM)	Student Space (2)	
B00F - R0013 - Practical Activities - 1hb - (28.01 SQM)	Student Space (12)	
B00F - R0014 - Practical Activities - 1hb - (27.97 SQM)	Student Space (12)	
B00F - R0016 - Withdrawal Space - 1hb - (5.89 SQM)	Student Space (2)	
B00F - R0017 - Home Base - (51.03 SQM) - Teaching Space: 1	Student Space (23)	
B00F - R0018 - Home Base - (50.87 SQM) - Teaching Space: 1	Student Space (23)	
B00F - R0019 - Withdrawal Space - 1hb - (5.88 SQM)	Student Space (2)	
B00F - R0021 - Practical Activities - 1hb - (27.37 SQM)	Student Space (12)	
B00G - R0006 - Reading Area - (200.15 SQM)	Student Space (92)	
B00H - R0001 - Staff Kitchen - (16.62 SQM)	Office (4)	
B00H - R0002 - Home Base - (74.05 SQM) - Teaching Space: 1	Student Space (34)	
B00H - R0003 - Home Base - (56.68 SQM) - Teaching Space: 1	Student Space (26)	
B00H - R0008 - Movement - (7.73 SQM)	Not Applicable	Circulation or storage space.
B00L - R0004 - Practical Activities - 1hb - (16.52 SQM)	Student Space (7)	
B00L - R0006 - Home Base - (58.57 SQM) - Teaching Space: 1	Student Space (27)	
B00L - R0008 - Withdrawal Space - 1hb - (9.23 SQM)	Student Space (4)	
B00L - R0009 - Practical Activities - 1hb - (14.03 SQM)	Student Space (6)	
B00L - R0011 - Home Base - (61.19 SQM) - Teaching Space: 1	Student Space (28)	
B00L - R0013 - Withdrawal Space - 2hb - (11.68 SQM)	Student Space (5)	
B00L - R0014 - Practical Activities - 1hb - (13.94 SQM)	Student Space (6)	
B00L - R0016 - Home Base - (60.7 SQM) - Teaching Space: 1	Student Space (28)	
B00L - R1001 - Practical Activities - 1hb - (14.3 SQM)	Student Space (6)	
B00L - R1003 - Home Base - (60.53 SQM) - Teaching Space: 1	Student Space (28)	
B00L - R1005 - Withdrawal Space - 2hb - (11.68 SQM)	Student Space (5)	
B00L - R1006 - Practical Activities - 1hb - (14.12 SQM)	Student Space (6)	
B00L - R1008 - Home Base - (60.83 SQM) - Teaching Space: 1	Student Space (28)	
B00L - R1011 - Practical Activities - 1hb - (17.63 SQM)	Student Space (8)	
B00L - R1014 - Withdrawal Space - 1hb - (9.23 SQM)	Student Space (4)	
B00L - R1015 - Home Base - (57.8 SQM) - Teaching Space: 1	Student Space (26)	