

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Lalor Park Public School (4191)</b>
<b>AMU REGION:</b>	<b>Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Blacktown</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Blacktown</b>

4191 - Lalor Park Public School  
Site Plan (13168)



1:859

Printed: 12-Jun-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Home Base - (93.7 SQM) - Teaching Space: 1	● Student Space (43)	
B00A - R0006 - Movement - (5.64 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Movement - (5.2 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Home Base - (91.52 SQM) - Teaching Space: 1	● Student Space (42)	
B00A - R0014 - Home Base - (65.75 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R0017 - Movement - (7.55 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Movement - (5.2 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Practical Activities - Pre - (5.4 SQM)	● Student Space (2)	
B00A - R0023 - Home Base - Pre - (53.8 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0030 - Outdoor Learning Area - (25.39 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Movement - (5.17 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Practical Activities - 1hb - (10.05 SQM)	● Student Space (4)	
B00B - R0003 - Staff Room Annexe - (18.4 SQM)	● Office (4)	
B00B - R0004 - Home Base - (67.49 SQM) - Teaching Space: 1	● Student Space (31)	
B00B - R0006 - Staff Room Annexe - (21.65 SQM)	● Office (5)	
B00B - R0008 - Movement - (22.61 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Home Base - (65.87 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R0011 - Home Base - (65.57 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R0014 - Movement - (7.88 SQM)	Not Applicable	Circulation or storage space.
B00B - R0018 - Movement - (5.17 SQM)	Not Applicable	Circulation or storage space.
B00B - R0021 - Practical Activities - 1hb - (25.23 SQM)	● Student Space (11)	
B00C - R0001 - Home Base - (68.09 SQM) - Teaching Space: 1	● Student Space (31)	
B00C - R0004 - Movement - (7.88 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - Movement - (5.22 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Communal Space - (114.71 SQM)	● Student Space (53)	
B00C - R0009 - Raised Platform - (17.34 SQM)	Not Applicable	Circulation or storage space.
B00C - R0012 - Movement - (11.37 SQM)	Not Applicable	Circulation or storage space.
B00C - R0015 - Home Base - (68.32 SQM) - Teaching Space: 1	● Student Space (31)	
B00C - R0016 - Staff Room Annexe - (12.47 SQM)	● Office (3)	
B00C - R0018 - Canteen - (23.45 SQM)	Not Applicable	Circulation or storage space.
B00C - R0021 - Movement - (5.2 SQM)	Not Applicable	Circulation or storage space.
B00C - R0024 - Movement - (25.07 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Home Base - M - (67.91 SQM) - Teaching Space: 1	● Student Space (31)	
B00D - R0004 - Movement - (7.86 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Movement - (5.17 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Home Base - (67.91 SQM) - Teaching Space: 1	● Student Space (31)	
B00E - R0001 - Home Base - (67.65 SQM) - Teaching Space: 1	● Student Space (31)	
B00E - R0004 - Movement - (7.9 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Movement - (5.2 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Home Base - (67.65 SQM) - Teaching Space: 1	● Student Space (31)	
B00F - R0001 - Home Base - (67.56 SQM) - Teaching Space: 1	● Student Space (31)	
B00F - R0004 - Movement - (7.87 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Movement - (5.22 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Practical Activities - 1hb - (65.83 SQM)	● Student Space (30)	
B00F - R0009 - Practical Activities - 1hb - (65.58 SQM)	● Student Space (30)	
B00F - R0014 - Home Base - (67.47 SQM) - Teaching Space: 1	● Student Space (31)	
B00F - R0015 - Staff Room Annexe - (17.77 SQM)	● Office (4)	
B00F - R0017 - Movement - (5.22 SQM)	Not Applicable	Circulation or storage space.
B00F - R0021 - Staff Room - (23.45 SQM)	● Office (5)	
B00F - R0022 - Movement - (12.21 SQM)	Not Applicable	Circulation or storage space.
B00G - R0006 - Withdrawal Space - 1hb - (13.87 SQM)	● Student Space (6)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0007 - Movement - (5.2 SQM)	Not Applicable	Circulation or storage space.
B00G - R0009 - Home Base - (56.96 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0010 - Home Base - (56.89 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0013 - Movement - (6.37 SQM)	Not Applicable	Circulation or storage space.
B00G - R0014 - Movement - (5.2 SQM)	Not Applicable	Circulation or storage space.
B00G - R0017 - Home Base - (58.46 SQM) - Teaching Space: 1	● Student Space (27)	
B00H - R0004 - Entry Vestibule - (8.21 SQM)	Not Applicable	Circulation or storage space.
B00H - R0006 - Principal - (17.13 SQM)	○ Office (4)	
B00H - R0008 - Interview - (26.16 SQM)	○ Office (6)	
B00H - R0009 - Movement - (11.86 SQM)	Not Applicable	Circulation or storage space.
B00H - R0011 - Movement - (7.36 SQM)	Not Applicable	Circulation or storage space.
B00H - R0013 - Movement - (24.65 SQM)	Not Applicable	Circulation or storage space.
B00H - R0014 - Clerical Office - (43.98 SQM)	○ Office (10)	
B00H - R0017 - Clerical Office - (36.58 SQM)	○ Office (9)	
B00H - R0019 - Sick Bay - (6.88 SQM)	● Student Space (3)	
B00H - R0022 - Movement - (15.21 SQM)	Not Applicable	Circulation or storage space.
B00H - R0026 - Home Base - (57.18 SQM) - Teaching Space: 1	● Student Space (26)	
B00H - R0027 - Home Base - (56.95 SQM) - Teaching Space: 1	● Student Space (26)	
B00H - R0030 - Movement - (11.81 SQM)	Not Applicable	Circulation or storage space.
B00H - R0033 - Staff Room - (49.64 SQM)	○ Office (12)	
B00H - R0034 - Staff Kitchen - (6.47 SQM)	○ Office (1)	
B00H - R1008 - Reading Area - (122.08 SQM)	● Student Space (56)	
B00H - R1011 - Movement - (20.27 SQM)	Not Applicable	Circulation or storage space.
B00H - R1014 - Seminar/Study - (60.62 SQM)	○ Office (15)	
B00H - R1018 - Movement - (17.12 SQM)	Not Applicable	Circulation or storage space.
B00H - R1020 - Movement - (8.03 SQM)	Not Applicable	Circulation or storage space.
B00P - R0001 - Communal Space - (146.96 SQM)	● Student Space (68)	
B00P - R0002 - Raised Platform - (57.08 SQM)	Not Applicable	Circulation or storage space.
B00P - R0003 - Movement - (7.74 SQM)	Not Applicable	Circulation or storage space.
B00P - R0005 - Movement - (13.7 SQM)	Not Applicable	Circulation or storage space.