

VENTILATION AUDIT REPORT

SCHOOL:	Lambton High School (8482)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Newcastle
LOCAL GOVERNMENT AREA:	Newcastle

8482 - Lambton High School
Site Plan (12749)



































Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Duplicating Workroom - (8.68 SQM)	Office (2)	
B00A - R0005 - Commonroom - (92.08 SQM)	Office (23)	
B00A - R0006 - Clinic-Waiting - (14.45 SQM)	Office (3)	
B00A - R0007 - Staff Study - (9.47 SQM)	Office (2)	
B00A - R0008 - Interview/Office - Type 1 - (9.68 SQM)	Office (2)	
B00A - R0013 - Principal Office - (22.55 SQM)	Office (5)	
B00A - R0016 - Deputy Principal Office - (19.91 SQM)	Office (4)	
B00A - R0017 - Interview/Office - Type 1 - (16.26 SQM)	Office (4)	
B00A - R0018 - Movement - (7.26 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Public Entry - (46.4 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Movement - (63.11 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Movement - (7.83 SQM)	Not Applicable	Circulation or storage space.
B00A - R0026 - Teachers Aides - (12.11 SQM)	Office (3)	
B00A - R0027 - Staff Study - (13.39 SQM)	Office (3)	
B00A - R0028 - Movement - (87.1 SQM)	Not Applicable	Circulation or storage space.
B00A - R0029 - Movement - (50.72 SQM)	Not Applicable	Circulation or storage space.
B00A - R0031 - Movement - (18.59 SQM)	Not Applicable	Circulation or storage space.
B00A - R0032 - Movement - (9.89 SQM)	Not Applicable	Circulation or storage space.
B00A - R0036 - Administration - Clerical - (53.12 SQM)	Office (13)	
B00A - R0038 - Movement - (17.32 SQM)	Not Applicable	Circulation or storage space.
B00A - R0039 - Staff Study - (13.22 SQM)	Office (3)	
B00A - R0040 - Staff Study - (15.32 SQM)	Office (3)	
B00A - R1001 - Computer Learning Space - (53.92 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R1002 - General Learning Space - (53.91 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R1003 - Staff Study - (22.22 SQM)	Office (5)	
B00A - R1006 - General Learning Space - (59.89 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1007 - General Learning Space - (59.88 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1008 - Senior Study - (53.84 SQM)	Office (13)	
B00A - R1009 - General Learning Space - (39.82 SQM) - Teaching Space: 1	Student Space (18)	
B00A - R1010 - General Learning Space - (39.81 SQM) - Teaching Space: 1	Student Space (18)	
B00A - R1013 - General Learning Space - (39.98 SQM) - Teaching Space: 1	Student Space (18)	
B00A - R1015 - Movement - (60.13 SQM)	Not Applicable	Circulation or storage space.
B00A - R1019 - Movement - (15.28 SQM)	Not Applicable	Circulation or storage space.
B00A - R1021 - Movement - (37.1 SQM)	Not Applicable	Circulation or storage space.
B00A - R1022 - Movement - (6.53 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - General Learning Space - (53.7 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0002 - General Learning Space - (53.7 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0003 - Staff Study - (13.01 SQM)	Office (3)	
B00B - R0005 - Staff Study - (10.6 SQM)	Office (2)	
B00B - R0008 - Darkroom Space - (7.96 SQM)	Office (1)	
B00B - R0011 - General Learning Space - (52.97 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0012 - General Learning Space - (39.45 SQM) - Teaching Space: 1	Student Space (18)	
B00B - R0013 - General Learning Space - (52.6 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0014 - General Learning Space - (51.51 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R0019 - Movement - (10.16 SQM)	Not Applicable	Circulation or storage space.
B00B - R0021 - Staff Study - (32.73 SQM)	Office (8)	
B00B - R0022 - Movement - (94.02 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - General Learning Space - (53.69 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1002 - General Learning Space - (53.7 SQM) - Teaching Space: 1	Student Space (24)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R1003 - Staff Study - (18.37 SQM)	Office (4)	
B00B - R1004 - General Learning Space - (53.7 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1005 - General Learning Space - (54.06 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R1006 - General Learning Space - (53.69 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1007 - General Learning Space - (54.06 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R1008 - Staff Study - (10.54 SQM)	Office (2)	
B00B - R1012 - General Learning Space - (53.69 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1013 - Staff Study - (39.18 SQM)	Office (9)	
B00B - R1015 - Movement - (27.34 SQM)	Not Applicable	Circulation or storage space.
B00B - R1016 - Movement - (14.93 SQM)	Not Applicable	Circulation or storage space.
B00B - R1017 - Movement - (15.05 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - General Learning Space - (53.7 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0002 - Staff Study - (24.84 SQM)	Office (6)	
B00C - R0003 - General Learning Space - (53.7 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0005 - General Learning Space - (53.7 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0006 - General Learning Space - (53.34 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0013 - Staff Study - (11.05 SQM)	Office (2)	
B00C - R0019 - General Learning Space - (53.69 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0021 - Movement - (5.91 SQM)	Not Applicable	Circulation or storage space.
B00C - R0022 - Staff Study - (50.14 SQM)	Office (12)	
B00C - R0023 - Movement - (78.09 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - General Learning Space - (53.7 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1002 - General Learning Space - (53.69 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1003 - Movement - (18.73 SQM)	Not Applicable	Circulation or storage space.
B00C - R1004 - Staff Study - (18.2 SQM)	Office (4)	
B00C - R1005 - General Learning Space - (53.69 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1006 - General Learning Space - (54.43 SQM) - Teaching Space: 1	Student Space (25)	
B00C - R1007 - General Learning Space - (53.7 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1008 - General Learning Space - (54.44 SQM) - Teaching Space: 1	Student Space (25)	
B00C - R1012 - Staff Study - (10.72 SQM)	Office (2)	
B00C - R1013 - Staff Study - (39.45 SQM)	Office (9)	
B00C - R1014 - General Learning Space - (53.33 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1015 - Movement - (27.9 SQM)	Not Applicable	Circulation or storage space.
B00C - R1017 - Movement - (13.08 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - General Assistants - (23.31 SQM)	Office (5)	
B00D - R0006 - Laboratory L.S. - (90.57 SQM) - Teaching Space: 1	Student Space (42)	
B00D - R0007 - Preparation - (48.46 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Laboratory L.S. - (90.56 SQM) - Teaching Space: 1	Student Space (42)	
B00D - R0009 - Movement - (63.68 SQM)	Not Applicable	Circulation or storage space.
B00D - R1004 - General Learning Space - (90.08 SQM) - Teaching Space: 1	Student Space (41)	
B00D - R1005 - Staff Study - (48.46 SQM)	Office (12)	
B00D - R1006 - Art Learning Space - (90.25 SQM) - Teaching Space: 1	Student Space (41)	
B00D - R1007 - Movement - (60.55 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Welding Area - (10.81 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Materials Technology L.S. - (72.06 SQM) - Teaching Space: 1	Student Space (33)	
B00E - R0007 - Metal Technology Bay - (10.44 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Materials Technology L.S. - (82.87 SQM) - Teaching Space: 1	Student Space (38)	
B00E - R0009 - Darkroom Space - (18.27 SQM)	Office (4)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0010 - Art Learning Space - (63.93 SQM) - Teaching Space: 1	 Student Space (29)	
B00E - R0012 - Movement - (37.69 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - Design L.S. - (52.08 SQM) - Teaching Space: 1	 Student Space (24)	
B00E - R1004 - Materials Technology L.S. - (83.02 SQM) - Teaching Space: 1	 Student Space (38)	
B00E - R1007 - Materials Technology L.S. - (83.01 SQM) - Teaching Space: 1	 Student Space (38)	
B00E - R1010 - Design L.S. - (52.82 SQM) - Teaching Space: 1	 Student Space (24)	
B00E - R1011 - Staff Study - (26.05 SQM)	 Office (6)	
B00E - R1013 - Movement - (46.56 SQM)	Not Applicable	Circulation or storage space.
B00F - R0012 - Student Canteen - (52.44 SQM)	Not Applicable	Circulation or storage space.
B00F - R0015 - Tiered Learning Area - (187.14 SQM)	 Student Space (86)	
B00F - R0016 - Audio Visual Workroom - (120.05 SQM)	 Student Space (55)	
B00F - R0019 - Student Canteen - (38.75 SQM)	Not Applicable	Circulation or storage space.
B00F - R0021 - Staff Study - (30.4 SQM)	 Office (7)	
B00F - R0022 - Movement - (15.03 SQM)	Not Applicable	Circulation or storage space.
B00F - R0023 - Movement - (37.65 SQM)	Not Applicable	Circulation or storage space.
B00F - R0026 - Gymnasium - (47.55 SQM)	 Student Space (22)	
B00F - R1012 - Movement - (11.64 SQM)	Not Applicable	Circulation or storage space.
B00F - R1013 - Movement - (13.8 SQM)	Not Applicable	Circulation or storage space.
B00F - R1019 - Movement - (13.72 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Food Technology L.S. - (81.97 SQM) - Teaching Space: 1	 Student Space (38)	
B00G - R0008 - General Learning Space - (65.67 SQM) - Teaching Space: 1	 Student Space (30)	
B00G - R0011 - Staff Study - (32.34 SQM)	 Office (8)	
B00G - R0013 - Staff Study - (17.49 SQM)	 Office (4)	
B00G - R0018 - Food Technology L.S. - (113.85 SQM) - Teaching Space: 1	 Student Space (52)	
B00G - R0019 - Preparation - Materials - (20.72 SQM)	Not Applicable	Circulation or storage space.
B00G - R0024 - Movement - (71.45 SQM)	Not Applicable	Circulation or storage space.
B00G - R0026 - Staff Study - (9.74 SQM)	 Office (2)	
B00G - R1001 - Materials Technology L.S. - (65.3 SQM) - Teaching Space: 1	 Student Space (30)	
B00G - R1002 - Music Learning Space - (65.29 SQM) - Teaching Space: 1	 Student Space (30)	
B00G - R1003 - Staff Study - (32.16 SQM)	 Office (8)	
B00G - R1004 - Music Learning Space - (65.3 SQM) - Teaching Space: 1	 Student Space (30)	
B00G - R1005 - Darkroom Space - (13.87 SQM)	 Office (3)	
B00G - R1006 - Art Learning Space - (65.3 SQM) - Teaching Space: 1	 Student Space (30)	
B00G - R1007 - Art Learning Space - (64.86 SQM) - Teaching Space: 1	 Student Space (30)	
B00G - R1009 - Materials Technology L.S. - (64.97 SQM) - Teaching Space: 1	 Student Space (30)	
B00G - R1016 - Movement - (56.48 SQM)	Not Applicable	Circulation or storage space.
B00H - M1001 - Main Area - (154.8 SQM)	Not Applicable	Circulation or storage space.
B00H - M1002 - Seminar - (23.82 SQM)	 Office (5)	
B00H - M1003 - Seminar - (23.82 SQM)	 Office (5)	
B00H - R0001 - Laboratory L.S. - (91.58 SQM) - Teaching Space: 1	 Student Space (42)	
B00H - R0002 - Preparation - (49.26 SQM)	Not Applicable	Circulation or storage space.
B00H - R0003 - Laboratory L.S. - (91.58 SQM) - Teaching Space: 1	 Student Space (42)	
B00H - R0005 - Laboratory L.S. - (91.57 SQM) - Teaching Space: 1	 Student Space (42)	
B00H - R0006 - Preparation - (49.27 SQM)	Not Applicable	Circulation or storage space.
B00H - R0007 - Laboratory L.S. - (91.57 SQM) - Teaching Space: 1	 Student Space (42)	
B00H - R0010 - Movement - (58.58 SQM)	Not Applicable	Circulation or storage space.
B00H - R0015 - Movement - (11.64 SQM)	Not Applicable	Circulation or storage space.
B00H - R0016 - Movement - (87.88 SQM)	Not Applicable	Circulation or storage space.
B00H - R1003 - Workroom - (13.69 SQM)	 Office (3)	
B00H - R1005 - Audio Visual Workroom - (35.55 SQM)	 Student Space (16)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R1007 - Seminar - (13.03 SQM)	Office (3)	
B00H - R1008 - Seminar - (14.6 SQM)	Office (3)	
B00H - R1009 - Seminar - (13.6 SQM)	Office (3)	
B00H - R1013 - Seminar - (14.36 SQM)	Office (3)	
B00H - R1014 - Seminar - (12.96 SQM)	Office (3)	
B00H - R1015 - Main Area - (379.42 SQM)	Not Applicable	Circulation or storage space.
B00H - R1016 - Movement - (17.25 SQM)	Not Applicable	Circulation or storage space.
B00H - R1017 - Movement - (125.46 SQM)	Not Applicable	Circulation or storage space.
B00I - M0001 - Movement - (39.96 SQM)	Not Applicable	Circulation or storage space.
B00I - M0002 - Multi-Purpose Space - (94.82 SQM)	Student Space (43)	
B00I - M0003 - Music Learning Space - (43.35 SQM) - Teaching Space: 1	Student Space (20)	
B00I - R0004 - Movement - (10.59 SQM)	Not Applicable	Circulation or storage space.
B00I - R0009 - Movement - (11.23 SQM)	Not Applicable	Circulation or storage space.
B00I - R0012 - Multi-Purpose Space - (479.28 SQM)	Student Space (222)	
B00I - R0019 - Movement - (24.76 SQM)	Not Applicable	Circulation or storage space.
B00I - R0020 - Staff Kitchen - (12.46 SQM)	Office (3)	
B00I - R0021 - Movement - (6.34 SQM)	Not Applicable	Circulation or storage space.
B00I - R0025 - Movement - (5.18 SQM)	Not Applicable	Circulation or storage space.
B00I - R0026 - Movement - (8.36 SQM)	Not Applicable	Circulation or storage space.
B00I - R0027 - Movement - (10.55 SQM)	Not Applicable	Circulation or storage space.
B00I - R0028 - Movement - (10.56 SQM)	Not Applicable	Circulation or storage space.
B00I - R0029 - Movement - (32.84 SQM)	Not Applicable	Circulation or storage space.
B00I - R0030 - Movement - (10.55 SQM)	Not Applicable	Circulation or storage space.
B00I - R0031 - Movement - (10.55 SQM)	Not Applicable	Circulation or storage space.
B00I - R0036 - Stage - (89.84 SQM)	Not Applicable	Circulation or storage space.
B00J - R0007 - Movement - (6.91 SQM)	Not Applicable	Circulation or storage space.
B00J - R1001 - Movement - (8.15 SQM)	Not Applicable	Circulation or storage space.
B00J - R1002 - Movement - (14.03 SQM)	Not Applicable	Circulation or storage space.
B00J - R1004 - Movement - (9.78 SQM)	Not Applicable	Circulation or storage space.
B00J - R1005 - Movement - (14.11 SQM)	Not Applicable	Circulation or storage space.
B00K - R0002 - Movement - (13.58 SQM)	Not Applicable	Circulation or storage space.
B00K - R0006 - Movement - (6.3 SQM)	Not Applicable	Circulation or storage space.
B00K - R1001 - Movement - (6.41 SQM)	Not Applicable	Circulation or storage space.
B00K - R1002 - Movement - (14.09 SQM)	Not Applicable	Circulation or storage space.
B00K - R1003 - Movement - (6.32 SQM)	Not Applicable	Circulation or storage space.
B00L - R0002 - Movement - (6.84 SQM)	Not Applicable	Circulation or storage space.
B00L - R0003 - Movement - (83.08 SQM)	Not Applicable	Circulation or storage space.
B00L - R1001 - Movement - (81.34 SQM)	Not Applicable	Circulation or storage space.