

VENTILATION AUDIT REPORT

SCHOOL:	Lambton Public School (2366)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Wallsend
LOCAL GOVERNMENT AREA:	Newcastle

2366 - Lambton Public School
Site Plan (12748)



1:767

Printed: 18-Jul-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Clerical Office - (18.56 SQM)	Office (4)	
B00A - R0002 - Movement - (17.47 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Sick Bay - (13.55 SQM)	Student Space (6)	
B00A - R0004 - Deputy Principal - (13.63 SQM)	Office (3)	
B00A - R0011 - Clerical Office - (13.75 SQM)	Office (3)	
B00A - R0012 - Duplicating Workroom - (13.68 SQM)	Office (3)	
B00A - R0014 - Entry Vestibule - (12.58 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Movement - (11.17 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Principal - (20.45 SQM)	Office (5)	
B00A - R0020 - Staff Room - (64.8 SQM)	Office (16)	
B00B - R0001 - Movement - (39.24 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Home Base - (60.31 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0003 - Home Base - (60.1 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0004 - Home Base - (64.63 SQM) - Teaching Space: 1	Student Space (29)	
B00B - R0005 - Movement - (21.68 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Movement - (18.64 SQM)	Not Applicable	Circulation or storage space.
B00B - R0010 - Withdrawal Space - 2hb - (37.48 SQM)	Student Space (17)	
B00C - R0002 - Home Base - (48.27 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R0003 - Movement - (21.88 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Home Base - (48.34 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R0005 - Home Base - (55.45 SQM) - Teaching Space: 1	Student Space (25)	
B00C - R0006 - Home Base - (115 SQM)	Student Space (53)	
B00C - R0007 - Raised Platform - (22.52 SQM)	Not Applicable	Circulation or storage space.
B00C - R0010 - Movement - (21.01 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - Home Base - (71.39 SQM) - Teaching Space: 1	Student Space (33)	
B00C - R0014 - Home Base - (65.72 SQM) - Teaching Space: 1	Student Space (30)	
B00F - R0001 - Movement - (52.04 SQM)	Not Applicable	Circulation or storage space.
B00F - R0004 - Home Base - (57.95 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0005 - Home Base - (58.1 SQM) - Teaching Space: 1	Student Space (26)	
B00G - R0001 - Movement - (26.76 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Home Base - (50.95 SQM) - Teaching Space: 1	Student Space (23)	
B00G - R0003 - Home Base - (50.74 SQM) - Teaching Space: 1	Student Space (23)	
B00H - R0002 - Home Base - (52.31 SQM) - Teaching Space: 1	Student Space (24)	
B00H - R0003 - Home Base - (52.25 SQM) - Teaching Space: 1	Student Space (24)	
B00H - R0006 - Practical Activities - 2hb - (13.7 SQM)	Student Space (6)	
B00H - R0007 - Practical Activities - 1hb - (9.97 SQM)	Student Space (4)	
B00I - R0001 - Movement - (140.41 SQM)	Not Applicable	Circulation or storage space.
B00I - R0007 - Reading Area - (158.11 SQM)	Student Space (73)	
B00I - R0008 - Special Programs Room - (44.02 SQM)	Student Space (20)	
B00K - R0001 - Movement - (18.74 SQM)	Not Applicable	Circulation or storage space.
B00K - R0004 - Canteen - (19.99 SQM)	Not Applicable	Circulation or storage space.
B00L - R0005 - Communal Space - (200.36 SQM)	Student Space (92)	
B00L - R0016 - Movement - (17.38 SQM)	Not Applicable	Circulation or storage space.
B00L - R0017 - Raised Platform - (59 SQM)	Not Applicable	Circulation or storage space.
B00L - R0019 - Movement - (5.96 SQM)	Not Applicable	Circulation or storage space.
B00L - R0021 - Canteen - (38.71 SQM)	Not Applicable	Circulation or storage space.
OS 602 10243 - OS 602 10243 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 11080 - OS 602 11080 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	