


VENTILATION AUDIT REPORT

SCHOOL:	Lane Cove West Public School (3908)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Lane Cove
LOCAL GOVERNMENT AREA:	Lane Cove

3908 - Lane Cove West Public School
Site Plan (11173)



Printed: 05-May-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R0002 - Staff Room Annexe - (13.06 SQM)	Office (3)	
B00B - R0004 - Home Base - (46.93 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0006 - Home Base - (46.93 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0007 - Home Base - (46.93 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0008 - Home Base - (46.93 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0009 - Home Base - (46.93 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0010 - Home Base - (41.64 SQM) - Teaching Space: 1	Student Space (19)	
B00B - R0011 - Practical Activities - 1hb - (5.29 SQM)	Student Space (2)	
B00B - R0013 - Movement - (88.01 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Home Base - (47.98 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R0003 - Practical Activities - 1hb - (5.6 SQM)	Student Space (2)	
B00C - R0004 - Practical Activities - 1hb - (5.91 SQM)	Student Space (2)	
B00C - R0005 - Home Base - (47.67 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R0006 - Home Base - (53.58 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0008 - Interview - (13.66 SQM)	Office (3)	
B00C - R0015 - Movement - (41.7 SQM)	Not Applicable	Circulation or storage space.
B00C - R0016 - Movement - (5.75 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Reading Area - (158.34 SQM)	Student Space (73)	
B00D - R0006 - Special Programs Room - (43.74 SQM)	Student Space (20)	
B00D - R0011 - Movement - (139.21 SQM)	Not Applicable	Circulation or storage space.
B00D - R0012 - Special Programs Room - (38.13 SQM)	Student Space (17)	
B00N - R0001 - Home Base - (61.38 SQM) - Teaching Space: 1	Student Space (28)	
B00N - R0002 - Practical Activities - (19.24 SQM)	Student Space (8)	
B00N - R0004 - Withdrawal Space - 2hb - (11.77 SQM)	Student Space (5)	
B00N - R0005 - Home Base - (60.76 SQM) - Teaching Space: 1	Student Space (28)	
B00N - R0006 - Practical Activities - (19.18 SQM)	Student Space (8)	
B00N - R0009 - Home Base - (60.54 SQM) - Teaching Space: 1	Student Space (28)	
B00N - R0010 - Practical Activities - (19.27 SQM)	Student Space (8)	
B00N - R0011 - Withdrawal Space - 2hb - (11.77 SQM)	Student Space (5)	
B00N - R0012 - Home Base - (60.72 SQM) - Teaching Space: 1	Student Space (28)	
B00N - R0013 - Practical Activities - (19.19 SQM)	Student Space (8)	
B00N - R0016 - Home Base - (61.05 SQM) - Teaching Space: 1	Student Space (28)	
B00N - R0017 - Practical Activities - (19.19 SQM)	Student Space (8)	
B00N - R0018 - Withdrawal Space - 2hb - (11.81 SQM)	Student Space (5)	
B00N - R0019 - Home Base - (61.73 SQM) - Teaching Space: 1	Student Space (28)	
B00N - R0020 - Practical Activities - (19.17 SQM)	Student Space (8)	
B00O - R0001 - Entry Vestibule - (24.94 SQM)	Not Applicable	Circulation or storage space.
B00O - R0002 - Clerical Office - (36.55 SQM)	Office (9)	
B00O - R0003 - Clerical/Printing - (22.83 SQM)	Not Applicable	Circulation or storage space.
B00O - R0004 - Sick Bay - (8.64 SQM)	Student Space (4)	
B00O - R0006 - Deputy Principal - (16.74 SQM)	Office (4)	
B00O - R0009 - Staff Room - (47.81 SQM)	Office (11)	
B00O - R0010 - Staff Room - (19.26 SQM)	Office (4)	
B00O - R0011 - Deputy Principal - (12.91 SQM)	Office (3)	
B00O - R0015 - Movement - (53.08 SQM)	Not Applicable	Circulation or storage space.
B00O - R0017 - Principal - (17.03 SQM)	Office (4)	
B00O - R0018 - Interview - (12.91 SQM)	Office (3)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00Q - R0002 - Communal Space - (198.54 SQM)	● Student Space (92)	
B00Q - R0003 - Raised Platform - (53.67 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0017 - Movement - (5.05 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0018 - Movement - (16.56 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0020 - Canteen - (41.62 SQM)	Not Applicable	Circulation or storage space.
B00T - R0001 - Practical Activities - 1hb - (18.16 SQM)	● Student Space (8)	
B00T - R0002 - Practical Activities - 1hb - (18.15 SQM)	● Student Space (8)	
B00T - R0003 - Home Base - (56.5 SQM) - Teaching Space: 1	● Student Space (26)	
B00T - R0006 - Home Base - (56.5 SQM) - Teaching Space: 1	● Student Space (26)	
B00T - R0007 - Withdrawal Space - 2hb - (10.6 SQM)	● Student Space (4)	
B00T - R1001 - Practical Activities - 1hb - (18.28 SQM)	● Student Space (8)	
B00T - R1002 - Practical Activities - 1hb - (18.28 SQM)	● Student Space (8)	
B00T - R1003 - Home Base - (56.59 SQM) - Teaching Space: 1	● Student Space (26)	
B00T - R1006 - Home Base - (56.59 SQM) - Teaching Space: 1	● Student Space (26)	
B00T - R1007 - Withdrawal Space - 2hb - (10.95 SQM)	● Student Space (5)	
OS 602 13295 - OS 602 13295 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 14014 - OS 602 14014 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 17699 - OS 602 17699 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 603 13608 - OS 603 13608 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	
OS 603 13715 - OS 603 13715 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	