

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Lansdowne Public School (2370)</b>
<b>AMU REGION:</b>	<b>North Coast</b>
<b>STATE ELECTORATE:</b>	<b>Port Macquarie</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Mid-Coast</b>

2370 - Lansdowne Public School  
Site Plan (12751)


















1:998

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Practical Activities - 1hb - (30.4 SQM)	 Student Space (14)	
B00A - R0003 - Home Base - (58.43 SQM) - Teaching Space: 1	 Student Space (27)	
B00A - R0006 - Entry Vestibule - (11.42 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Clerical Office - (10.2 SQM)	 Office (2)	
B00A - R0011 - Sick Bay - (9.84 SQM)	 Student Space (4)	
B00A - R0013 - Movement - (11.87 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Principal - (11.98 SQM)	 Office (2)	
B00A - R0018 - Staff Room - (35.53 SQM)	 Office (8)	
B00A - R0019 - Staff Kitchen - (5.56 SQM)	 Office (1)	
B00B - R0001 - Practical Activities - 1hb - (17.23 SQM)	 Student Space (7)	
B00B - R0002 - Home Base - (53.66 SQM) - Teaching Space: 1	 Student Space (24)	
B00B - R0003 - Staff Room - (28.53 SQM)	 Office (7)	
B00E - R0002 - Home Base - (46.14 SQM) - Teaching Space: 1	 Student Space (21)	
B00E - R0003 - Practical Activities - 1hb - (27.06 SQM)	 Student Space (12)	
B00E - R0004 - Home Base - (46.01 SQM) - Teaching Space: 1	 Student Space (21)	
B00E - R0006 - Canteen - (26.61 SQM)	Not Applicable	Circulation or storage space.
B00G - R0005 - Special Programs Room - (33.51 SQM)	 Student Space (15)	
B00G - R0006 - Movement - (5.22 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Reading Area - (58.81 SQM)	 Student Space (27)	