

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Lansvale East Public School (4391)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Cabramatta</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Fairfield</b>

4391 - Lansvale East Public School  
Site Plan (11174)



1:999

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0004 - Special Programs Room - (56.83 SQM)	● Student Space (26)	
B00A - R0005 - Home Base - (56.99 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0008 - Movement - (5.8 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Home Base - (56.75 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0014 - Home Base - (56.91 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0019 - Interview - (18.59 SQM)	● Office (4)	
B00A - R0022 - Clerical Office - (5.86 SQM)	● Office (1)	
B00A - R0023 - Entry Vestibule - (14.45 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Movement - (13.66 SQM)	Not Applicable	Circulation or storage space.
B00A - R0029 - Staff Room - (30.35 SQM)	● Office (7)	
B00B - R0003 - Home Base - (57.07 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0004 - Home Base - (56.99 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0002 - Reading Area - (91.5 SQM)	● Student Space (42)	
B01A - R0005 - Home Base - (56.69 SQM) - Teaching Space: 1	● Student Space (26)	
B01A - R0006 - Home Base - (85.66 SQM) - Teaching Space: 1	● Student Space (39)	
OS 502 11307 - OS 502 11307 - Admin Staff/Principal/Clerk/Dup/Clinic - (152 SQM)	● Office (38)	
OS 602 11398 - OS 602 11398 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 12745 - OS 602 12745 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 18131 - OS 602 18131 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 606 19008 - OS 606 19008 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 621 15002 - OS 621 15002 - Learning Unit Single - PWD - (95 SQM)	● Student Space (44)	
OS 811 11308 - OS 811 11308 - FSU/Shelter/Stores - (209 SQM)	Not Applicable	Circulation or storage space.