

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Lapstone Public School (4424)</b>
<b>AMU REGION:</b>	<b>Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Penrith</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Blue Mountains</b>

4424 - Lapstone Public School  
Site Plan (10637)



1:1,010

Printed: 26-Sep-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0009 - Home Base - (95.1 SQM) - Teaching Space: 1	● Student Space (44)	
B00A - R0010 - Home Base - (95.1 SQM) - Teaching Space: 1	● Student Space (44)	
B00A - R0017 - Canteen - (23.85 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Movement - (12.27 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Principal - (14.49 SQM)	● Office (3)	
B00A - R0028 - Entry Vestibule - (13.15 SQM)	Not Applicable	Circulation or storage space.
B00A - R0029 - Clerical Office - (21.22 SQM)	● Office (5)	
B00A - R0030 - Interview - (11.9 SQM)	● Office (2)	
B00A - R0031 - Sick Bay - (9.66 SQM)	● Student Space (4)	
B00C - R0003 - Home Base - (62.82 SQM) - Teaching Space: 1	● Student Space (29)	
B00C - R0009 - Home Base - (63.36 SQM) - Teaching Space: 1	● Student Space (29)	
B00C - R0010 - Home Base - (63.37 SQM) - Teaching Space: 1	● Student Space (29)	
B00C - R0019 - Home Base - (62.89 SQM) - Teaching Space: 1	● Student Space (29)	
B00E - R0002 - Practical Activities - 1hb - (10.35 SQM)	● Student Space (4)	
B00E - R0003 - Home Base - (68.28 SQM) - Teaching Space: 1	● Student Space (31)	
B00E - R0006 - Practical Activities - 1hb - (15.23 SQM)	● Student Space (7)	
B00E - R0007 - Home Base - (63.33 SQM) - Teaching Space: 1	● Student Space (29)	
B00E - R0009 - Home Base - (63.16 SQM) - Teaching Space: 1	● Student Space (29)	
B00E - R0010 - Practical Activities - 1hb - (15.23 SQM)	● Student Space (7)	
B00E - R0013 - Practical Activities - 1hb - (10.41 SQM)	● Student Space (4)	
B00E - R0014 - Home Base - (68.2 SQM) - Teaching Space: 1	● Student Space (31)	
B00J - R0001 - Communal Space - (148.03 SQM)	● Student Space (68)	
B00J - R0002 - Raised Platform - (59.78 SQM)	Not Applicable	Circulation or storage space.
B00J - R0003 - Movement - (6.41 SQM)	Not Applicable	Circulation or storage space.
B00J - R0004 - Movement - (11.38 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Withdrawal Space - 1hb - (34.24 SQM)	● Student Space (15)	
OS 521 13333 - OS 521 13333 - Staff Study - (76 SQM)	● Office (19)	
OS 534 14349 - OS 534 14349 - Library/Group Study/Office/A V Store - (152 SQM)	● Student Space (70)	