

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Largs Public School (2374)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Maitland</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Maitland</b>

2374 - Largs Public School  
Site Plan (12754)



1:640

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Movement - (5.18 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Principal - (9.79 SQM)	Office (2)	
B00A - R0004 - Home Base - (56.63 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0005 - Canteen - (23.83 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Movement - (13.11 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Home Base - (44.51 SQM) - Teaching Space: 1	Student Space (20)	
B00B - R0004 - Clerical Office - (8.6 SQM)	Office (2)	
B00B - R0008 - Entry Vestibule - (6.25 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Clerical Office - (7.96 SQM)	Office (1)	
B00B - R0010 - Principal - (16.54 SQM)	Office (4)	
B00B - R0015 - Staff Room - (27.62 SQM)	Office (6)	
B00C - R0003 - Home Base - (47.34 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R0004 - Home Base - (45.74 SQM) - Teaching Space: 1	Student Space (21)	
B00K - R0002 - Practical Activities - 1hb - (19.38 SQM)	Student Space (8)	
B00K - R0003 - Home Base - (58.72 SQM) - Teaching Space: 1	Student Space (27)	
B00K - R0005 - Withdrawal Space - 2hb - (10.68 SQM)	Student Space (4)	
B00K - R0006 - Practical Activities - 1hb - (19.38 SQM)	Student Space (8)	
B00K - R0007 - Home Base - (58.82 SQM) - Teaching Space: 1	Student Space (27)	
B00N - R0002 - Practical Activities - 1hb - (17.83 SQM)	Student Space (8)	
B00N - R0003 - Home Base - (61.28 SQM) - Teaching Space: 1	Student Space (28)	
B00N - R0004 - Withdrawal Space - 2hb - (16.45 SQM)	Student Space (7)	
B00N - R0007 - Home Base - (61.14 SQM) - Teaching Space: 1	Student Space (28)	
OS 602 14659 - OS 602 14659 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	