


VENTILATION AUDIT REPORT

| | |
|-------------------------------|---------------------------------------|
| SCHOOL: | Laurieton Public School (2377) |
| AMU REGION: | North Coast |
| STATE ELECTORATE: | Port Macquarie |
| LOCAL GOVERNMENT AREA: | Port Macquarie-Hastings |

2377 - Laurieton Public School
Site Plan (13469)



Ventilation Audit Key

| Category | Description |
|---|--|
|  | Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings. |
|  | Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces. |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|---|---|-------------------------------|
| B001 - R0004 - Entry Vestibule - (8.58 SQM) | Not Applicable | Circulation or storage space. |
| B001 - R0008 - Sick Bay - (5.8 SQM) | ● Student Space (2) | |
| B001 - R0009 - Clerical Office - (15.71 SQM) | ● Office (3) | |
| B001 - R0012 - Home Base - (56.27 SQM) - Teaching Space: 1 | ● Student Space (26) | |
| B001 - R0016 - Movement - (5.76 SQM) | Not Applicable | Circulation or storage space. |
| B001 - R0018 - Sick Bay - (13.12 SQM) | ● Student Space (6) | |
| B001 - R0021 - Clerical Office - (18.82 SQM) | ● Office (4) | |
| B001 - R0022 - Entry Vestibule - (8.88 SQM) | Not Applicable | Circulation or storage space. |
| B001 - R0023 - Interview - (12.47 SQM) | ● Office (3) | |
| B002 - R0002 - Reading Area - (92.72 SQM) | ● Student Space (43) | |
| B003 - R0003 - Home Base - (53.29 SQM) - Teaching Space: 1 | ● Student Space (24) | |
| B003 - R0007 - Home Base - (67.59 SQM) - Teaching Space: 1 | ● Student Space (31) | |
| B003 - R0008 - Practical Activities - 1hb - (17.64 SQM) | ● Student Space (8) | |
| B003 - R0011 - Staff Room - (57.01 SQM) | ● Office (14) | |
| B003 - R0020 - Canteen - (21.58 SQM) | Not Applicable | Circulation or storage space. |
| B007 - R0002 - Withdrawal Space - 1hb - (44.02 SQM) | ● Student Space (20) | |
| B009 - R0002 - Practical Activities - 1hb - (19.39 SQM) | ● Student Space (8) | |
| B009 - R0004 - Home Base - (59.2 SQM) - Teaching Space: 1 | ● Student Space (27) | |
| B009 - R0005 - Withdrawal Space - 2hb - (11.36 SQM) | ● Student Space (5) | |
| B009 - R0006 - Home Base - (59.19 SQM) - Teaching Space: 1 | ● Student Space (27) | |
| B009 - R0008 - Practical Activities - 1hb - (19.4 SQM) | ● Student Space (9) | |
| B010 - R0001 - Communal Space - (145.26 SQM) | ● Student Space (67) | |
| B010 - R0002 - Raised Platform - (56.08 SQM) | Not Applicable | Circulation or storage space. |
| B010 - R0016 - Movement - (7.14 SQM) | Not Applicable | Circulation or storage space. |
| B010 - R0017 - Movement - (15.27 SQM) | Not Applicable | Circulation or storage space. |
| B010 - R0018 - Movement - (11.84 SQM) | Not Applicable | Circulation or storage space. |
| OS 601 10185 - OS 601 10185 - Learning Unit - Standard/Withdrawal - (76 SQM) | ● Student Space (35) | |
| OS 601 10209 - OS 601 10209 - Learning Unit - Standard/Withdrawal - (76 SQM) | ● Student Space (35) | |
| OS 602 16191 - OS 602 16191 - Learning Unit - Standard With P.A.A. - (76 SQM) | ● Student Space (35) | |