

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Lavington Public School (2378)</b>
<b>AMU REGION:</b>	<b>Southern NSW</b>
<b>STATE ELECTORATE:</b>	<b>Albury</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Albury</b>

2378 - Lavington Public School  
Site Plan (12756)















1:1,561

Printed: 19-Dec-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0005 - Principal - (17.35 SQM)	Office (4)	
B00A - R0006 - Sick Bay - (8.39 SQM)	Student Space (3)	
B00A - R0007 - Staff Room Annexe - (11.63 SQM)	Office (2)	
B00A - R0010 - Staff Room - (51.08 SQM)	Office (12)	
B00A - R0011 - Staff Kitchen - (11.87 SQM)	Office (2)	
B00A - R0012 - Movement - (16.91 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Staff Room Annexe - (12.8 SQM)	Office (3)	
B00A - R0014 - Duplicating Workroom - (29.95 SQM)	Office (7)	
B00A - R0015 - Clerical Office - (14.06 SQM)	Office (3)	
B00A - R0016 - Entry Vestibule - (18.04 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Movement - (82.56 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Home Base - (62.66 SQM) - Teaching Space: 1	Student Space (29)	
B00B - R0008 - Home Base - (64.65 SQM) - Teaching Space: 1	Student Space (29)	
B00B - R0011 - Practical Activities - 1hb - (7.91 SQM)	Student Space (3)	
B00B - R0012 - Practical Activities - 1hb - (7.95 SQM)	Student Space (3)	
B00B - R0013 - Special Programs Room - (83.61 SQM)	Student Space (38)	
B00D - R0001 - Movement - (18.03 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Home Base - (64.89 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R0003 - Movement - (9.03 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Home Base - (57.23 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0003 - Home Base - (57.17 SQM) - Teaching Space: 1	Student Space (26)	
B00E - R0009 - Withdrawal Space - 1hb - (22.51 SQM)	Student Space (10)	
B00E - R0011 - Clerical Office - (16.92 SQM)	Office (4)	
B00F - R0006 - Movement - (78.49 SQM)	Not Applicable	Circulation or storage space.
B00F - R0007 - Communal Space - (134.55 SQM)	Student Space (62)	
B00F - R0008 - Canteen - (26.36 SQM)	Not Applicable	Circulation or storage space.
B00F - R0012 - Movement - (24.64 SQM)	Not Applicable	Circulation or storage space.
B00F - R0015 - Raised Platform - (53.53 SQM)	Not Applicable	Circulation or storage space.
B00F - R0016 - Movement - (6.29 SQM)	Not Applicable	Circulation or storage space.
B00F - R0019 - Movement - (17.48 SQM)	Not Applicable	Circulation or storage space.
B00F - R0020 - Movement - (6.47 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Movement - (48.45 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Withdrawal Space - 1hb - (20.1 SQM)	Student Space (9)	
B00G - R0005 - Home Base - (57.41 SQM) - Teaching Space: 1	Student Space (26)	
B00G - R0008 - Withdrawal Space - 1hb - (19.35 SQM)	Student Space (8)	
B00G - R0009 - Home Base - (57.47 SQM) - Teaching Space: 1	Student Space (26)	
B00H - R0001 - Home Base - (57.8 SQM) - Teaching Space: 1	Student Space (26)	
B00H - R0004 - Withdrawal Space - 1hb - (24.66 SQM)	Student Space (11)	
B00H - R0006 - Home Base - (57.63 SQM) - Teaching Space: 1	Student Space (26)	
B00H - R0007 - Home Base - (57.73 SQM) - Teaching Space: 1	Student Space (26)	
B00H - R0010 - Interview - (12.91 SQM)	Office (3)	
B00H - R0011 - Home Base - (66.75 SQM) - Teaching Space: 1	Student Space (30)	
B00H - R0012 - Home Base - (53.85 SQM) - Teaching Space: 1	Student Space (24)	
B00H - R0013 - Movement - (104.76 SQM)	Not Applicable	Circulation or storage space.
B00I - R0004 - Movement - (91.03 SQM)	Not Applicable	Circulation or storage space.
B00I - R0006 - Home Base - (65.95 SQM) - Teaching Space: 1	Student Space (30)	
B00I - R0007 - Home Base - (93.87 SQM) - Teaching Space: 1	Student Space (43)	
B00I - R0009 - Practical Activities - 1hb - (8.22 SQM)	Student Space (3)	
B00I - R0010 - Practical Activities - 1hb - (6.3 SQM)	Student Space (2)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00I - R0011 - Special Programs Room - (56.23 SQM) - Teaching Space: 1	 Student Space (26)	
B00L - R0001 - Reading Area - (169.76 SQM)	 Student Space (78)	
B00L - R0007 - Movement - (89.87 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - Home Base - (59.98 SQM) - Teaching Space: 1	 Student Space (27)	
B00M - R0003 - Practical Activities - (19.11 SQM)	 Student Space (8)	
B00M - R0004 - Withdrawal Space - 2hb - (11.56 SQM)	 Student Space (5)	
B00M - R0005 - Home Base - (60.2 SQM) - Teaching Space: 1	 Student Space (27)	
B00M - R0006 - Practical Activities - (19.05 SQM)	 Student Space (8)	
B00M - R0008 - Practical Activities - (19.05 SQM)	 Student Space (8)	
B00M - R0010 - Home Base - (60.2 SQM) - Teaching Space: 1	 Student Space (27)	
B00M - R0011 - Withdrawal Space - 2hb - (11.56 SQM)	 Student Space (5)	
B00M - R0012 - Practical Activities - (19.05 SQM)	 Student Space (8)	
B00M - R0013 - Home Base - (60.2 SQM) - Teaching Space: 1	 Student Space (27)	