


VENTILATION AUDIT REPORT

SCHOOL:	Leeville Public School (1740)
AMU REGION:	North Coast
STATE ELECTORATE:	Clarence
LOCAL GOVERNMENT AREA:	Richmond Valley

1740 - Leeville Public School
Site Plan (12760)






















1:1,182

Printed: 20-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Withdrawal Space - 1hb - (6.98 SQM)	 Student Space (3)	
B00A - R0004 - Practical Activities - 1hb - (18.29 SQM)	 Student Space (8)	
B00A - R0005 - Home Base - (64.84 SQM) - Teaching Space: 1	 Student Space (30)	
B00A - R0008 - Home Base - (65.02 SQM) - Teaching Space: 1	 Student Space (30)	
B00A - R0009 - Practical Activities - 1hb - (18.36 SQM)	 Student Space (8)	
B00A - R0013 - Withdrawal Space - 1hb - (6.94 SQM)	 Student Space (3)	
B00C - R0001 - Staff Room - (19.01 SQM)	 Office (4)	
B00D - R0003 - Canteen - (14.99 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Entry Vestibule - (8 SQM)	Not Applicable	Circulation or storage space.
B00F - R0010 - Clerical Office - (18 SQM)	 Office (4)	
B00F - R0011 - Sick Bay - (7 SQM)	 Student Space (3)	
B00F - R0012 - Principal - (15 SQM)	 Office (3)	
B00F - R0013 - Practical Activities - 1hb - (7 SQM)	 Student Space (3)	
B00F - R0014 - Home Base - (43 SQM) - Teaching Space: 1	 Student Space (19)	
B00H - R0002 - Clerical Office - (19.07 SQM)	 Office (4)	
B00H - R0004 - Sick Bay - (7.58 SQM)	 Student Space (3)	
B00H - R0007 - Entry Vestibule - (19.47 SQM)	Not Applicable	Circulation or storage space.
B00H - R0008 - Staff Room - (21.38 SQM)	 Office (5)	
B00H - R0009 - Staff Kitchen - (5.19 SQM)	 Office (1)	
B00H - R0011 - Principal - (17.13 SQM)	 Office (4)	
B00H - R0012 - Reading Area - (71.83 SQM)	 Student Space (33)	
B00H - R0015 - Clerical Office/Workroom - (13.68 SQM)	 Office (3)	