

VENTILATION AUDIT REPORT

SCHOOL:	Leonay Public School (4475)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Penrith
LOCAL GOVERNMENT AREA:	Penrith

4475 - Leonay Public School
Site Plan (10463)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0004 - Practical Activities - 1hb - (20.02 SQM)	● Student Space (9)	
B00A - R0005 - Home Base - (54.22 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R0006 - Home Base - (54.13 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R0007 - Practical Activities - 1hb - (20.02 SQM)	● Student Space (9)	
B00A - R0016 - Home Base - (60.97 SQM) - Teaching Space: 1	● Student Space (28)	
B00A - R0018 - Practical Activities - 1hb - (13.51 SQM)	● Student Space (6)	
B00A - R0019 - Practical Activities - 1hb - (13.29 SQM)	● Student Space (6)	
B00A - R0020 - Home Base - (61 SQM) - Teaching Space: 1	● Student Space (28)	
B00A - R0026 - Movement - (69.31 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Practical Activities - 1hb - (21.45 SQM)	● Student Space (9)	
B00B - R0003 - Home Base - (73.73 SQM) - Teaching Space: 1	● Student Space (34)	
B00B - R0004 - Practical Activities - 1hb - (21.35 SQM)	● Student Space (9)	
B00B - R0005 - Home Base - (73.63 SQM) - Teaching Space: 1	● Student Space (34)	
B00B - R0009 - Practical Activities - 1hb - (19.48 SQM)	● Student Space (9)	
B00B - R0010 - Home Base - (54.32 SQM) - Teaching Space: 1	● Student Space (25)	
B00B - R0011 - Home Base - (54.32 SQM) - Teaching Space: 1	● Student Space (25)	
B00B - R0012 - Practical Activities - 1hb - (19.59 SQM)	● Student Space (9)	
B00B - R0018 - Movement - (85.18 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Staff Room - (44.51 SQM)	● Office (11)	
B00C - R0003 - Deputy Principal - (13.43 SQM)	● Office (3)	
B00C - R0004 - Deputy Principal - (13.21 SQM)	● Office (3)	
B00C - R0006 - Entry Vestibule - (19.13 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - Clerical Office - (11.92 SQM)	● Office (2)	
B00C - R0008 - Principal - (23.56 SQM)	● Office (5)	
B00C - R0015 - Canteen - (23.3 SQM)	Not Applicable	Circulation or storage space.
B00C - R0018 - Movement - (5.62 SQM)	Not Applicable	Circulation or storage space.
B00C - R0019 - Duplicating Workroom - (13.25 SQM)	● Office (3)	
B00C - R0020 - Sick Bay - (16.03 SQM)	● Student Space (7)	
B00C - R0022 - Movement - (14.69 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Movement - (40.95 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Communal Space - (139.55 SQM)	● Student Space (64)	
B00D - R0004 - Raised Platform - (28.56 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Seminar/Study - (11 SQM)	● Office (2)	
B00E - R0012 - Movement - (12.15 SQM)	Not Applicable	Circulation or storage space.
B00E - R0013 - Reading Area - (177.51 SQM)	● Student Space (82)	
B00G - R0003 - Special Programs Room - (32.74 SQM)	● Student Space (15)	
B00G - R0004 - Practical Activities - 1hb - (18.33 SQM)	● Student Space (8)	
B00G - R0006 - Home Base - (59.27 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0007 - Withdrawal Space - 2hb - (11.16 SQM)	● Student Space (5)	
B00G - R0008 - Home Base - (59.21 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0010 - Practical Activities - 1hb - (18.39 SQM)	● Student Space (8)	
B00G - R0012 - Withdrawal Space - 1hb - (8.65 SQM)	● Student Space (4)	
B00G - R0013 - Home Base - (58.44 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0014 - Practical Activities - 1hb - (18.3 SQM)	● Student Space (8)	