


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Leppington Public School (2926)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Camden</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Camden</b>

2926 - Leppington Public School  
Site Plan (11175)





1:1,187

Printed: 30-Mar-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (13.19 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Principal - (23.36 SQM)	Office (5)	
B00A - R0003 - Sick Bay - (7.34 SQM)	Student Space (3)	
B00A - R0004 - Interview - (15.46 SQM)	Office (3)	
B00A - R0006 - Entry Vestibule - (20.25 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Clerical Office - (21.07 SQM)	Office (5)	
B00A - R0010 - Movement - (15.68 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Communal Space - (91.12 SQM)	Student Space (42)	
B00B - R0002 - Staff Room Annexe - (10.4 SQM)	Office (2)	
B00B - R0004 - Movement - (26.36 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Home Base - (56.76 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0006 - Home Base - (56.46 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0011 - Home Base - (57.6 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0019 - Home Base - (57.86 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0020 - Movement - (132.09 SQM)	Not Applicable	Circulation or storage space.
B00D - R0021 - Practical Activities/Movement - 2hb - (13.76 SQM)	Student Space (6)	
B00E - R0003 - Special Programs Room - (39.98 SQM)	Student Space (18)	
B00E - R0009 - Movement - (10.53 SQM)	Not Applicable	Circulation or storage space.
B00E - R0012 - Reading Area - (155.27 SQM)	Student Space (72)	
B00E - R0014 - Movement - (122.15 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Movement - (13.65 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Canteen - (18.02 SQM)	Not Applicable	Circulation or storage space.
B00H - R0003 - Movement - (14.4 SQM)	Not Applicable	Circulation or storage space.
B00H - R0005 - Home Base - (41.69 SQM) - Teaching Space: 1	Student Space (19)	
B00H - R0006 - Practical Activities - 1hb - (13.93 SQM)	Student Space (6)	
B00I - R0001 - Home Base - (47.21 SQM) - Teaching Space: 1	Student Space (21)	
B00I - R0002 - Movement - (12.14 SQM)	Not Applicable	Circulation or storage space.
B00J - R0004 - Home Base - (57.04 SQM) - Teaching Space: 1	Student Space (26)	
B00J - R0005 - Home Base - (67.16 SQM) - Teaching Space: 1	Student Space (31)	
B00J - R0006 - Practical Activities - 1hb - (5.98 SQM)	Student Space (2)	
B00J - R0009 - Movement - (8.14 SQM)	Not Applicable	Circulation or storage space.
B00J - R0011 - Movement - (7.65 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Practical Activities - (44.02 SQM)	Student Space (20)	
B00K - R0002 - Withdrawal Space - 1hb - (5.8 SQM)	Student Space (2)	
B00L - R0001 - Home Base - (54.04 SQM) - Teaching Space: 1	Student Space (25)	
B00L - R0004 - Staff Room Annexe - (9.4 SQM)	Office (2)	
B00L - R0005 - Special Programs Room - (13.44 SQM)	Student Space (6)	
B00M - R0001 - Home Base - (54.11 SQM) - Teaching Space: 1	Student Space (25)	
B00M - R0007 - Practical Activities - 1hb - (7.9 SQM)	Student Space (3)	
B00M - R0010 - Home Base - (56.96 SQM) - Teaching Space: 1	Student Space (26)	
B00P - R0001 - Movement - (8.79 SQM)	Not Applicable	Circulation or storage space.
OS 602 10054 - OS 602 10054 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 10620 - OS 602 10620 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 11025 - OS 602 11025 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 13012 - OS 602 13012 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 13574 - OS 602 13574 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 14111 - OS 602 14111 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 14766 - OS 602 14766 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	

Entity Location	Audit Condition Classification (Capacity)	Comment
OS 602 14914 - OS 602 14914 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 15390 - OS 602 15390 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	