

VENTILATION AUDIT REPORT

SCHOOL:	Les Powell School (5712)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Cabramatta
LOCAL GOVERNMENT AREA:	Fairfield

5712 - Les Powell School
Site Plan (10547)



1:964

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Staff Room Annexe - (16.85 SQM)	Office (4)	
B00A - R0004 - Movement - (15.58 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Entry Vestibule - (27.83 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Clerical Office - (13.87 SQM)	Office (3)	
B00A - R0011 - Principal - (13.87 SQM)	Office (3)	
B00A - R0012 - Duplicating Workroom - (10.47 SQM)	Office (2)	
B00A - R0014 - Staff Room Annexe - (14.48 SQM)	Office (3)	
B00A - R0020 - Movement - (6.41 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Movement - (65.37 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Staff Room - (25.44 SQM)	Office (6)	
B00A - R0026 - Staff Kitchen - (5.79 SQM)	Office (1)	
B00A - R0027 - Home Base - S - (28.17 SQM) - Teaching Space: 1	Student Space (13)	
B00A - R0028 - Practical Activities - S - 1hb - (28.56 SQM)	Student Space (13)	
B00A - R0030 - Staff Kitchen - (6.59 SQM)	Office (1)	
B00A - R0031 - Practical Activities - M - 1hb - (28.57 SQM)	Student Space (13)	
B00A - R0032 - Home Base - M - (30.18 SQM) - Teaching Space: 1	Student Space (14)	
B00B - R0002 - Movement - (39.33 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Practical Activities - P - 1hb - (10.92 SQM)	Student Space (5)	
B00B - R0016 - Movement - (12.88 SQM)	Not Applicable	Circulation or storage space.
B00B - R0020 - Movement - (6.36 SQM)	Not Applicable	Circulation or storage space.
B00B - R0022 - Practical Activities - P - 1hb - (28.23 SQM)	Student Space (13)	
B00B - R0027 - Movement - (70.73 SQM)	Not Applicable	Circulation or storage space.
B00B - R0029 - Movement - (28.23 SQM)	Not Applicable	Circulation or storage space.
B00B - R0030 - Home Base - S - (43.99 SQM) - Teaching Space: 1	Student Space (20)	
B00B - R0031 - Practical Activities - S - 1hb - (22.41 SQM)	Student Space (10)	
B00B - R0032 - Practical Activities - S - 1hb - (33.15 SQM)	Student Space (15)	
B00B - R0033 - Home Base - S - (28.04 SQM) - Teaching Space: 1	Student Space (13)	
B00B - R0034 - Home Base - S - (28.56 SQM) - Teaching Space: 1	Student Space (13)	
B00B - R0035 - Practical Activities - S - 1hb - (28.51 SQM)	Student Space (13)	
B00B - R0036 - Practical Activities - S - 1hb - (28.75 SQM)	Student Space (13)	
B00B - R0037 - Home Base - S - (28.31 SQM) - Teaching Space: 1	Student Space (13)	
B00C - R0003 - Withdrawal - P - (6.12 SQM)	Student Space (2)	
B00C - R0004 - Home Base - (54.74 SQM) - Teaching Space: 1	Student Space (25)	
B00C - R0005 - Practical Activities - P - 1hb - (54.59 SQM)	Student Space (25)	
B00C - R0010 - Home Base - P - (54.59 SQM) - Teaching Space: 1	Student Space (25)	
B00C - R0011 - Staff Room Annexe - (8.56 SQM)	Office (2)	
B00C - R0012 - Staff Room Annexe - (8.19 SQM)	Office (2)	
B00C - R0013 - Movement - (38.11 SQM)	Not Applicable	Circulation or storage space.
B00C - R0017 - Hydrotherapy - Pool - (214.14 SQM)	Not Applicable	Circulation or storage space.
B00C - R0024 - Movement - (54.08 SQM)	Not Applicable	Circulation or storage space.
B00C - R0026 - Outdoor Learning Area - (20.29 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Movement - (9.28 SQM)	Not Applicable	Circulation or storage space.
NS 120 13820 - NS 120 13820 - Learning Unit Primary Single - PWD - (76 SQM)	Student Space (35)	
NS 120 15521 - NS 120 15521 - Learning Unit Primary Single - PWD - (76 SQM)	Student Space (35)	
OS 621 14330 - OS 621 14330 - Learning Unit Single - PWD - (95 SQM)	Student Space (44)	
OS 621 15821 - OS 621 15821 - Learning Unit Single - PWD - (95 SQM)	Student Space (44)	
OS 621 17716 - OS 621 17716 - Learning Unit Single - PWD - (95 SQM)	Student Space (44)	