

VENTILATION AUDIT REPORT

SCHOOL:	Leumeah Public School (4058)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Macquarie Fields
LOCAL GOVERNMENT AREA:	Campbelltown

4058 - Leumeah Public School
Site Plan (10465)



1:1,104

Printed: 02-Sep-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Practical Activities - 1hb - (16.29 SQM)	● Student Space (7)	
B00A - R0003 - Home Base - (56.69 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0005 - Interview - (14.01 SQM)	● Office (3)	
B00A - R0010 - Movement - (20.82 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Duplicating Workroom - (23.21 SQM)	● Office (5)	
B00A - R0012 - Staff Room Annexe - (17.98 SQM)	● Office (4)	
B00A - R0013 - Movement - (63.19 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Clerical Office - (5.4 SQM)	● Office (1)	
B00A - R0015 - Deputy Principal - (14.68 SQM)	● Office (3)	
B00A - R0017 - Clerical Office - (33.79 SQM)	● Office (8)	
B00A - R0018 - Sick Bay - (9.24 SQM)	● Student Space (4)	
B00A - R0019 - Movement - (19.12 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Deputy Principal - (12.48 SQM)	● Office (3)	
B00A - R0024 - Principal - (16.35 SQM)	● Office (4)	
B00A - R0025 - Staff Room - (79.35 SQM)	● Office (19)	
B00A - R0026 - Movement - (109.89 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Practical Activities - 1hb - (11.7 SQM)	● Student Space (5)	
B00B - R0003 - Home Base - (91.57 SQM) - Teaching Space: 1	● Student Space (42)	
B00B - R0004 - Home Base - (91.56 SQM) - Teaching Space: 1	● Student Space (42)	
B00B - R0005 - Practical Activities - 1hb - (11.7 SQM)	● Student Space (5)	
B00B - R0007 - Practical Activities - 1hb - (20.62 SQM)	● Student Space (9)	
B00B - R0008 - Home Base - (57.5 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0014 - Movement - (97.65 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Practical Activities - 1hb - (21.48 SQM)	● Student Space (9)	
B00C - R0002 - Home Base - (56.59 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0003 - Home Base - (56.65 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0004 - Practical Activities - 1hb - (21.5 SQM)	● Student Space (9)	
B00C - R0010 - Movement - (77.19 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Home Base - (57.81 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0002 - Practical Activities - 1hb - (20.64 SQM)	● Student Space (9)	
B00D - R0003 - Practical Activities - 1hb - (20.64 SQM)	● Student Space (9)	
B00D - R0004 - Home Base - (57.82 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0005 - Movement - (24.42 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Canteen - (30.41 SQM)	Not Applicable	Circulation or storage space.
B00D - R0014 - Movement - (82.07 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Home Base - (57.5 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0002 - Practical Activities - 1hb - (20.62 SQM)	● Student Space (9)	
B00E - R0003 - Practical Activities - 1hb - (20.62 SQM)	● Student Space (9)	
B00E - R0004 - Home Base - (57.5 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0005 - Movement - (64.74 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Home Base - (57.64 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0002 - Practical Activities - 1hb - (20.68 SQM)	● Student Space (9)	
B00F - R0003 - Practical Activities - 1hb - (20.68 SQM)	● Student Space (9)	
B00F - R0004 - Home Base - (57.64 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0005 - Home Base - (91.37 SQM) - Teaching Space: 1	● Student Space (42)	
B00F - R0006 - Practical Activities - 1hb - (13.33 SQM)	● Student Space (6)	
B00F - R0010 - Movement - (86.03 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Home Base - (57.57 SQM) - Teaching Space: 1	● Student Space (26)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0002 - Practical Activities - 1hb - (20.65 SQM)	● Student Space (9)	
B00G - R0003 - Practical Activities - 1hb - (20.6 SQM)	● Student Space (9)	
B00G - R0004 - Home Base - (57.44 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0005 - Home Base - (57.43 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0006 - Practical Activities - 1hb - (20.61 SQM)	● Student Space (9)	
B00G - R0007 - Practical Activities - 1hb - (19.45 SQM)	● Student Space (9)	
B00G - R0008 - Home Base - (57.52 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0012 - Movement - (97.75 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Communal Space - (222.3 SQM)	● Student Space (103)	
B00H - R0002 - Raised Platform - (37.86 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - Movement - (7.23 SQM)	Not Applicable	Circulation or storage space.
B00H - R0008 - Staff Kitchen - (13.33 SQM)	● Office (3)	
B00H - R0013 - Shared Study Space - (15.44 SQM)	● Office (3)	
B00H - R0018 - Movement - (7.29 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Home Base - (70.06 SQM) - Teaching Space: 1	● Student Space (32)	
B00L - R0002 - Practical Activities - 1hb - (25.12 SQM)	● Student Space (11)	
B00L - R0003 - Practical Activities - 1hb - (25.13 SQM)	● Student Space (11)	
B00L - R0004 - Home Base - (69.17 SQM) - Teaching Space: 1	● Student Space (32)	
B00L - R0005 - Home Base - (70.05 SQM) - Teaching Space: 1	● Student Space (32)	
B00L - R0006 - Practical Activities - 1hb - (25.12 SQM)	● Student Space (11)	
B00L - R0007 - Practical Activities - 1hb - (25.13 SQM)	● Student Space (11)	
B00L - R0008 - Home Base - (70.05 SQM) - Teaching Space: 1	● Student Space (32)	
B00L - R0010 - Movement - (95.04 SQM)	Not Applicable	Circulation or storage space.
B00L - R1001 - Entry Vestibule - (13.1 SQM)	Not Applicable	Circulation or storage space.
B00L - R1009 - Reading Area - (31.45 SQM)	● Student Space (14)	
B00L - R1011 - Reading Area - (276.11 SQM)	● Student Space (128)	
B00L - R1012 - Movement - (12.19 SQM)	Not Applicable	Circulation or storage space.
B00M - R0002 - Movement - (5.13 SQM)	Not Applicable	Circulation or storage space.
B00M - R0004 - Special Programs Room - (33.24 SQM)	● Student Space (15)	
B00M - R0006 - Special Programs Room - (33.17 SQM)	● Student Space (15)	