


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Leura Public School (2391)</b>
<b>AMU REGION:</b>	<b>Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Blue Mountains</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Blue Mountains</b>

2391 - Leura Public School  
Site Plan (12763)



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0001 - Movement - (53.69 SQM)	Not Applicable	Circulation or storage space.
B001 - R0002 - Home Base - (67.9 SQM) - Teaching Space: 1	● Student Space (31)	
B001 - R0005 - Movement - (7.53 SQM)	Not Applicable	Circulation or storage space.
B001 - R0008 - Home Base - (65.89 SQM) - Teaching Space: 1	● Student Space (30)	
B001 - R0014 - Movement - (12.11 SQM)	Not Applicable	Circulation or storage space.
B001 - R0016 - Interview - (20.3 SQM)	● Office (5)	
B001 - R0019 - Movement - (24.05 SQM)	Not Applicable	Circulation or storage space.
B001 - R0020 - Home Base - (66.16 SQM) - Teaching Space: 1	● Student Space (30)	
B001 - R0021 - Home Base - (92.32 SQM) - Teaching Space: 1	● Student Space (42)	
B001 - R0024 - Movement - (7.46 SQM)	Not Applicable	Circulation or storage space.
B001 - R0027 - Movement - (75.64 SQM)	Not Applicable	Circulation or storage space.
B001 - R9005 - Canteen - (24.39 SQM)	Not Applicable	Circulation or storage space.
B001 - R9008 - Movement - (7.31 SQM)	Not Applicable	Circulation or storage space.
B001 - R9009 - Movement - (64.23 SQM)	Not Applicable	Circulation or storage space.
B001 - R9010 - Staff Room - (70.9 SQM)	● Office (17)	
B002 - R0005 - Movement - (54.07 SQM)	Not Applicable	Circulation or storage space.
B002 - R0006 - Movement - (10.33 SQM)	Not Applicable	Circulation or storage space.
B002 - R0007 - Home Base - (68.07 SQM) - Teaching Space: 1	● Student Space (31)	
B002 - R0008 - Withdrawal Space - 2hb - (6.2 SQM)	● Student Space (2)	
B002 - R0014 - Home Base - (58.48 SQM) - Teaching Space: 1	● Student Space (27)	
B003 - R0002 - Deputy Principal - (16.07 SQM)	● Office (4)	
B003 - R0007 - Home Base - (57.03 SQM) - Teaching Space: 1	● Student Space (26)	
B003 - R0008 - Home Base - (57.03 SQM) - Teaching Space: 1	● Student Space (26)	
B003 - R0011 - Movement - (45.1 SQM)	Not Applicable	Circulation or storage space.
B003 - R0013 - Principal - (17.28 SQM)	● Office (4)	
B003 - R0014 - Duplicating Workroom - (22.28 SQM)	● Office (5)	
B003 - R0017 - Sick Bay - (8.7 SQM)	● Student Space (4)	
B003 - R0020 - Staff Room - (25.22 SQM)	● Office (6)	
B003 - R0022 - Movement - (81.46 SQM)	Not Applicable	Circulation or storage space.
B004 - R0001 - Practical Activities - 1hb - (20.41 SQM)	● Student Space (9)	
B004 - R0002 - Home Base - (52.7 SQM) - Teaching Space: 1	● Student Space (24)	
B004 - R0004 - Movement - (31.63 SQM)	Not Applicable	Circulation or storage space.
B004 - R0006 - Movement - (36.53 SQM)	Not Applicable	Circulation or storage space.
B004 - R0007 - Home Base - (52.93 SQM) - Teaching Space: 1	● Student Space (24)	
B004 - R0008 - Practical Activities - 1hb - (20.17 SQM)	● Student Space (9)	
B004 - R0009 - Special Programs Room - (73.35 SQM)	● Student Space (34)	
B004 - R1001 - Practical Activities - 1hb - (19.71 SQM)	● Student Space (9)	
B004 - R1002 - Home Base - (52.78 SQM) - Teaching Space: 1	● Student Space (24)	
B004 - R1003 - Movement - (23.97 SQM)	Not Applicable	Circulation or storage space.
B004 - R1004 - Home Base - (52.93 SQM) - Teaching Space: 1	● Student Space (24)	
B004 - R1005 - Practical Activities - 1hb - (20.33 SQM)	● Student Space (9)	
B004 - R1006 - Movement - (7.09 SQM)	Not Applicable	Circulation or storage space.
B004 - R1007 - Movement - (33.7 SQM)	Not Applicable	Circulation or storage space.
B006 - R0001 - Movement - (204.29 SQM)	Not Applicable	Circulation or storage space.
B006 - R0003 - Staff Kitchen - (6.47 SQM)	● Office (1)	
B006 - R0004 - Communal Space - (146.55 SQM)	● Student Space (67)	
B006 - R0005 - Communal Space - (45.09 SQM)	● Student Space (20)	
B007 - R0001 - Reading Area - (166.45 SQM)	● Student Space (77)	
OS 603 11054 - OS 603 11054 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	