


VENTILATION AUDIT REPORT

SCHOOL:	Lisarow Public School (2407)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	The Entrance
LOCAL GOVERNMENT AREA:	Central Coast

2407 - Lisarow Public School
Site Plan (12769)



1:1,000

Printed: 03-Sep-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0008 - Movement - (43.54 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Communal Space - (123.69 SQM)	● Student Space (57)	
B00B - R0002 - Practical Activities - 1hb - (10.25 SQM)	● Student Space (4)	
B00B - R0003 - Home Base - (45.25 SQM) - Teaching Space: 1	● Student Space (20)	
B00B - R0004 - Special Programs Room - (44.23 SQM)	● Student Space (20)	
B00B - R0008 - Movement - (6.63 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Practical Activities - 1hb - (12.01 SQM)	● Student Space (5)	
B00C - M0001 - Clerical/Printing - (8.46 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Clerical Office - (18.82 SQM)	● Office (4)	
B00C - R0008 - Staff Kitchen - (12.15 SQM)	● Office (3)	
B00C - R0009 - Principal - (21.14 SQM)	● Office (5)	
B00C - R0012 - Deputy Principal - (13.33 SQM)	● Office (3)	
B00C - R0013 - Staff Room - (13.04 SQM)	● Office (3)	
B00C - R0014 - Clerical Office - (9.78 SQM)	● Office (2)	
B00C - R0015 - Sick Bay - (5.5 SQM)	● Student Space (2)	
B00C - R0016 - Clerical/Printing - (16.57 SQM)	Not Applicable	Circulation or storage space.
B00C - R0018 - Movement - (5.04 SQM)	Not Applicable	Circulation or storage space.
B00C - R0019 - Study Annexe - (17.68 SQM)	● Office (4)	
B00C - R0020 - Staff Room - (51.92 SQM)	● Office (12)	
B00C - R0021 - Staff Kitchen - (6.92 SQM)	● Office (1)	
B00C - R0022 - Movement - (13.2 SQM)	Not Applicable	Circulation or storage space.
B00C - R0023 - Interview - (26.83 SQM)	● Office (6)	
B00C - R0024 - Entry Vestibule - (18.5 SQM)	Not Applicable	Circulation or storage space.
B00C - R0025 - Clerical Office - (13.74 SQM)	● Office (3)	
B00C - R0026 - Movement - (8.6 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Home Base - (55.87 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R0003 - Home Base - (50.76 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R0005 - Practical Activities - 1hb - (11.74 SQM)	● Student Space (5)	
B00I - R0004 - Movement - (17.94 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Home Base - (59.94 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0003 - Practical Activity Area - (19.14 SQM)	● Student Space (8)	
B00J - R0004 - Withdrawal Space - 1hb - (11.63 SQM)	● Student Space (5)	
B00J - R0005 - Home Base - (59.39 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0007 - Practical Activity Area - (19.14 SQM)	● Student Space (8)	
B00J - R0009 - Movement - (40.59 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Interview - (16.31 SQM)	● Office (4)	
B00M - R0001 - Reading Area - (168.41 SQM)	● Student Space (78)	
B00N - R0001 - Practical Activities - 1hb - (15.86 SQM)	● Student Space (7)	
B00N - R0003 - Home Base - (58.59 SQM) - Teaching Space: 1	● Student Space (27)	
B00N - R0004 - Withdrawal Space - 1hb - (9.26 SQM)	● Student Space (4)	
B00N - R0006 - Practical Activities - 1hb - (15.32 SQM)	● Student Space (7)	
B00N - R0009 - Home Base - (61.34 SQM) - Teaching Space: 1	● Student Space (28)	
B00N - R0010 - Withdrawal Space - 2hb - (11.78 SQM)	● Student Space (5)	
B00N - R0011 - Home Base - (61.35 SQM) - Teaching Space: 1	● Student Space (28)	
B00N - R0014 - Practical Activities - 1hb - (14.58 SQM)	● Student Space (6)	
OS 601 11670 - OS 601 11670 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 602 14714 - OS 602 14714 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 801 12611 - OS 801 12611 - FSU - (57 SQM)	Not Applicable	Circulation or storage space.