

VENTILATION AUDIT REPORT

SCHOOL:	Lismore Public School (1780)
AMU REGION:	North Coast
STATE ELECTORATE:	Lismore
LOCAL GOVERNMENT AREA:	Lismore

1780 - Lismore Public School
Site Plan (10639)



1:942

Printed: 20-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Home Base - (47.03 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R0003 - Home Base - (47.01 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R0004 - Home Base - (46.96 SQM) - Teaching Space: 1	Student Space (21)	
B00A - R0005 - Staff Room Annexe - (16.55 SQM)	Office (4)	
B00A - R0009 - Practical Activities - 1hb - (72.09 SQM)	Student Space (33)	
B00A - R0010 - Staff Room Annexe - (16.39 SQM)	Office (4)	
B00A - R0012 - Movement - (5.19 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Movement - (10.99 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Home Base - (47.64 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1002 - Home Base - (47.99 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1003 - Home Base - (47.93 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R1004 - Staff Room Annexe - (18.75 SQM)	Office (4)	
B00A - R1007 - Practical Activities - 1hb - (65.64 SQM)	Student Space (30)	
B00A - R1008 - Movement - (16.93 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Special Programs Room - (16.15 SQM)	Student Space (7)	
B00B - R0003 - Movement - (29.12 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Staff Room Annexe - (16.73 SQM)	Office (4)	
B00B - R0008 - Practical Activities - 1hb - (34.57 SQM)	Student Space (16)	
B00B - R0009 - Home Base - (46.37 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0010 - Home Base - (46.85 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0011 - Home Base - (46.83 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0012 - Movement - (12.8 SQM)	Not Applicable	Circulation or storage space.
B00B - R1002 - Practical Activities - 1hb - (66.56 SQM)	Student Space (30)	
B00B - R1005 - Interview - (18.57 SQM)	Office (4)	
B00B - R1006 - Home Base - (47.84 SQM) - Teaching Space: 1	Student Space (22)	
B00B - R1007 - Home Base - (47.92 SQM) - Teaching Space: 1	Student Space (22)	
B00B - R1008 - Home Base - (47.96 SQM) - Teaching Space: 1	Student Space (22)	
B00B - R1011 - Movement - (17.04 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Clerical Office/Workroom - (13.02 SQM)	Office (3)	
B00C - R0005 - Duplicating Workroom - (19.54 SQM)	Office (4)	
B00C - R0008 - Movement - (8.46 SQM)	Not Applicable	Circulation or storage space.
B00C - R0009 - Practical Activities - 1hb - (63.93 SQM)	Student Space (29)	
B00C - R0010 - Home Base - (46.89 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R0011 - Home Base - (46.91 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R0012 - Home Base - (46.86 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R0014 - Movement - (14.74 SQM)	Not Applicable	Circulation or storage space.
B00C - R0015 - Home Base - (46.9 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R0019 - Movement - (7.49 SQM)	Not Applicable	Circulation or storage space.
B00C - R0028 - Withdrawal Space - 1hb - (24.01 SQM)	Student Space (11)	
B00C - R0029 - Interview - (10 SQM)	Office (2)	
B00C - R0030 - Interview - (11.23 SQM)	Office (2)	
B00C - R0033 - Home Base - (38 SQM) - Teaching Space: 1	Student Space (17)	
B00C - R0034 - Practical Activities/Movement - 1hb - (23.49 SQM)	Student Space (10)	
B00D - R0004 - Movement - (63.29 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Practical Activities - 1hb - (16.23 SQM)	Student Space (7)	
B00D - R0007 - Home Base - (84.79 SQM) - Teaching Space: 1	Student Space (39)	
B00D - R0008 - Home Base - (85.1 SQM) - Teaching Space: 1	Student Space (39)	
B00D - R0009 - Practical Activities - 1hb - (16.52 SQM)	Student Space (7)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R1001 - Movement - (90.2 SQM)	Not Applicable	Circulation or storage space.
B00D - R1002 - Home Base - (51.88 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1004 - Practical Activities - 1hb - (21.29 SQM)	● Student Space (9)	
B00D - R1005 - Home Base - (53.16 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1006 - Home Base - (53.55 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1007 - Practical Activities - 1hb - (21.2 SQM)	● Student Space (9)	
B00D - R1011 - Withdrawal Space - 1hb - (7.02 SQM)	● Student Space (3)	
B00E - R0001 - Movement - (170.76 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Communal Space - (192.57 SQM)	● Student Space (89)	
B00E - R0015 - Raised Platform - (52.02 SQM)	Not Applicable	Circulation or storage space.
B00E - R0019 - Canteen - (41.32 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Home Base - P - (48.42 SQM) - Teaching Space: 1	● Student Space (22)	
B00G - R0004 - Movement - (53.84 SQM)	Not Applicable	Circulation or storage space.
B00G - R0005 - Home Base - P - (43.71 SQM) - Teaching Space: 1	● Student Space (20)	
B00G - R0019 - Practical Activities - 1hb - (10.69 SQM)	● Student Space (4)	
B00G - R0025 - Home Base/Practical Activities - (43.92 SQM) - Teaching Space: 1	● Student Space (20)	
B00G - R0026 - Movement - (12.98 SQM)	Not Applicable	Circulation or storage space.
B00G - R0027 - Movement - (5.44 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Duplicating Workroom - (18.88 SQM)	● Office (4)	
B00H - R0002 - Movement - (29.19 SQM)	Not Applicable	Circulation or storage space.
B00H - R0005 - Deputy Principal - (12.31 SQM)	● Office (3)	
B00H - R0006 - Clerical Office - (12.96 SQM)	● Office (3)	
B00H - R0007 - Entry Vestibule - (13.43 SQM)	Not Applicable	Circulation or storage space.
B00H - R0008 - Movement - (156.12 SQM)	Not Applicable	Circulation or storage space.
B00H - R0009 - Clerical Office - (13 SQM)	● Office (3)	
B00H - R0010 - Sick Bay - (5.94 SQM)	● Student Space (2)	
B00H - R0013 - Principal - (16.51 SQM)	● Office (4)	
B00H - R0017 - Staff Room - (99.09 SQM)	● Office (24)	
B00H - R0018 - Staff Room - (32.6 SQM)	● Office (8)	
B00H - R0022 - Staff Room Annexe - (19.14 SQM)	● Office (4)	
B00H - R1001 - Movement - (22.92 SQM)	Not Applicable	Circulation or storage space.
B00H - R1002 - Reading Area - (269.75 SQM)	● Student Space (125)	
B00H - R1008 - Seminar/Study - (12.13 SQM)	● Office (3)	
B00H - R1010 - Movement - (31.45 SQM)	Not Applicable	Circulation or storage space.